



LP GAS TORCH

RA NO

DATE

H.T.I Score	9	Medium-Regular monitoring, Supervision
Contract		
Persons involved in RA	Name	Signatures
Foreman		
Second Foreman		
Safety Officer		
Representative		

Documentation Required	Training Required	PPE and Safety Equipment Required
OHS Act and Construction Regulations	General induction – all employees	Gloves
Appointment 6(1)	Toolbox talks	Eye protection
Appointment welding supervisor	Operating LP Gas torch	Apron
Welding and flame cutting register	RA LP Gas Torch	Overalls
		Fire extinguisher

Activity Steps		Hazards and Risks	Preventative Measures	Rating
1	PPE	Incorrect PPE used could cause burn injuries	Flame proof welding PPE to be used- Gloves, eye protection, apron	8
2	Pre-start check	Failure of equipment can lead to burns and property damage	Inspect all areas of the bottle, pipe regulator and nozzle before use and record findings	8
3	Operation		Practise good house keeping. Clear work area of all combustible materials prior to using equipment. Fire extinguisher to be on hand	12
		Incorrect lighting could cause burn injuries	Only a flint type lighter is to be used	8