



PLASTERING

RA NO

DATE

H.T.I Score	7	Medium-Regular Monitoring/ Supervision
Contract		
Persons involved in RA	Name	Signatures
Foreman		
Second Foreman		
Safety Officer		
Representative		

Documentation Required	Training Required	PPE and Safety Equipment Required
OHS Act and Construction Regulations	General induction - all employees	Overalls
Appointment 6(1)	Toolbox talks	Safety Footwear
Appointment Scaffold Supervisor	First Aider	Gloves
Scaffold Registers	Fall Protection Plan	Safety Harnesses
Appointment Ladder Inspector	Elevated positions	Respiratory Mask
Ladder Register		
Fall Protection Plan		

Activity Steps		Hazards and Risks	Preventative Measures	Rating
1	Mix mortar	Faulty hand tools can cause bruises or cuts.	Shovels and hand tools must be inspected to ensure they are in good condition.	5
		Inhalation of dry cement dust can cause lung function impairment	Dust Masks to be worn when working with dry cement	8
2	Wet walls.	Plaster can dry out or not stick to wall causing poor quality of work.	Moisten wall prior to applying mortar.	5
3	Supply mortar to plasterer	Faulty hand tools can cause bruises or cuts.	Shovels, wheelbarrows and hand tools must be inspected to ensure they are in good condition.	5
4	Apply mortar to wall.	Faulty hand tools can cause bruises or cuts.	Trowels and hand tools must be inspected to ensure they are clean and in good condition.	5
		Skin exposure to cement can cause cement burns	Gloves and overalls to be worn	5

5	Working on heights	Falling from heights can cause serious	Employees to wear Safety harnesses	11
		Working on unsafe scaffolds	Only safe to use scaffolds to be used	11
		Working on unsafe ladders	Only ladders checked on register to be used	11
		Working on drums	Workers must only work from a safe access platform	8
6	Screed mortar.	Faulty spirit level; uneven straight edge. Poor quality of work	Levels, trowels and hand tools must be inspected to ensure they are clean and in good condition., good standard of scaffolding / trestles.	5
7	Skim, float or scratch plaster to final finish.	Faulty spirit level, faulty tools can cause poor quality of work	Trowels and hand tools must be inspected to ensure they are clean and in good condition.	5
8	Clean up area.	Rubble, people could trip or fall causing bruises, scratches, cuts or fractures when falling over objects.	Good housekeeping standards to be maintained	5
9	Moisten wall.	Plaster could dry too fast causing cracks and poor quality of work	Apply water to prevent rapid drying out,	5