



## MONTHLY TOWER CRANE INSPECTION

SITE:
DATE:

EQUIPMENT NUMBER

1	A Lifting-equipment supervisor and inspector to be appointed													
2	A Lifting-equipment operator to be appointed													
3	Rigger / Banks man identified and used													
4	Load test not yet expired (valid for 12 months)													
5	Load test for chains / slings not yet expired													
6	Ladders is in good order													
7	Bolts and Pins on mast and top Tower are tight													
8	Bolts and Pins on Jib/ Counter jib are tight													
9	Bolts on steering are tight													
10	Structure is free from cracks													
11	Ropes / Sheaves / Anchors in good condition and reeved correctly													
12	Hook Assembly in good condition													
13	Chains / Hooks / Safety catches in good order													
14	All limit switches and overloads are functional and correct													
15	Brakes are functioning correctly													
16	Dead Man control switch is in proper working order													
17	Main supply cable and trailing cable in good order													
18	Travel base bolt, fish plates, rails and rail stop ends tight and in good order													
19	Larmen switch in good order													

INSPECTED BY:

CONSTRUCTION SUPERVISOR:

SIGNATURE:

SIGNATURE: