Pole Shed App Ver 01 2022 by RnH Consulting Engineers

Job No.: 8908446 **Address:** 29C Koropewa Road, KERIKERI, New Zealand **Date:** 8/18/2022

Latitude: -35.205829 **Longitude:** 173.910162 **Elevation:** 92.5 m

General Input

Roof Live Load	0.25 KPa	Roof Dead Load	0.25 KPa	Roof Live Point Load	1.1 Kn
Snow Zone	N0	Ground Snow Load	0 KPa	Roof Snow Load	0 KPa
Earthquake Zone	1	Subsoil Category	D	Exposure Zone	B
Importance Level	1	Ultimate wind & Earthquake ARI	500 Years	Max Height	6.6 m
Wind Region	NZ1	Terrain Category	2.39	Design Wind Speed	40.37 m/s
Wind Pressure	0.98 KPa	Lee Zone	NO	Ultimate Snow ARI	50 Years
Wind Category	High				

Note: Wind lateral loads are governing over Earthquake loads, So only wind loads are considered in calculations

Pressure Coefficients and Pressues

Shed Type = Gable Enclosed

For roof Cp,i = -0.3

For roof CP,e from 0 m To 6.60 m Cpe = -0.9 pe = -0.79 KPa pnet = -0.79 KPa

For roof CP,e from 6.6 m To 13.20 m Cpe = -0.5 pe = -0.44 KPa pnet = -0.44 KPa

For wall Windward Cp,i = -0.3 side Wall Cp,i = -0.3

For wall Windward and Leeward CP,e from 0 m To 30 m Cpe = 0.7 pe = 0.62 KPa pnet = 0.91 KPa

For side wall CP,e from 0 m To 6.60 m Cpe = pe = -0.57 KPa pnet = -0.57 KPa

Maximum Upward pressure used in roof member Design = 0.79 KPa

Maximum Downward pressure used in roof member Design = 0.47 KPa

Maximum Wall pressure used in Design = 0.91 KPa

Maximum Racking pressure used in Design = 0.927 KPa

Design Summary

Purlin Design

Purlin Spacing = 700 mm Purlin Span = 4800 mm Try Purlin 200x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1 K1 Medium term = 0.8 K1 Long term = 0.6 K4 =1 K5 =1 K8 Downward =1.00

K8 Upward =0.43 S1 Downward =11.27 S1 Upward =26.03

Shear Capacity of timber =3 MPa Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{1.35D}$	0.68 Kn-m	Capacity	2.39 Kn-m	Passing Percentage	**351.47 %**
$M_{1.2D+1.5L\ 1.2D+Sn\ 1.2D+WnDn}$	1.92 Kn-m	Capacity	3.18 Kn-m	Passing Percentage	**165.63 %**
$M_{0.9D-WnUp}$	-1.14 Kn-m	Capacity	-1.70 Kn-m	Passing Percentage	**149.12 %**
$V_{1.35D}$	0.57 Kn	Capacity	9.65 Kn	Passing Percentage	**1692.98 %**
$V_{1.2D+1.5L\ 1.2D+Sn\ 1.2D+WnDn}$	1.29 Kn	Capacity	12.86 Kn	Passing Percentage	**996.90 %**
$V_{0.9D-WnUp}$	-0.95 Kn	Capacity	-16.08 Kn	Passing Percentage	**1692.63 %**

Deflections

Modulus of Elasticity = 8000 MPa NZS3603 Amt 4, Table 2.3 considering at least 4 members acting together

k2 for Long Term Loads = 2

Deflection under Dead and Live Load = 10.89 mm	Limit by AS1170.0 Table C1 Span/250 = 19.20 mm
Deflection under Dead and Service Wind = 13.34 mm	Limit by AS1170.0 Table C1 Span/120 = 40.00 mm

Reactions

Maximum downward =1.29 kn Maximum upward = -0.95 kn

Number of Blocking = 0 if 0 then no blocking required, if 1 then one midspan blocking required

Rafter Design Internal

Internal Rafter Load Width = 5000 mm Internal Rafter Span = 7350 mm Try Rafter 2x300x63 LVL13

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1 K1 Medium term = 0.8 K1 Long term = 0.6 K4 =1 K5 =1 K8 Downward =1.00

K8 Upward =1.00 S1 Downward =5.30 S1 Upward =5.30

Shear Capacity of timber =5.3 MPa Bending Capacity of timber =48 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

Second page

$M_{1.35D}$	11.40 Kn-m	Capacity	48.88 Kn-m	Passing Percentage	**428.77 %**
$M_{1.2D+1.5L\ 1.2D+Sn\ 1.2D+WnDn}$	26.00 Kn-m	Capacity	65.18 Kn-m	Passing Percentage	**250.69 %**
$M_{0.9D-WnUp}$	-19.08 Kn-m	Capacity	-81.48 Kn-m	Passing Percentage	**427.04 %**
$V_{1.35D}$	6.20 Kn	Capacity	64.42 Kn	Passing Percentage	**1039.03 %**
$V_{1.2D+1.5L\ 1.2D+Sn\ 1.2D+WnDn}$	14.15 Kn	Capacity	85.9 Kn	Passing Percentage	**607.07 %**
$V_{0.9D-WnUp}$	-10.38 Kn	Capacity	-107.38 Kn	Passing Percentage	**1034.49 %**

Deflections

Modulus of Elasticity = 11000 MPa NZS3603 Amt 4, Table 2.3

k2 for Long Term Loads = 2

Deflection under Dead and Live Load = 17.835 mm	Limit by AS1170.0 Table C1 Span/250 = 30.00 mm
Deflection under Dead and Service Wind = 24.275 mm	Limit by AS1170.0 Table C1 Span/120 = 62.50 mm

Reactions

Maximum downward =14.15 kn Maximum upward = -10.38 kn

Rafter to Pole Connection check

Bolt Size = M16 Number of Bolts = 2

Calculations as per NZS 3603:1993 Amend 2005 clause 4.4

Joint Group for Rafters =J2 Joint Group for Pole = J5

Minimum Bolt edge, end and spacing for Load perpendicular to grains = 80 mm

Factor of Safety = 0.7

For Perpendicular to grain loading

K11 = 12.6 fpj = 22.7 Mpa for Rafter with effective thickness = 126 mm

For Parallel to grain loading

K11 = 2.0 fcj = 36.1 Mpa for Pole with effective thickness = 100 mm

Capacity under short term loads = 51.75 Kn > -10.38 Kn

Rafter Design External

External Rafter Load Width = 2500 mm External Rafter Span = 7311 mm Try Rafter 300x63 LVL13

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet

condition after installation)

K1 Short term = 1 K1 Medium term = 0.8 K1 Long term = 0.6 K4 =1 K5 =1 K8 Downward =1.00

K8 Upward =1.00 S1 Downward =11.01 S1 Upward =11.01

Shear Capacity of timber =5.3 MPa Bending Capacity of timber =48 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{1.35D}$	5.64 Kn-m	Capacity	21.72 Kn-m	Passing Percentage	**385.11 %**
$M_{1.2D+1.5L\ 1.2D+Sn\ 1.2D+WnDn}$	12.86 Kn-m	Capacity	28.96 Kn-m	Passing Percentage	**225.19 %**
$M_{0.9D-WnUp}$	-9.44 Kn-m	Capacity	-36.20 Kn-m	Passing Percentage	**383.47 %**
$V_{1.35D}$	3.08 Kn	Capacity	32.21 Kn	Passing Percentage	**1045.78 %**
$V_{1.2D+1.5L\ 1.2D+Sn\ 1.2D+WnDn}$	7.04 Kn	Capacity	42.95 Kn	Passing Percentage	**610.09 %**
$V_{0.9D-WnUp}$	-5.16 Kn	Capacity	-53.69 Kn	Passing Percentage	**1040.50 %**

Deflections

Modulus of Elasticity = 11000 MPa NZS3603 Amt 4, Table 2.3

k2 for Long Term Loads = 2

Deflection under Dead and Live Load = 19.82 mm	Limit by AS1170.0 Table C1 Span/250 = 30.00 mm
Deflection under Dead and Service Wind = 24.28 mm	Limit by AS1170.0 Table C1 Span/120 = 62.50 mm

Reactions

Maximum downward =7.04 kn Maximum upward = -5.16 kn

Rafter to Pole Connection check

Bolt Size = M16 Number of Bolts = 2

Calculations as per NZS 3603:1993 Amend 2005 clause 4.4

Joint Group for Rafters =J2 Joint Group for Pole = J5

Factor of Safety = 0.7

For Perpendicular to grain loading

K11 = 12.6 fpj = 22.7 Mpa for Rafter with effective thickness = 63 mm

For Parallel to grain loading

K11 = 2.0 fcj = 36.1 Mpa for Pole with effective thickness = 100 mm

Eccentric Load check

V = phi x k1 x k4 x k5 x fs x b x ds ..... (Eq 4.12) = -51.42 kn > -5.16 Kn

Single Shear Capacity under short term loads = -25.88 Kn > -5.16 Kn

Intermediate Design Front and Back

Intermediate Spacing = 2500 mm Intermediate Span = 6049 mm Try Intermediate 2x250x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1 K4 =1 K5 =1 K8 Downward =0.97

K8 Upward =1.00 S1 Downward =12.68 S1 Upward =1.04

Shear Capacity of timber =3 MPa Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{Wind+Snow}$	10.41 Kn-m	Capacity	12.02 Kn-m	Passing Percentage	**115.47 %**
$V_{0.9D-WnUp}$	6.88 Kn-m	Capacity	-40.2 Kn-m	Passing Percentage	**584.30 %**

Deflections

Modulus of Elasticity = 5400 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 56.41 mm Limit by AS1170.0 Table C1 Span/120 = 50.41 mm

Reactions

Maximum = 6.88 kn

Intermediate Design Sides

Intermediate Spacing = 3750 mm Intermediate Span = 6250 mm Try Intermediate 2x250x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1 K4 =1 K5 =1 K8 Downward =0.97

K8 Upward =1.00 S1 Downward =12.68 S1 Upward =1.06

Shear Capacity of timber =3 MPa Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{Wind+Snow}$	8.33 Kn-m	Capacity	12.02 Kn-m	Passing Percentage	**144.30 %**

$V_{0.9D-WnUp}$	5.33 Kn-m	Capacity	40.2 Kn-m	Passing Percentage	**754.22 %**

Deflections

Modulus of Elasticity = 5400 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 96.4 mm Limit by AS1170.0 Table C1 Span/120 = 52.08 mm

Reactions

Maximum = 5.33 kn

Middle Pole Design

Geometry

250 SED H5 (Minimum 300 dia. at Floor Level)	Dry Use	Height	6700 mm
Area	70650 mm2	As	52987.5 mm2
Ix	397406250 mm4	Zx	2649375 mm3
Iy	397406250 mm4	Zx	2649375 mm3
Lateral Restraint	6700 mm c/c		

Loads

Total Area over Pole = 37.5 m2

Dead	9.38 Kn	Live	9.38 Kn
Wind	17.63 Kn	Snow	0.00 Kn
Moment wind	Kn-m		
Phi	0.8	K8	0.56
K1 snow	0.8	K1 Dead	0.6
K1wind	1		

Material

Peeling	Steaming	Normal	Dry Use
fb =	36.3 MPa	fs =	2.96 MPa
fc =	18 MPa	fp =	7.2 MPa
ft =	22 MPa	E =	9257 MPa

Capacities

PhiNcx Wind	570.11 Kn	PhiMnx Wind	43.11 Kn-m	PhiVnx Wind	125.47 Kn
PhiNcx Dead	342.07 Kn	PhiMnx Dead	25.87 Kn-m	PhiVnx Dead	75.28 Kn

Checks

(Mx/PhiMnx)+(N/phiNcx) = 0.65 < 1 OK

(Mx/PhiMnx)^2+(N/phiNcx) = 0.40 < 1 OK

Deflection at top under service lateral loads = 42.52 mm < 89.33 mm

Drained Lateral Strength of Middle pile in cohesionless soils Free Head short pile

Soil Properties

Gamma	18 Kn/m3	Friction angle	30 deg	Cohesion	0 Kn/m3
K0 =	(1-sin(30)) / (1+sin(30))				
Kp =	(1+sin(30)) / (1-sin(30))				

Geometry For Middle Bay Pole

Ds =	600 mm	Pile Diameter
L =	1900 mm	Pile embedment length
f1 =	4950 mm	Distance at which the shear force is applied
f2 =	0 mm	Distance of top soil at rest pressure

Loads

Moment Wind =	25.17 Kn-m
Shear Wind =	5.09 Kn

Pile Properties

Safety Factory	0.55	
Hu =	8.92 Kn	Ultimate Lateral Strength of the Pile, Short pile
Mu =	25.70 Kn-m	Ultimate Moment Capacity of Pile

Checks

Applied Forces/Capacities = 0.98 < 1 OK

End Pole Design

Geometry For End Bay Pole

Ds =	600 mm	Pile Diameter
L =	1900 mm	Pile embedment length
f1 =	4950 mm	Distance at which the shear force is applied

f2 =	0 mm	Distance of top soil at rest pressure

Loads

Total Area over Pole = 9.375 m2

Moment Wind =	12.59 Kn-m
Shear Wind =	2.54 Kn

Pile Properties

Safety Factory	0.55	
Hu =	8.92 Kn	Ultimate Lateral Strength of the Pile, Short pile
Mu =	25.70 Kn-m	Ultimate Moment Capacity of Pile

Checks

Applied Forces/Capacities = 0.49 < 1 OK

Drained Lateral Strength of End pile in cohesionless soils Free Head short pile

Soil Properties

Gamma	18 Kn/m3	Friction angle	30 deg	Cohesion	0 Kn/m3
K0 =	(1-sin(30)) / (1+sin(30))				
Kp =	(1+sin(30)) / (1-sin(30))				

Geometry For End Bay Pole

Ds =	600 mm	Pile Diameter
L =	1900 mm	Pile embedment length
f1 =	4950 mm	Distance at which the shear force is applied
f2 =	0 mm	Distance of top soil at rest pressure

Loads

Moment Wind =	12.59 Kn-m
Shear Wind =	2.54 Kn

Pile Properties

Safety Factory	0.55	
Hu =	8.92 Kn	Ultimate Lateral Strength of the Pile, Short pile
Mu =	25.70 Kn-m	Ultimate Moment Capacity of Pile

Checks

Applied Forces/Capacities = 0.49 < 1 OK

Uplift Check

Density of Concrete = 24 Kn/m3

Density of Timber Pole = 5 Kn/m3

Due to cast in place pile, the surface interaction between soil and pile will be rough thus angle of friction between both is taken equal to soil angle of internal friction

Ks (Lateral Earth Pressure Coefficient)for cast into place concrete piles = 1.5

Formula to calculate Skin Friction = Safecty factor (0.55) x Density of Soil(18) x Height of Pile(1900) x Ks(1.5) x tan(30) x Pi x Dia of Pile(0.6) x Height of Pile(1900)

Skin Friction = 29.16 Kn

Weight of Pile + Pile Skin Friction = 32.25 Kn

Uplift on one Pile = 21.19 Kn

Uplift is ok