Pole Shed App Ver 01 2022 by RnH Consulting Engineers

Job No.: 2206017	**Address:** 690 Abel Tasman Drive, Takaka, New Zealand	**Date:** 7/28/2022
Latitude: -40.838847	**Longitude:** 172.874604	**Elevation:** 17 m

General Input

Roof Live Load	0.25 KPa	Roof Dead Load	0.25 KPa	Roof Live Point Load	1.1 Kn
Snow Zone	N2	Ground Snow Load	0 KPa	Roof Snow Load	0 KPa
Earthquake Zone	2	Subsoil Category	D	Exposure Zone	C
Importance Level	1	Ultimate wind ARI	100 Years	Max Height	6.25 m
Wind Region	NZ2	Terrain Category	2.0	Design Wind Speed	39.17 m/s
Wind Pressure	0.92 KPa	Lee Zone	NO	Ultimate ARI	100 Years
Wind Category	High				

Pressure Coefficients and Pressues

Shed Type = Gable Open

For roof Cp,i = -0.56

For roof CP,e from 0 m To 3.13 m Cpe = -1.3 pe = -0.85 KPa pnet = -1.37 KPa

For roof CP,e from 3.13 m To 6 m Cpe = -0.7 pe = -0.46 KPa pnet = -0.98 KPa

For wall Windward Cp,i = -0.56 side Wall Cp,i = -0.6

For wall Windward and Leeward CP,e from 0 m To 9 m Cpe = 0.7 pe = 0.57 KPa pnet = 1.12 KPa

For side wall CP,e from 0 m To 6.25 m Cpe = pe = -0.53 KPa pnet = 0.02 KPa

Maximum Upward pressure used in roof member Design = 1.37 KPa

Maximum Downward pressure used in roof member Design = 0.46 KPa

Maximum Wall pressure used in Design = 1.12 KPa

Maximum Racking pressure used in Design = 0.9 KPa

Design Summary

Purlin Design

Purlin Spacing = 850 mm Purlin Span = 4300 mm Try Purlin 190x45 SG8

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

Pole Shed App Ver 01 2022 by RnH Consulting Engineers

K1 Short term = 1 K1 Medium term = 0.8 K1 Long term = 0.6 K4 =1 K5 =1 K8 Downward =0.98

K8 Upward =0.72 S1 Downward =12.23 S1 Upward =18.90

Shear Capacity of timber =3 MPa Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{1.35D}$	0.66 Kn-m	Capacity	1.93 Kn-m	Passing Percentage	**292.42 %**
$M_{1.2D+1.5L\ 1.2D+Sn\ 1.2D+WnDn}$	1.77 Kn-m	Capacity	2.57 Kn-m	Passing Percentage	**145.20 %**
$M_{0.9D-WnUp}$	-2.25 Kn-m	Capacity	-2.37 Kn-m	Passing Percentage	**105.33 %**
$V_{1.35D}$	0.62 Kn	Capacity	8.25 Kn	Passing Percentage	**1330.65 %**
$V_{1.2D+1.5L\ 1.2D+Sn\ 1.2D+WnDn}$	1.39 Kn	Capacity	11.00 Kn	Passing Percentage	**791.37 %**
$V_{0.9D-WnUp}$	-2.09 Kn	Capacity	-13.75 Kn	Passing Percentage	**657.89 %**

Deflections

Modulus of Elasticity = 8000 MPa NZS3603 Amt 4, Table 2.3 considering at least 4 members acting together

k2 for Long Term Loads = 2

Deflection under Dead and Live Load = 11.03 mm	Limit by AS1170.0 Table C1 Span/250 = 17.20 mm
Deflection under Dead and Service Wind = 13.42 mm	Limit by AS1170.0 Table C1 Span/120 = 35.83 mm

Reactions

Maximum downward =1.39 kn Maximum upward = -2.09 kn

Number of Blocking = 1 if 0 then no blocking required, if 1 then one midspan blocking required

Rafter Design Internal

Internal Rafter Load Width = 4500 mm Internal Rafter Span = 5850 mm Try Rafter 2x240x45 LVL13

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1 K1 Medium term = 0.8 K1 Long term = 0.6 K4 =1 K5 =1 K8 Downward =1.00

K8 Upward =1.00 S1 Downward =6.71 S1 Upward =6.71

Shear Capacity of timber =5.3 MPa Bending Capacity of timber =48 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{1.35D}$	6.50 Kn-m	Capacity	22.34 Kn-m	Passing Percentage	**343.69 %**
$M_{1.2D+1.5L\ 1.2D+Sn\ 1.2D+WnDn}$	14.63 Kn-m	Capacity	29.8 Kn-m	Passing Percentage	**203.69 %**

Second page

$M_{0.9D-WnUp}$	-22.04 Kn-m	Capacity	-37.24 Kn-m	Passing Percentage	**168.97 %**
$V_{1.35D}$	4.44 Kn	Capacity	36.82 Kn	Passing Percentage	**829.28 %**
$V_{1.2D+1.5L\ 1.2D+Sn\ 1.2D+WnDn}$	10.00 Kn	Capacity	49.08 Kn	Passing Percentage	**490.80 %**
$V_{0.9D-WnUp}$	-15.07 Kn	Capacity	-61.36 Kn	Passing Percentage	**407.17 %**

Deflections

Modulus of Elasticity = 11000 MPa NZS3603 Amt 4, Table 2.3

k2 for Long Term Loads = 2

Deflection under Dead and Live Load = 17.98 mm	Limit by AS1170.0 Table C1 Span/250 = 24.00 mm
Deflection under Dead and Service Wind = 24.305 mm	Limit by AS1170.0 Table C1 Span/120 = 50.00 mm

Reactions

Maximum downward =10.00 kn Maximum upward = -15.07 kn

Rafter to Pole Connection check

Bolt Size = M12 Number of Bolts = 2

Calculations as per NZS 3603:1993 Amend 2005 clause 4.4

Joint Group for Rafters =J2 Joint Group for Pole = J5

Minimum Bolt edge, end and spacing for Load perpendicular to grains = 60 mm

Factor of Safety = 0.7

For Perpendicular to grain loading

K11 = 12.6 fpj = 22.7 Mpa for Rafter with effective thickness = 90 mm

For Parallel to grain loading

K11 = 2.0 fcj = 36.1 Mpa for Pole with effective thickness = 100 mm

Capacity under short term loads = 29.11 Kn > -15.07 Kn

Rafter Design External

External Rafter Load Width = 2250 mm External Rafter Span = 2841 mm Try Rafter 290x45 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1 K1 Medium term = 0.8 K1 Long term = 0.6 K4 =1 K5 =1 K8 Downward =0.89

K8 Upward =0.89 S1 Downward =15.23 S1 Upward =15.23

Shear Capacity of timber =3 MPa Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{1.35D}$	0.77 Kn-m	Capacity	3.80 Kn-m	Passing Percentage	**493.51 %**
$M_{1.2D+1.5L\ 1.2D+Sn\ 1.2D+WnDn}$	1.73 Kn-m	Capacity	5.06 Kn-m	Passing Percentage	**292.49 %**
$M_{0.9D-WnUp}$	-2.60 Kn-m	Capacity	-6.33 Kn-m	Passing Percentage	**243.46 %**
$V_{1.35D}$	1.08 Kn	Capacity	12.59 Kn	Passing Percentage	**1165.74 %**
$V_{1.2D+1.5L\ 1.2D+Sn\ 1.2D+WnDn}$	2.43 Kn	Capacity	16.79 Kn	Passing Percentage	**690.95 %**
$V_{0.9D-WnUp}$	-3.66 Kn	Capacity	-20.98 Kn	Passing Percentage	**573.22 %**

Deflections

Modulus of Elasticity = 11000 MPa NZS3603 Amt 4, Table 2.3

k2 for Long Term Loads = 2

Deflection under Dead and Live Load = 1.44 mm	Limit by AS1170.0 Table C1 Span/250 = 12.00 mm
Deflection under Dead and Service Wind = 1.75 mm	Limit by AS1170.0 Table C1 Span/120 = 25.00 mm

Reactions

Maximum downward =2.43 kn Maximum upward = -3.66 kn

Rafter to Pole Connection check

Bolt Size = M12 Number of Bolts = 2

Calculations as per NZS 3603:1993 Amend 2005 clause 4.4

Joint Group for Rafters =J5 Joint Group for Pole = J5

Factor of Safety = 0.7

For Perpendicular to grain loading

K11 = 14.9 fpj = 12.9 Mpa for Rafter with effective thickness = 45 mm

For Parallel to grain loading

K11 = 2.0 fcj = 36.1 Mpa for Pole with effective thickness = 100 mm

Eccentric Load check

V = phi x k1 x k4 x k5 x fs x b x ds ..... (Eq 4.12) = -21.73 kn > -3.66 Kn

Single Shear Capacity under short term loads = -9.75 Kn > -3.66 Kn

Girt Design Front and Back

Girt's Spacing = 850 mm Girt's Span = 4500 mm Try Intermediate 190x45 SG8

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1 K4 =1 K5 =1 K8 Downward =0.98

K8 Upward =0.39 S1 Downward =12.23 S1 Upward =27.34

Shear Capacity of timber =3 MPa Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{Wind+Snow}$	1.20 Kn-m	Capacity	1.27 Kn-m	Passing Percentage	**105.83 %**
$V_{0.9D-WnUp}$	1.07 Kn-m	Capacity	13.75 Kn-m	Passing Percentage	**1285.05 %**

Deflections

Modulus of Elasticity = 8000 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 12.35 mm Limit by AS1170.0 Table C1 Span/120 = 37.50 mm

Sag during installation = 25.71 mm

Reactions

Maximum = 1.07 kn

Girt Design Sides

Girt's Spacing = 1300 mm Girt's Span = 3000 mm Try Intermediate 140x45 SG6

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1 K4 =1 K5 =1 K8 Downward =1.00

K8 Upward =0.72 S1 Downward =10.36 S1 Upward =18.92

Shear Capacity of timber =3 MPa Bending Capacity of timber =10 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{Wind+Snow}$	0.82 Kn-m	Capacity	0.97 Kn-m	Passing Percentage	**118.29 %**
$V_{0.9D-WnUp}$	1.09 Kn-m	Capacity	10.13 Kn-m	Passing Percentage	**929.36 %**

Deflections

Modulus of Elasticity = 6000 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 12.44 mm	Limit by AS1170.0 Table C1 Span/120 = 25.00 mm
Sag during installation =6.77 mm	

Reactions

Maximum = 1.09 kn

Middle Pole Design

Geometry

225 SED H5 (Minimum 275 dia. at Floor Level)	Dry Use	Height	5700 mm
Area	59366 mm2	As	44524.21875 mm2
Ix	280595337 mm4	Zx	2040693 mm3
Iy	280595337 mm4	Zx	2040693 mm3
Lateral Restraint	5700 mm c/c		

Loads

Total Area over Pole = 13.5 m2

Dead	3.38 Kn	Live	3.38 Kn
Wind	6.21 Kn	Snow	0.00 Kn
Moment wind	Kn-m		
Phi	0.8	K8	0.63
K1 snow	0.8	K1 Dead	0.6
K1wind	1		

Material

Peeling	Steaming	Normal	Dry Use
fb =	36.3 MPa	fs =	2.96 MPa
fc =	18 MPa	fp =	7.2 MPa
ft =	22 MPa	E =	9257 MPa

Capacities

PhiNcx Wind	542.54 Kn	PhiMnx Wind	37.61 Kn-m	PhiVnx Wind	105.43 Kn
PhiNcx Dead	325.53 Kn	PhiMnx Dead	22.57 Kn-m	PhiVnx Dead	63.26 Kn

Checks

(Mx/PhiMnx)+(N/phiNcx) = 0.81 < 1 OK

(Mx/PhiMnx)^2+(N/phiNcx) = 0.64 < 1 OK

Deflection at top under service lateral loads = 57.02 mm < 76.00 mm

Drained Lateral Strength of Middle pile in cohesionless soils Free Head short pile

Soil Properties

Gamma	18 Kn/m3	Friction angle	30 deg	Cohesion	0 Kn/m3
K0 =	(1-sin(30)) / (1+sin(30))				
Kp =	(1+sin(30)) / (1-sin(30))				

Geometry For Middle Bay Pole

Ds =	600 mm	Pile Diameter
L =	2100 mm	Pile embedment length
f1 =	4688 mm	Distance at which the shear force is applied
f2 =	0 mm	Distance of top soil at rest pressure

Loads

Moment Wind =	29.59 Kn-m
Shear Wind =	6.31 Kn

Pile Properties

Safety Factory	0.55	
Hu =	12.16 Kn	Ultimate Lateral Strength of the Pile, Short pile
Mu =	33.58 Kn-m	Ultimate Moment Capacity of Pile

Checks

Applied Forces/Capacities = 0.88 < 1 OK

End Pole Design

Geometry For End Bay Pole

Ds =	600 mm	Pile Diameter
L =	1400 mm	Pile embedment length
f1 =	4688 mm	Distance at which the shear force is applied

f2 =	0 mm	Distance of top soil at rest pressure

Loads

Total Area over Pole = 3.375 m2

Moment Wind =	9.86 Kn-m
Shear Wind =	2.10 Kn

Pile Properties

Safety Factory	0.55	
Hu =	4.02 Kn	Ultimate Lateral Strength of the Pile, Short pile
Mu =	10.78 Kn-m	Ultimate Moment Capacity of Pile

Checks

Applied Forces/Capacities = 0.91 < 1 OK

Drained Lateral Strength of End pile in cohesionless soils Free Head short pile

Soil Properties

Gamma	18 Kn/m3	Friction angle	30 deg	Cohesion	0 Kn/m3
K0 =	(1-sin(30)) / (1+sin(30))				
Kp =	(1+sin(30)) / (1-sin(30))				

Geometry For End Bay Pole

Ds =	600 mm	Pile Diameter
L =	1400 mm	Pile embedment length
f1 =	4688 mm	Distance at which the shear force is applied
f2 =	0 mm	Distance of top soil at rest pressure

Loads

Moment Wind =	9.86 Kn-m
Shear Wind =	2.10 Kn

Pile Properties

Safety Factory	0.55	
Hu =	4.02 Kn	Ultimate Lateral Strength of the Pile, Short pile
Mu =	10.78 Kn-m	Ultimate Moment Capacity of Pile

Checks

Applied Forces/Capacities = 0.91 < 1 OK

Uplift Check

Density of Concrete = 24 Kn/m3

Density of Timber Pole = 5 Kn/m3

Due to cast in place pile, the surface interaction between soil and pile will be rough thus angle of friction between both is taken equal to soil angle of internal friction

Ks (Lateral Earth Pressure Coefficient)for cast into place concrete piles = 1.5

Formula to calculate Skin Friction = Safecty factor (0.55) x Density of Soil(18) x Height of Pile(2100) x Ks(1.5) x tan(30) x Pi x Dia of Pile(0.6) x Height of Pile(2100)

Skin Friction = 35.62 Kn

Weight of Pile + Pile Skin Friction = 39.56 Kn

Uplift on one Pile = 15.46 Kn

Uplift is ok