

Job No.: Richard Hudson

Address: 20 Tieke Place, Horahora, New Zealand

Date: 8/18/2022

Latitude: -35.732017

Longitude: 174.288268

Elevation: 84 m

General Input

Roof Live Load	0.25 KPa	Roof Dead Load	0.25 KPa	Roof Live Point Load	1.1 Kn
Snow Zone	N0	Ground Snow Load	0 KPa	Roof Snow Load	0 KPa
Earthquake Zone	1	Subsoil Category	D	Exposure Zone	B
Importance Level	1	Ultimate wind & Earthquake ARI	100 Years	Max Height	2.71 m
Wind Region	NZ1	Terrain Category	2.89	Design Wind Speed	42.83 m/s
Wind Pressure	1.1 KPa	Lee Zone	NO	Ultimate Snow ARI	50 Years
Wind Category	High				

Note: Wind lateral loads are governing over Earthquake loads, So only wind loads are considered in calculations

Pressure Coefficients and Pressures

Shed Type = Mono Free

For roof $C_{p,i} = -0.3$

For roof $C_{p,e}$ from 0 m To 2.61 m $C_{p,e} = -0.9$ $p_e = -0.89$ KPa $p_{net} = -0.89$ KPa

For roof $C_{p,e}$ from 2.61 m To 5.21 m $C_{p,e} = -0.5$ $p_e = -0.50$ KPa $p_{net} = -0.50$ KPa

For wall Windward $C_{p,i} = 0$ side Wall $C_{p,i} = 0$

For wall Windward and Leeward $C_{p,e}$ from 0 m To 0 m $C_{p,e} = 0$ $p_e = 0$ KPa $p_{net} = 0$ KPa

For side wall $C_{p,e}$ from 0 m To 0 m $C_{p,e} =$ $p_e = 0$ KPa $p_{net} = 0$ KPa

Maximum Upward pressure used in roof member Design = 0.89 KPa

Maximum Downward pressure used in roof member Design = 0.43 KPa

Maximum Wall pressure used in Design = 0 KPa

Maximum Racking pressure used in Design = 0.6 KPa

Design Summary

Purlin Design

Purlin Spacing = 900 mm

Purlin Span = 3800 mm

Try Purlin 200x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet

condition after installation)

K1 Short term = 1 K1 Medium term = 0.8 K1 Long term = 0.6 K4 = 1 K5 = 1 K8 Downward = 1.00

K8 Upward = 0.53 S1 Downward = 11.27 S1 Upward = 23.16

Shear Capacity of timber = 3 MPa Bending Capacity of timber = 14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

M _{1.35D}	0.55 Kn-m	Capacity	2.39 Kn-m	Passing Percentage	434.55 %
M _{1.2D+1.5L 1.2D+S_n 1.2D+W_nD_n}	1.53 Kn-m	Capacity	3.18 Kn-m	Passing Percentage	207.84 %
M _{0.9D-W_nUp}	-1.08 Kn-m	Capacity	-2.10 Kn-m	Passing Percentage	194.44 %
V _{1.35D}	0.58 Kn	Capacity	9.65 Kn	Passing Percentage	1663.79 %
V _{1.2D+1.5L 1.2D+S_n 1.2D+W_nD_n}	1.25 Kn	Capacity	12.86 Kn	Passing Percentage	1028.80 %
V _{0.9D-W_nUp}	-1.14 Kn	Capacity	-16.08 Kn	Passing Percentage	1410.53 %

Deflections

Modulus of Elasticity = 8000 MPa NZS3603 Amt 4, Table 2.3 considering at least 4 members acting together

k₂ for Long Term Loads = 2

Deflection under Dead and Live Load = 5.50 mm Limit by AS1170.0 Table C1 Span/250 = 15.20 mm

Deflection under Dead and Service Wind = 6.55 mm Limit by AS1170.0 Table C1 Span/120 = 31.67 mm

Reactions

Maximum downward = 1.25 kn Maximum upward = -1.14 kn

Number of Blocking = 0 if 0 then no blocking required, if 1 then one midspan blocking required

Rafter Design Internal

Internal Rafter Load Width = 4000 mm Internal Rafter Span = 5850 mm Try Rafter 2x300x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1 K1 Medium term = 0.8 K1 Long term = 0.6 K4 = 1 K5 = 1 K8 Downward = 1.00

K8 Upward = 1.00 S1 Downward = 6.81 S1 Upward = 6.81

Shear Capacity of timber = 3 MPa Bending Capacity of timber = 14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

Pole Shed App Ver 01 2022 by RnH Consulting Engineers

M _{1.35D}	5.78 Kn-m	Capacity	11.32 Kn-m	Passing Percentage	195.85 %
M _{1.2D+1.5L 1.2D+Sn 1.2D+WnDn}	12.49 Kn-m	Capacity	15.08 Kn-m	Passing Percentage	120.74 %
M _{0.9D-WnUp}	-11.38 Kn-m	Capacity	-18.86 Kn-m	Passing Percentage	165.73 %
V _{1.35D}	3.95 Kn	Capacity	28.94 Kn	Passing Percentage	732.66 %
V _{1.2D+1.5L 1.2D+Sn 1.2D+WnDn}	8.54 Kn	Capacity	38.6 Kn	Passing Percentage	451.99 %
V _{0.9D-WnUp}	-7.78 Kn	Capacity	-48.24 Kn	Passing Percentage	620.05 %

Deflections

Modulus of Elasticity = 5400 MPa NZS3603 Amt 4, Table 2.3

k₂ for Long Term Loads = 2

Deflection under Dead and Live Load = 15 mm Limit by AS1170.0 Table C1 Span/250 = 24.00 mm

Deflection under Dead and Service Wind = 19.86 mm Limit by AS1170.0 Table C1 Span/120 = 50.00 mm

Reactions

Maximum downward = 8.54 kn Maximum upward = -7.78 kn

Rafter to Pole Connection check

Bolt Size = M12 Number of Bolts = 2

Calculations as per NZS 3603:1993 Amend 2005 clause 4.4

Joint Group for Rafters = J5 Joint Group for Pole = J5

Minimum Bolt edge, end and spacing for Load perpendicular to grains = 60 mm

Factor of Safety = 0.7

For Perpendicular to grain loading

K₁₁ = 14.9 f_{pj} = 12.9 Mpa for Rafter with effective thickness = 100 mm

For Parallel to grain loading

K₁₁ = 2.0 f_{cj} = 36.1 Mpa for Pole with effective thickness = 100 mm

Capacity under short term loads = 21.67 Kn > -7.78 Kn

Rafter Design External

External Rafter Load Width = 2000 mm External Rafter Span = 5808 mm Try Rafter 300x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

Pole Shed App Ver 01 2022 by RnH Consulting Engineers

K1 Short term = 1 K1 Medium term = 0.8 K1 Long term = 0.6 K4 = 1 K5 = 1 K8 Downward = 0.94

K8 Upward = 0.94 S1 Downward = 13.93 S1 Upward = 13.93

Shear Capacity of timber = 3 MPa Bending Capacity of timber = 14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

M _{1.35D}	2.85 Kn-m	Capacity	4.72 Kn-m	Passing Percentage	165.61 %
M _{1.2D+1.5L 1.2D+S_n 1.2D+W_nD_n}	6.16 Kn-m	Capacity	6.30 Kn-m	Passing Percentage	102.27 %
M _{0.9D-W_nUp}	-5.61 Kn-m	Capacity	-7.87 Kn-m	Passing Percentage	140.29 %
V _{1.35D}	1.96 Kn	Capacity	14.47 Kn	Passing Percentage	738.27 %
V _{1.2D+1.5L 1.2D+S_n 1.2D+W_nD_n}	4.24 Kn	Capacity	19.30 Kn	Passing Percentage	455.19 %
V _{0.9D-W_nUp}	-3.86 Kn	Capacity	-24.12 Kn	Passing Percentage	624.87 %

Deflections

Modulus of Elasticity = 5400 MPa NZS3603 Amt 4, Table 2.3

k₂ for Long Term Loads = 2

Deflection under Dead and Live Load = 16.67 mm Limit by AS1170.0 Table C1 Span/250 = 24.00 mm

Deflection under Dead and Service Wind = 19.86 mm Limit by AS1170.0 Table C1 Span/120 = 50.00 mm

Reactions

Maximum downward = 4.24 kn Maximum upward = -3.86 kn

Rafter to Pole Connection check

Bolt Size = M12 Number of Bolts = 2

Calculations as per NZS 3603:1993 Amend 2005 clause 4.4

Joint Group for Rafters = J5 Joint Group for Pole = J5

Factor of Safety = 0.7

For Perpendicular to grain loading

K₁₁ = 14.9 f_{pj} = 12.9 Mpa for Rafter with effective thickness = 50 mm

For Parallel to grain loading

K₁₁ = 2.0 f_{cj} = 36.1 Mpa for Pole with effective thickness = 100 mm

Eccentric Load check

V = $\phi \times k_1 \times k_4 \times k_5 \times f_s \times b \times d_s$ (Eq 4.12) = -25.20 kn > -3.86 Kn

Single Shear Capacity under short term loads = $-10.84 \text{ Kn} > -3.86 \text{ Kn}$

End Pole Design

Geometry For End Bay Pole

Ds =	600 mm	Pile Diameter
L =	1300 mm	Pile embedment length
f1 =	2032 mm	Distance at which the shear force is applied
f2 =	0 mm	Distance of top soil at rest pressure

Loads

Total Area over Pole = 6 m^2

Moment Wind =	1.65 Kn-m
Shear Wind =	0.81 Kn

Pile Properties

Safety Factory	0.55	
Hu =	5.87 Kn	Ultimate Lateral Strength of the Pile, Short pile
Mu =	7.32 Kn-m	Ultimate Moment Capacity of Pile

Checks

Applied Forces/Capacities = $0.23 < 1$ OK

Drained Lateral Strength of End pile in cohesionless soils Free Head short pile

Soil Properties

Gamma	18 Kn/m ³	Friction angle	30 deg	Cohesion	0 Kn/m ³
K0 =	$(1 - \sin(30)) / (1 + \sin(30))$				
Kp =	$(1 + \sin(30)) / (1 - \sin(30))$				

Geometry For End Bay Pole

Ds =	600 mm	Pile Diameter
L =	1300 mm	Pile embedment length
f1 =	2032 mm	Distance at which the shear force is applied
f2 =	0 mm	Distance of top soil at rest pressure

Loads

Moment Wind = 1.65 Kn-m
Shear Wind = 0.81 Kn

Pile Properties

Safety Factory 0.55
Hu = 5.87 Kn Ultimate Lateral Strength of the Pile, Short pile
Mu = 7.32 Kn-m Ultimate Moment Capacity of Pile

Checks

Applied Forces/Capacities = 0.23 < 1 OK

Uplift Check

Density of Concrete = 24 Kn/m³

Density of Timber Pole = 5 Kn/m³

Due to cast in place pile, the surface interaction between soil and pile will be rough thus angle of friction between both is taken equal to soil angle of internal friction

Ks (Lateral Earth Pressure Coefficient) for cast into place concrete piles = 1.5

Formula to calculate Skin Friction = Safety factor (0.55) x Density of Soil(18) x Height of Pile(1300) x Ks(1.5) x tan(30) x Pi x Dia of Pile(0.6) x Height of Pile(1300)

Skin Friction = 13.65 Kn

Weight of Pile + Pile Skin Friction = 17.68 Kn

Uplift on one Pile = 7.98 Kn

Uplift is ok