


Power Grid Analysis with Applications to Power grid Security

Why Do we care?

A failure in a line causes stress on the power grid.

When looking at the transient after failing a line, we can see other power line reach a flow higher than the lines capacity.

These additional failure can lead to cascading failure.



One way to analyze these


Swing Equation:

$$\ddot{\theta}_i = P_i - \gamma_i \dot{\theta}_i + \sum_j K_{ij} \sin(\theta_j - \theta_i)$$

$$power = K_{ij} \sin(\theta_j - \theta_i)$$

A line will fail if the power reach the threshold flow.


$$\alpha \in [0, 1]$$
$$\alpha K_{ij} < K_{ij} \sin(\theta_j - \theta_i)$$



Example of Line Failure

An example showing the transient after a line failure.

We can see how power flow jump much larger than the steady state.




Linear Swing equation

Now we look at a linear swing equation:

$$\ddot{\theta}_i = P_i - \gamma_i \dot{\theta}_i + \sum_j K_{ij} (\theta_j - \theta_i)$$

The results of the transient is similar to the nonlinear swing equation in the networks we are viewing.



Linearizing The Swing Equation

We now look at the linear swing equation.

$$\ddot{\theta}(t) = P - \gamma \dot{\theta}(t) + L \theta(t)$$

Where L is the Laplacian matrix

We now diagonalize L . Where V is the eigenvector and λ are the eigenvalues .

$$L = V \Lambda V^{-1}$$

we multiply the left side by V^{-1}

We now set

$$\begin{aligned}\eta(t) &= V^{-1} \theta(t) \\ Q &= V^{-1} P\end{aligned}$$

And get

$$\ddot{\eta}(t) = Q - \gamma \dot{\eta}(t) - \Lambda \eta(t)$$

We can break up this equation

$$\ddot{\eta}_i(t) = Q_i - \gamma \dot{\eta}_i(t) - \lambda_i \eta_i(t)$$

Linearize Swing Equation

We now have decoupled the systems. We can now analyze eta independently of other etas

To get back theta we use:

$$\theta_i(t) = \sum_j V_{ij} \eta_j(t)$$

