

MEMORY MAP TABLE

Model: LGC-X30														
Communications Type : Modbus RTU, RS232 Full Duplex / RS485 Half Duplex														
Baud_Rate : 4800 - 57600 Baud (Default : 19200) / Data Bit 8, Stop Bit 1, Parity None														
MACHINE TYPE : ABS														
DATA TYPE : Read Coil Status(0x01) / Forces Single Coil(0x05)														
No.	Modbus Address Reg. No.	Modbus Address Bit No.	Tag Name	Description (24 Char. Max.)	Device Bit Status=0	Device Bit Status=1	Range (Min)	Range (Max)	Default	EEPROM Write	Unit	DCS Scale	Signal Type	Remarks
1	00001	1	0	운전	동작없음	운전	0	1	0	0			Key Input	
2	00002	1	1	정지	동작없음	정지	0	1	0	0			Key Input	
DATA TYPE : Read Input Status(0x02)														
No.	Modbus Address Reg. No.	Modbus Address Bit No.	Tag Name	Description (24 Char. Max.)	Device Bit Status=0	Device Bit Status=1	Range (Min)	Range (Max)	Default	EEPROM Write	Unit	DCS Scale	Signal Type	Remarks
1	10001	1	0	운전 상태	정지	운전							Status Flag	
2	10006	1	5	추기 펌프 운전 상태	정지	운전							Status Flag	
3	10011	2	2	연소 운전 상태	정지	운전	D0(comp)+D1(interlock)						Status Flag	
4	10012	2	3	냉매 펌프 운전 상태	정지	운전	D0						Status Flag	
5	10013	2	4	냉수 유량 정상 상태	유량없음	유량정상	D0(pump)+D1(flow sw)						Status Flag	
6	10014	2	5	냉각수 유량 정상 상태	유량없음	유량정상	D0(pump)+D1(flow sw)						Status Flag	
7	10016	2	7	부전 상태	OFF	ON	D0						Status Flag	
8	10018	3	1	이상 상태	OFF	ON	message						Status Flag	
DATA TYPE : Read Holding Register(0x03) / Preset Single Register(0x06)														
No.	Modbus Address Reg. No.	Modbus Address Bit No.	Tag Name	Description (24 Char. Max.)	Device Bit Status=0	Device Bit Status=1	Range (Min)	Range (Max)	Default	EEPROM Write	Unit	DCS Scale	Signal Type	Remarks
1	40003			냉수 출구 온도			3	20	7	1	℃	10		
2	40004			온수 출구 온도			40	80	60	1	℃	10		난방시사용
DATA TYPE : Read Input Register(0x04)														
No.	Modbus Address Reg. No.	Modbus Address Bit No.	Tag Name	Description (24 Char. Max.)	Device Bit Status=0	Device Bit Status=1	Range (Min)	Range (Max)	Default	EEPROM Write	Unit	DCS Scale	Signal Type	Remarks
1	30001			운전 메시지			0	300			-	1		
2	30002			경보 메시지			0	300			-	1		
3	30003			이상 메시지			0	300			-	1		
4	30010			제어밸브 개도			0	100			%	1		
5	30021		TE1	냉온수 입구 온도 센서			-40	400			℃	10	Analog Input	Master
6	30022		TE2	냉온수 출구 온도 센서			-40	400			℃	10	Analog Input	
7	30023		TE3	냉각수 입구 온도 센서			-40	400			℃	10	Analog Input	
8	30024		TE4	냉각수 출구 온도 센서			-40	400			℃	10	Analog Input	
9	30025		TE5	응축기 냉매 온도 센서			-40	400			℃	10	Analog Input	
10	30026		TE6	고온 재생기 온도 센서			-40	400			℃	10	Analog Input	
11	30027		A11	저실 압력 센서			0	Set			mmHg	1	Analog Input	
12	30028		A12	추기 장치 압력			0	Set			mmHg	1	Analog Input	
13	30029		A13	냉수 유량 센서			0	Set			mAg	100	Analog Input	
14	30030		A14	냉각수 유량 센서			0	Set			m³/h	1	Analog Input	
15	30041		TE1	온수 출구 온도 센서(80℃)			-40	400			℃	10	Analog Input	Slave
16	30042		TE2	온수 입구 온도 센서(80℃)			-40	400			℃	10	Analog Input	
17	30043		TE3	저온 재생기 온도 센서			-40	400			℃	10	Analog Input	
18	30044		TE4	증발기 냉매 온도 센서			-40	400			℃	10	Analog Input	
19	30045		TE5	흡수기 회액 온도 센서			-40	400			℃	10	Analog Input	
20	30046		TE6	배기가스 출구 온도 센서			-40	400			℃	10	Analog Input	