



Alarms =Alarms_BatDischarged, Alarms_RedundancyLost, Alarms_InverterCritical, Alarms_OnBattery, Alarms_BypassInputNok, Alarms_RectifierInputNok, Alarms_ChargerPreventive, Alarms_RemoteService, Alarms_ChargerCritical

Anomalies = Battery_p, Bypass_V3, Bypass_V2, Bypass_V1, Output_V3, Output_V1, Rectifier_V3, Output_fr, Rectifier_V2, Battery_Vp, Rectifier_V1, Output_V2, Bypass_Fr



