

ALLEN FACE KOREA LTD

TR34 (3rd EDITION) ANALYSIS INTRUCTIONS

Support by	Allenface
	Allenface Europe
	e-mail: af@allenface.com / allenfacekorea@naver.com
Further information:	www.allenface.com & www.allenface-europe.com
	https://blog.naver.com/allenfacekorea
Project Name:	방초리
Project Address:	안성시 일죽 방초리 221
Concrete Floor Installer:	일도티씨에스㈜
Testing Organization:	ALLEN FACE KOREA
Slab ID:	지상1층 #1
Date of Testing:	2024-03-06
Test Apparatus:	D-Meter® Manufactured by Allen Face&Company, Serial Number: 098
Testing Technician:	TAEHYUN LEE (ALLEN FACE KOREA)
Total Test Area(m2)	89
Comments:	Slab on Grade
City:	인천광역시
Signee:	TAEHYUN LEE (ALLEN FACE KOREA)
Specified floor class	TR34 3rd Version FM3

Combined & Individual Session Totals																
Session Number:	All	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15
Total Run Length (m):	1027.8	41.4	108	34.2	178.5	39.6	45.9	124.2	41.4	124.5	41.7	31.2	113.4	41.4	31.2	31.2
# of Runs in Session:	96	6	6	6	18	4	8	6	6	6	6	4	6	6	4	4
Session Date:	03/06/24	03/05/24	03/06/24	03/06/24	03/06/24	03/06/24	03/06/24	03/06/24	03/06/24	03/06/24	03/06/24	03/06/24	03/06/24	03/06/24	03/06/24	03/06/24
Session Time:	04:54 UTC	23:34 UTC	00:20 UTC	00:31 UTC	01:29 UTC	01:41 UTC	01:55 UTC	02:32 UTC	02:45 UTC	03:21 UTC	03:35 UTC	03:45 UTC	04:21 UTC	04:34 UTC	04:43 UTC	04:54 UTC
OAFF	32.7	35.5	29.7	44.9	30.0	41.3	30.3	32.3	34.8	31.1	35.2	46.7	34.5	28.8	30.9	52.0
<90% CI>	<32.3-33.1>	<31.7-39.2>	<28.0-31.4>	<39.7-50.2>	<28.8-31.3>	<36.9-45.7>	<27.3-33.4>	<30.6-34.1>	<31.2-38.5>	<29.4-32.7>	<31.5-38.8>	<41.0-52.5>	<32.6-36.5>	<25.8-31.8>	<27.1-34.7>	<45.6-58.3>
O AFL	27.2	38.5	23.3	38.9	30.2	30.7	29.0	25.5	42.0	28.9	29.2	33.1	21.2	27.9	35.6	39.3
<90% CI>	<26.8-27.7>	<33.3-43.7>	<21.8-24.8>	<32.6-45.2>	<28.6-31.7>	<26.9-34.6>	<25.0-33.0>	<24.0-27.0>	<36.3-47.7>	<27.3-30.6>	<25.3-33.1>	<28.0-38.1>	<19.9-22.5>	<24.1-31.7>	<30.2-41.0>	<33.3-45.2>
Check Code:	43U3 RD6# %L&B X50%	#5T8 &OMP LS6E 435#	3%FD 6&#O %%A2 6K92	QN#& O#SM 3&7O P1B4	FK&# 1&C3 ISKH MAC1	O7T# 21&3 IQI3 FUC1	3SSH #T#C 3&6N 1#K2	O&7N 36FI 6VQ4 #143	XV#5 OL7P 3&LF NCG4	6P2# 6#73 COUX W301	&U&S 3DP2 OM#7 #IE3	#8Y# %O8L P1#6 \$37#	#93V 6OE3 XVOB N3##	AOT& CDLO XW9# Y43&	OK%C 32VE #PEB #5V3	3F8J #JOI %N3P OOC3