

ALLEN FACE KOREA LTD

TR34 (4th EDITION) ANALYSIS INTRUCTIONS

Support by	Allenface
	Allenface Europe
	e-mail: af@allenface.com / allenfacekorea@naver.com
Further information:	www.allenface.com & www.allenface-europe.com
	https://blog.naver.com/allenfacekorea
Project Name:	인천 도화 물류센터
Project Address:	-
Concrete Floor Installer:	HEB
Testing Organization:	ALLEN FACE KOREA
Slab ID:	지상5층 #1
Date of Testing:	2024-03-12
Test Apparatus:	D-Meter® Manufactured by Allen Face&Company, Serial Number: 448
Testing Technician:	최동현 (ALLEN FACE KOREA)
Total Test Area(m2)	1,089
Comments:	
City:	인천시
Signee:	최동현 (ALLEN FACE KOREA)
Specified floor class	TR34 4th Version FM3

Combined & Individual Session Totals

Session Number:	All	1	2	3	4
Total Run Length (m):	520.2	185.4	59.4	223.2	52.2
# of Runs in Session:	26	6	6	8	6
Session Date:	03/12/24	03/12/24	03/12/24	03/12/24	03/12/24
Session Time:	02:11 UTC	00:38 UTC	00:57 UTC	01:50 UTC	02:11 UTC
OAFF	44.8	44.5	40.6	45.5	50.0
<90% CI>	<43.9-45.8>	<42.6-46.3>	<37.2-44.0>	<43.8-47.1>	<45.4-54.5>
O AFL	23.7	26.5	18.8	22.8	27.9
<90% CI>	<23.2-24.3>	<25.4-27.7>	<16.9-20.7>	<21.9-23.6>	<24.8-30.9>
Check Code:	9TLF 6Y\$& #&FD 4L62	&RDN 9%FY O7S\$ #YT3	FFR# %829 CSHX 5GC1	CVGD 92#E #JI& #LR3	1FF# S118 &#E9 NJW5