TR34 (4th edition) Free Movement Floor Tolerance Report

Allen Face Europe TR34 Analysis, ©Allen Face Europe, www.allenface-europe.com

1. Project Name:	인천 화도 물류센터	4.	Slab ID:	지상4층 2공구 #14
Project Location:	-		Date of Pouring:	#REF!
•	이처시		Date of Testing:	2024-03-12

2. Concrete Floor Installer: HEB Test Apparatus: D-Meter® Manufactured by Allen Face&Company, Serial Number: 448
Testing Technician: 최동현 (ALLEN FACE KOREA)

Testing Technician: 최동현 (ALLEN FACE KOREA)

3. Testing Organization: ALLEN FACE KOREA

Test Area: 61 m² (for test area organization see attached drawing)

TR34 FREE MOVEMENT FLOOR TOLERANCES											
Floor Classification	Property F (mm)	Property E (mm)									
Floor Classification	95% limit	95% limit									
FM1	1.8	4.5									
FM2	2.0	6.5									
FM3	2.2	8.0									
FM4	2.4	10.0									

The analysed D-Meter® Runs satisfy the

5. Floor Tolerance Requirements:

7. Summary:

TR34 4th Edition Convert into FF/FL number 값												
4th Edition	95% F number											
등급	Property F mm(±)	Property E mm(±)	FF	FL								
FM1	1.8	4.5	42.9	46.6								
FM2	2.0	6.5	38.6	32.3								
FM3	2.2	8.0	35.1	26.2								
FM4 2.4 10.0 32.2 21.0												
				C 1 .								

최동현 (ALLEN FACE KOREA)

Analysis:							Any point on the Property E survey grid is outside the ± 15 mm of datum											
	TR34 FREE MOVEMENT RESULTS																	
Run #:		1	2	3	4	5	6											All Runs:
Run Length (m):		5.40	5.40	5.40	5.40	5.40	5.40											32.40
	Property F (95%)	NO	YES	YES	NO	NO	YES											YES
FM1	% Defective	12.50%	0.00%	0.00%	6.25%	6.25%	0.00%											4.17%
FIVII	Property E (95%)	YES	YES	YES	NO	NO	YES											NO
	% Defective	0.00%	0.00%	0.00%	12.50%	37.50%	0.00%											8.33%
	Property F (95%)	NO	YES	YES	YES	NO	YES											YES
FM2	% Defective	12.50%	0.00%	0.00%	0.00%	6.25%	0.00%											3.13%
FIVIZ	Property E (95%)	YES	YES	YES	YES	YES	YES											YES
	% Defective	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%											0.00%
	Property F (95%)	YES	YES	YES	YES	NO	YES											YES
FM3	% Defective	0.00%	0.00%	0.00%	0.00%	6.25%	0.00%											1.04%
FIVIS	Property E (95%)	YES	YES	YES	YES	YES	YES											YES
	% Defective	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%											0.00%
	Property F (95%)	YES	YES	YES	YES	YES	YES											YES
FM4	% Defective	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%											0.00%
FIVI	Property E (95%)	YES	YES	YES	YES	YES	YES											YES
	% Defective	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%											0.00%

floor tolerance requirements.

FM2

TR34 (4th edition) Free Movement Floor Tolerance Report

Allen Face Europe TR34 Analysis, ©Allen Face Europe, www.allenface-europe.com

1.	Project Name:	인천 화도 물류센터	4.	Slab ID:	지상4층 2공구 #14
	Project Location:	-		Date of Pouring:	#REF!

인천시 HEB 2. Concrete Floor Installer:

Testing Organization: ALLEN FACE KOREA

5.	Floor Tolerance Requirements:	TR34 FREE MOVEMENT FLO

The analysed D-Meter® Runs satisfy the

TR34 FREE MOVEMENT FLOOR TOLERANCES											
Floor Classification	Property F (mm)	Property E (mm)									
rioui Ciassilication	100% limit	100% limit									
FM1	4.0	15.0									
FM2	4.5	15.0									
FM3	5.5	15.0									
FM4	7.5	15.0									

2024-03-12 Date of Testing:

Test Apparatus: D-Meter® Manufactured by Allen Face&Company, Serial Number: 448

Testing Technician:

최동현 (ALLEN FACE KOREA) 61 m² (for test area organization see attached drawing) Test Area:

Any point on the Property E survey grid is outside the ±15mm of datum

6.	Anaiysis

7. Summary:

	TR34 FREE MOVEMENT RESULTS																		
Run #:		1	2	3	4	5	6												All Runs:
Run Length (m):		5.40	5.40	5.40	5.40	5.40	5.40												32.40
	Property F (100%)	YES	YES	YES	YES	YES	YES												YES
FM1	% Defective	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%												0.00%
FIVII	Property E (100%)	YES	YES	YES	YES	YES	YES					1		T					YES
	% Defective	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%											Ĭ	0.00%
	Property F (100%)	YES	YES	YES	YES	YES	YES												YES
EN 42	% Defective	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%											Ĭ	0.00%
FM2	Property E (100%)	YES	YES	YES	YES	YES	YES										Ī		YES
	% Defective	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%											ľ	0.00%
	Property F (100%)	YES	YES	YES	YES	YES	YES												YES
5042	% Defective	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%												0.00%
FM3	Property E (100%)	YES	YES	YES	YES	YES	YES												YES
	% Defective	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%												0.00%
	Property F (100%)	YES	YES	YES	YES	YES	YES												YES
F144	% Defective	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%											ĺ	0.00%
FM4	Property E (100%)	YES	YES	YES	YES	YES	YES	[<u> </u>			T	<u> </u>	1			YES
	% Defective	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%											İ	0.00%

floor tolerance requirements.

		최동현 (ALLEN FACE KOREA)

FM1

