

Summary of Survey Result

Testing Company			Survey Result Summary				안성시 일죽면 방초리 물류창고	
Allen Face Korea			2024-03-12				4F	
Survey result						Permitted Limit TR34 4rd Edition FM3		Remark (TR34 4rd FM3)
SLAB ID	SLAB AREA	Measured	Measured	TR34 3rd Edition	TR34 3rd Edition	Property II	Property IV	PASS / FAIL
	M2	OAFF	O AFL	Measure (95%)	Measure (100%)	FM2(FF 22.0)	FM2(FL 26.0)	
#1	123	36.9	16.9	FM3	FM3	FM2(FF 22.0)	FM2(FL 26.0)	PASS
#2	363	35	16.8	FM4	FM1	FM2(FF 22.0)	FM2(FL 26.0)	PASS
#3	427	44.6	26.9	FM3	FM4	FM2(FF 22.0)	FM2(FL 26.0)	PASS
#4	605	37.4	25.4	FM4	FM2	FM2(FF 22.0)	FM2(FL 26.0)	PASS
#5	398	38.4	20.1	FM4	FM1	FM2(FF 22.0)	FM2(FL 26.0)	PASS
Average	383.2	38.5	21.2			Permitted Limit TR34 3rd Edition FM2		PASS