

Summary of Survey Result

Testing Company			Survey Result Summary				안성시 일죽면 방초리 물류창고	
Allen Face Korea			2024-03-06				1F	
Survey result						Permitted Limit TR34 3rd Edition FM2		Remark (TR34 3rd FM2)
SLAB ID	SLAB AREA	Measured	Measured	TR34 3rd Edition	TR34 3rd Edition	Property II	Property IV	PASS / FAIL
	M2	OAFF	O AFL	Measure (95%)	Measure (100%)	FM2(FF 22.0)	FM2(FL 26.0)	
#1	NOP	32.7	38.5	FM2(Special)	FM2(Special)	FM2(FF 22.0)	FM2(FL 26.0)	PASS
#2	NOP	29.7	23.3	FM2	FM2	FM2(FF 22.0)	FM2(FL 26.0)	PASS
#3	NOP	44.9	38.9	FM2	FM2(Special)	FM2(FF 22.0)	FM2(FL 26.0)	PASS
#4	NOP	30.0	30.2	FM2	FM2	FM2(FF 22.0)	FM2(FL 26.0)	PASS
#5	NOP	41.3	30.7	FM2	FM2	FM2(FF 22.0)	FM2(FL 26.0)	PASS
#6	NOP	30.3	29.0	FM2	FM2	FM2(FF 22.0)	FM2(FL 26.0)	PASS
#7	NOP	32.3	25.5	FM2	FM2	FM2(FF 22.0)	FM2(FL 26.0)	PASS
#8	NOP	34.8	42.0	FM2	FM2	FM2(FF 22.1)	FM2(FL 26.1)	PASS
#9	NOP	31.1	28.9	FM2	FM2	FM2(FF 22.2)	FM2(FL 26.2)	PASS
#10	NOP	35.2	29.2	FM2	FM2	FM2(FF 22.3)	FM2(FL 26.3)	PASS
#11	NOP	46.7	33.1	FM2	FM2	FM2(FF 22.4)	FM2(FL 26.4)	PASS
#12	NOP	34.5	21.2	FM2	FM2	FM2(FF 22.5)	FM2(FL 26.5)	PASS
#13	NOP	28.8	27.9	FM2	FM2	FM2(FF 22.6)	FM2(FL 26.6)	PASS
#14	NOP	30.9	35.6	FM2	FM2	FM2(FF 22.7)	FM2(FL 26.7)	PASS
#15	NOP	52.0	39.3	FM2	FM2	FM2(FF 22.8)	FM2(FL 26.8)	PASS
Average		35.7	31.6			Permitted Limit TR34 3rd Edition FM2		PASS