

## Summary of Survey Result

Test Company	Survey Date	Name of Project
AllenFace Korea	2024-03-05	이천시 대월면 대대리 576물류센터

By done - BS 8204-2 : 2003 + A2 : 2011				
Survey result			Permitted Limit AR 1	Remark
SLAB AREA	SLAB ID	Measured	STANDARD	PASS / FAIL
		mm	mm	
B2F	#1	0.055	0.1	PASS
1F	#1	0.091	0.1	PASS
3F	#1	0.181	0.1	PASS
4F	#1	0.055	0.1	PASS
Pass Average		0.096		PASS