

ALLEN FACE KOREA LTD

**TR34 (4th EDITION) ANALYSIS INTRUCTIONS**

Support by	Allenface
	Allenface Europe
	e-mail: af@allenface.com / allenfacekorea@naver.com
Further information:	<a href="http://www.allenface.com">www.allenface.com</a> & <a href="http://www.allenface-europe.com">www.allenface-europe.com</a>
	<a href="https://blog.naver.com/allenfacekorea">https://blog.naver.com/allenfacekorea</a>
Project Name:	인천 도화 물류센터
Project Address:	-
Concrete Floor Installer:	HEB
Testing Organization:	ALLEN FACE KOREA
Slab ID:	지상4층 1공구 #11
Date of Testing:	2024-03-12
Test Apparatus:	D-Meter® Manufactured by Allen Face&Company, Serial Number: 448
Testing Technician:	최동현 (ALLEN FACE KOREA)
Total Test Area(m2)	123
Comments:	
City:	인천시
Signee:	최동현 (ALLEN FACE KOREA)
Specified floor class	TR34 4th Version FM3

**Combined & Individual Session Totals**

Session Number:	All	1	2	3	4	5
Total Run Length ( m ):	346.2	39	55.2	68.4	124.2	59.4
# of Runs in Session:	24	4	4	4	6	6
Session Date:	03/12/24	03/12/24	03/12/24	03/12/24	03/12/24	03/12/24
Session Time:	02:19 UTC	01:04 UTC	01:17 UTC	01:35 UTC	02:04 UTC	02:19 UTC
<b>OAFF</b>	<b>38.2</b>	<b>36.9</b>	<b>35.0</b>	<b>44.6</b>	<b>37.4</b>	<b>38.4</b>
<90% CI>	<37.2-39.3>	<32.9-40.9>	<32.0-38.1>	<41.2-48.0>	<35.4-39.4>	<35.2-41.7>
<b>O AFL</b>	<b>21.5</b>	<b>16.9</b>	<b>16.8</b>	<b>26.9</b>	<b>25.4</b>	<b>20.1</b>
<90% CI>	<20.8-22.1>	<14.7-19.0>	<15.2-18.5>	<24.6-29.1>	<23.9-26.9>	<18.1-22.1>
Check Code:	OGRN 9LXY 6BF# #I%3	N1V# 6&\$D O#19 CD35	63#% &TSK 9146 ND54	FT#& &#NP 93B# D&N4	#4J# 1P79 IBA5 VT&1	#MM# 2B29 #3&3 5TO1