

LAS NASAS 09

Climatización

09.12.2025

	espacio	capacidad estimada	toneladas	tipo
2do nivel	máster 1	36,000 btu	3	fan coil
	closet y baño master 1	18,000 btu	1.5	fan coil
	máster 2	36,000 btu	3	fan coil
	dormitorio 3	18,000 btu	1.5	fan coil
	dormitorio 4	24,000 btu	2	fan coil
1er nivel	sala	48,000 btu	4	fan coil
	estudio	30,000 btu	2.5	fan coil
	comedor	30,000 btu	2.5	fan coil
	cocina 1	30,000 btu	2.5	fan coil
	cocina 2	12,000 btu	1	fan coil
	lavandería	12,000 btu	1	split
	área de staff	12,000 btu	1	split
	dormitorio staff 1	12,000 btu	1	split
	dormitorio staff 2	12,000 btu	1	split
				27.5 toneladas