WORKSHEET 2 OF 7

# Deal Readiness Tracker

*One sheet for each building. Copy this page.*

> **When to use it.** Start this sheet after the walk, for a building that the ten-minute screen in chapter 3 sent you to see. It tracks what has been confirmed, in writing, on the way to a deal. It has no score. It does not approve a building, and it does not replace the utility's written answer or a licensed engineer's finding. The cut points are mine. Change them to fit your buyer.

**Building:** _____ **Parcel no.:** _____ **Date started:** _____

**Serving utility (and source):** _____ **Kept by:** _____

**Target size for this building (total site load):** _____ MW

## The four status words

Give each of the eleven lines one status. These are the same four words the screen in chapter 3 uses.

| Status | Meaning |
|---|---|
| **Good** | The evidence meets the "good" description, and you hold it in writing |
| **Maybe** | In between, or a clue without confirmation |
| **Stop** | The evidence meets the "stop" description |
| **Unknown** | You do not have the facts yet. Write U, and who can answer. |

Write the evidence, its source and its date beside every status. A status with no evidence is "unknown". Update the sheet each time a written answer arrives.

# Gate 1. Power

## 1. Utility capacity, in writing

| Good | Maybe | Stop |
|---|---|---|
| The utility confirms in writing 1 MW or more of total site load at this address, today or by a stated date. Write the amount and the date | A large service is installed and the utility has not yet answered. Or the utility's answer depends on a study | The utility states in writing that less than 1 MW is available, with no upgrade path or date |

**Status** ☐ Good ☐ Maybe ☐ Stop ☐ Unknown

Evidence, source and date _____

_____

## 2. Installed service

| Good | Maybe | Stop |
|---|---|---|
| 5,000 kVA or more on the nameplates, or a substation on site that serves this parcel | 1,500 to 5,000 kVA | Under 1,500 kVA, and line 1 is not "good" |

**Status** ☐ Good ☐ Maybe ☐ Stop ☐ Unknown

Evidence, source and date _____

_____

## 3. Distance to a substation of the serving utility

| Good | Maybe | Stop |
|---|---|---|
| On site or next door, about a quarter mile or less | Within about 2 miles | More than about 2 miles, and no large service installed |

**Status** ☐ Good ☐ Maybe ☐ Stop ☐ Unknown

Evidence, source and date _____

_____

Notes for this gate:

- Line 1 is total site load, not IT load. Compare the utility's figure with the target size at the top of the sheet. A confirmed 2 MW is "good" on this line and still too small for a buyer who needs 6.

- Line 2 measures equipment. Chapter 2 gives the nameplate arithmetic. A nameplate is not a promise from the utility. Do not add two services together.
- Line 3 is a clue about the work to connect. A nearby substation proves neither service nor spare capacity. Record which map you used and its date.
- A "stop" on line 2 or line 3 alone does not stop the building. The utility's written answer on line 1 controls.

## Gate 2. Permits

### 4. Zoning

| Good | Maybe | Stop |
|---|---|---|
| The code lists the use, or a use that plainly covers it, as allowed by right in this district | The use needs a special or conditional approval. Or the code does not name it and staff must interpret | The use is prohibited, or a recorded restriction blocks it |

**Status** ☐ Good ☐ Maybe ☐ Stop ☐ Unknown

Evidence, source and date _____

_____

### 5. Flood designation

| Good | Maybe | Stop |
|---|---|---|
| Building and yard outside the mapped Special Flood Hazard Area | Part of the yard is in a mapped flood hazard area, or the area is mapped as moderate risk | Not used. A flood designation is a flag for review, not a stop |

**Status** ☐ Good ☐ Maybe ☐ Stop ☐ Unknown

Evidence, source and date _____

_____

### 6. Neighbors and water

| Good | Maybe | Stop |
|---|---|---|
| Industrial or vacant neighbors, and a cooling design that uses little water | Homes in sight but buffered by distance or a road. Or water use not yet known | Not used. Homes at the property line or a large new water withdrawal are "maybe", with a note |

**Status** ☐ Good ☐ Maybe ☐ Stop ☐ Unknown

Evidence, source and date _____

_____

Notes for this gate:

- Line 4: copy the exact words of the listed use from the code.
- Line 5: if the building itself is in a mapped Special Flood Hazard Area, mark "maybe" and write the zone. The engineers and the insurer decide what it costs.
- Line 6: low water use is not an automatic exemption from any permit.

## Gate 3. Structure

### 7. Floor type and the engineer's finding

| Good | Maybe | Stop |
|---|---|---|
| A licensed structural engineer has reviewed the floor and the delivery path for the intended rack layout and found them suitable, in writing | Slab on grade, not yet reviewed. Or an elevated floor awaiting an engineer's review | A licensed structural engineer has found the floor unsuitable and strengthening not feasible |

**Status** ☐ Good ☐ Maybe ☐ Stop ☐ Unknown

Evidence, source and date _____

_____

### 8. Clear height

| Good | Maybe | Stop |
|---|---|---|
| 16 feet or more | 12 to 16 feet | Under 12 feet, and the buyer has confirmed that is too low |

**Status** ☐ Good ☐ Maybe ☐ Stop ☐ Unknown

Evidence, source and date _____

_____

Notes for this gate:

- Line 7 asks two things: what kind of floor is it, and what has an engineer found? Write the floor type and the source. Do not write a pounds-per-square-foot figure as a pass or a fail. A floor's code design load cannot be compared with a rack's weight to pass or fail a building.
- Until an engineer has reported, line 7 is "maybe". Only an engineer's finding makes it "good" or "stop".
- Line 8: ask each buyer for its own minimum.

## Gate 4. Cooling

### 9. Yard for cooling and generators

| Good | Maybe | Stop |
|---|---|---|
| Open yard the owner controls on two or more sides, with truck access and no homes adjoining | Yard on one side only. Or no yard, and equipment would have to go on a roof or another route that an engineer must check | A mechanical engineer has found no workable yard, roof or other route |

**Status** ☐ Good ☐ Maybe ☐ Stop ☐ Unknown

Evidence, source and date _____

_____

Note for this gate: a mechanical engineer sizes the plant. You are recording whether there is anywhere to put it. No yard is a "maybe" until an engineer has looked.

## Gate 5. Connectivity

### 10. Fiber carriers and routes

| Good | Maybe | Stop |
|---|---|---|
| Two or more carriers confirm fiber to the building, entering by different routes | One carrier with fiber. Or two that may share a route. Or map listings and markers only | Carriers confirm no fiber at or near the address, and no route they will build |

**Status** ☐ Good ☐ Maybe ☐ Stop ☐ Unknown

Evidence, source and date _____

_____

Note for this gate: the FCC map reports mass-market internet service. A listing does not prove data center connectivity, and a missing listing does not prove there is no fiber. Only a carrier's written response makes this line "good" or "stop".

## After the gates. The owner and the paper

### 11. Owner and title

| Good | Maybe | Stop |
|---|---|---|
| One decision maker, open to a sale or a lease, who shares bills and drawings. A signed brokerage agreement is in your broker's file | Interested but slow. Several owners. Or wants a price before facts. Or no signed agreement yet | A title dispute. Another party already holds rights. Or the owner will share nothing |

**Status** ☐ Good ☐ Maybe ☐ Stop ☐ Unknown

Evidence, source and date _____

_____

## Questions to carry

**For the owner**

- Can we read the main switchgear and transformer nameplates together?
- Can I see electric bills from the busiest year, showing peak demand?
- Do you have the original structural drawings or a slab report?
- What was the heaviest equipment on this floor, and did it have its own foundation?

- Which outdoor areas are inside your property line and free of easements?
- Are there recorded use restrictions, easements or covenants on the parcel?
- Has the building or yard ever flooded?
- Which carriers have equipment in your telecom room?
- Who else has to agree before you can sell or lease?

### For the utility, from the owner or with the owner's written permission

- What capacity can you serve at this address today without new construction?
- What would it take, and how long, to serve the amount we need?
- Which substation and feeder serve this address?
- Which rate schedule would a load of this size take?

### For a buyer

- Is your megawatt figure IT load or total site load?
- What minimum clear height do you need?
- Does your cooling design evaporate water?
- Which network hub must the site reach?

## Where the building stands

| | |
|---|---|
| Lines marked Stop (list them, with the reason and the source) | _____ |
| Lines marked Good, with the document that proves each one | _____ |
| Lines still Unknown, and who has been asked | _____ |
| Next written answer expected, from whom and by when | _____ |

### How to read it.

- **A "stop" on line 1, 4, 7 or 11 stops the building.** Write down the reason and the source, and tell the owner.
- **No "stop":** keep working the unknowns, starting with line 1. Power first, always.
- **Ready to show a buyer** is this book's meaning of "qualified". It means line 1 is "good", line 4 is "good" or "maybe", line 11 is "good", and no line says "stop". The other lines may still be "maybe" or "unknown". Say so in the fact file.

**Do not count the lines.** One fatal problem can end a project. Several fixable ones need not. A sheet with many unknowns means you do not have the facts yet. It does not mean the building is poor.

> **This sheet is not an approval.** Nothing on this page states capacity, feasibility, value or a pass. The serving utility confirms power in writing. Licensed engineers decide what the building can carry and cool. Local officials decide what is permitted.