MARCH 2025 SEMI-ANNUAL REPORT
FEDERAL PLAN OOO – NESHAP AAAA

RENEWABLE ENERGY FACILITY
HARPER COUNTY, KANSAS
SOURCE ID 0770275

Prepared for

Lynx Renewable Energy, LLC

March 2025

Prepared by

Weaver Consultants Group, LLC
6420 Southwest Boulevard, Suite 206
Fort Worth, Texas 76109
817-735-9770

Project No. 7343-351-50-15

Weaver
Consultants
Group

March 20, 2025
Project No. 7343-351-50-15

Kansas Compliance Officer
Air Permitting and Compliance Branch
US EPA, Region 7
11201 Renner Blvd.
Lenexa, KS 66219

Re: March 2025 Semi-Annual Report
Lynx Renewable Energy, LLC
Source ID 0770275
Harper County, Kansas

To Whom it May Concern:

On behalf of Lynx Renewable Energy, LLC., please find enclosed the March 2025 Semi-Annual Report. Lynx Renewable Energy, LLC (Lynx) owns and operates a treatment system located at Plumb Thicket Landfill in Harper County, Kansas. Lynx is subject to the requirements of the United States Environmental Protection Agency's (EPA) 40 Code of Federal Regulations (CFR) Part 62, Subpart OOO (Federal Plan) and Part 63, Subpart AAAA (NESHAP). In accordance with the Federal Plan, the site will follow the compliance, operation, monitoring and reporting provisions of the NESHAP in lieu of the provisions in the Federal Plan.

The Lynx Renewables treatment system is owned, operated, and permitted separately from the Plumb Thicket Landfill and, as such, maintains separate permitting and compliance requirements.

This report covers the period of August 29, 2024 through February 28, 2025.

If you have any questions or comments regarding this submittal, please feel free to call.

Sincerely,
Weaver Consultants Group, LLC

Ali Yee
FOR
Stacy Murdock
Project Manager

Angie S. Vandergriff
Senior Project Director

Attachment: March 2025 Semi-Annual Reports:
Federal Plan OOO – NESHAP AAAA

cc: Allyson Prue, Bureau of Air, KDHE
Terry Peak, Dynamic Renewables
Eric Hallman, Dynamic Renewables

CONTENTS

1 INTRODUCTION **1**

2 REPORTING REQUIREMENTS **2**
§63.1981(h)(1) – Monitoring and Exceedances 2
§63.1981(h)(1)(iii) – Treatment System 3
§63.1981(h)(2) – Bypass line 4
§63.1981(h)(3) – Control Device or Treatment System Downtime 4
§63.1981(h)(4) – Collection System Downtime 4
§63.1965 – Deviations 4

3 ADDITIONAL REPORTING / RECORDKEEPING **6**
§63.1961(h) / §62.16722(h) – Monitoring System Malfunctions 6
§63.1983(c)(1) / §62.16726(c)(1)(i) – Enclosed Combustors 6

4 LIMITATIONS **8**

APPENDIX A
Control Device Downtime Log

APPENDIX B
Collection System Downtime Log

1 INTRODUCTION

Lynx Renewable Energy, LLC (Lynx) owns and operates a treatment system located at Plumb Thicket Landfill in Harper County, Kansas. Lynx is subject to the requirements of the United States Environmental Protection Agency's (EPA) 40 Code of Federal Regulations (CFR) Part 62, Subpart OOO (Federal Plan) and Part 63, Subpart AAAA (NESHAP). In accordance with the Federal Plan, the site will follow the compliance, operation, monitoring and reporting provisions of the NESHAP in lieu of the provisions in the Federal Plan.

The Lynx Renewables treatment system is owned, operated, and permitted separately from the Plumb Thicket Landfill and, as such, maintains separate permitting and compliance requirements.

This report covers the period of August 29, 2024 through February 28, 2025.

National Emission Standards for Hazardous Air Pollutants
Notes and Objections to Semiannual Report Submittal

Lynx Renewable Energy, LLC submits this semiannual report covering the reporting period from August 29, 2024 to February 28, 2025 (the "Report") in accordance with the provisions of 40 C.F.R. Part 63, Subpart AAAA, the National Emission Standards for Hazardous Air Pollutants for Municipal Solid Waste Landfills ("Landfill NESHAP"). The Report consists of the CEDRI electronic file report, using Version 2.0, and the accompanying pdf narrative report form attached thereto. Lynx Renewable Energy, LLC's submittal of the Report, and its Certification thereof, is made subject to the notes and objections set forth herein.

The elements of semiannual reporting required pursuant to the Landfill NESHAP are set forth at 40 C.F.R. §63.1981(h). As required by 40 C.F.R. §63.1981(l)(2), Lynx Renewable Energy, LLC has utilized the electronic file reporting format established by EPA and made available via its CEDRI website. However, certain aspects of the CEDRI electronic file are inconsistent with, or more expansive than, the Landfill NESHAP. Accordingly, Lynx Renewable Energy, LLC preserves and does not waive any objection it may have to the propriety, completeness or accuracy of the CEDRI reporting format or its consistency with the requirements of the Landfill NESHAP. Specifically, Lynx Renewable Energy, LLC objects to the CEDRI electronic file reporting format to the extent that it purports to require the submittal of information that is not required to be maintained or submitted pursuant to the Landfill NESHAP, requires information to be reported in a format in which it would not otherwise be maintained, or renders such information inaccurate or incomplete. Lynx Renewable Energy, LLC further objects to the CEDRI electronic file reporting format to the extent that it fails to include or require the inclusion of information otherwise required to be submitted pursuant to the Landfill NESHAP.

In furtherance of its preparation of the Report using the CEDRI electronic file reporting format, Lynx Renewable Energy, LLC identifies the following specific notes and objections:

- There is an error in the "Number of Exceedances" tab of the CEDRI electronic file report: in this tab, the spreadsheet does not correctly calculate the number of exceedances due to an error in the formula embedded in the spreadsheet.

- There is a limitation in the number of entries that may be included in each tab of the CEDRI spreadsheet because each tab is locked and limited to 476 rows. This limit may preclude the inclusion of all relevant information within the electronic file report.

- There is no place to add the concentration value as required by the rulemaking. This precludes the inclusion of all relevant information within the electronic file report.

- The CEDRI electronic file purports to incorporate several elements of the general provisions of 40 C.F.R. Subpart 63, Subpart A, which are not applicable. For example, the electronic file refers to "CMS" in several locations. Lynx Renewable Energy, LLC has included information about enclosed flare temperature monitoring in these sections, where appropriate, and as relevant to the operating requirements set forth at 40 C.F.R.

§63.1983(c). However, the type of temperature monitoring equipment used at municipal solid waste landfills (thermocouples) are not typically required to meet the full set of requirements for more traditional continuous monitoring systems as set forth in Subpart A, such as equipment manufacturer, model number and calibration or certification information. Further, such information is not required to be maintained under the Landfill NESHAP and therefore is neither feasible nor required to be included within the Report. *See*, Table 1 to the Landfill NESHAP, which indicates that "Additional recordkeeping for sources with CMS" requirements under 40 C.F.R. §63.10(c) are not applicable to this sector. Accordingly, in completing the Report, Lynx Renewable Energy, LLC has completed only those fields in the CEDRI electronic file where applicable and/or otherwise appropriate.

- While the CEDRI electronic file format contains operating information required to be submitted under the Landfill NESHAP as set forth at 40 C.F.R. §63.1981(h), it is Lynx Renewable Energy, LLC's understanding that the certification and deviation requirements, as set forth in the "Certification" and "Deviation" tabs of the CEDRI spreadsheet, are applicable only to CMS systems at the affected facility, and do not apply to the other operational and compliance information required pursuant to the Landfill NESHAP.

- In the "exceedances" tab of the CEDRI electronic file, the duration of reported exceedances auto-calculates to hours. However, the nature of the Landfill NESHAP operational requirements, and the timing requirements for corrective action of initial monitored exceedances, would instead dictate that the duration of these events should be reported in days; Lynx Renewable Energy, LLC has submitted this information consistent with these requirements.

Submission of this Report and the information contained herein should not be construed as a waiver of any objection which Lynx Renewable Energy, LLC may have to the legal propriety of the agency's requiring or using information submitted in the Report to assess Lynx Renewable Energy, LLC's compliance status and any such objections are hereby reserved regardless of whether a specific objection is identified herein.

2 REPORTING REQUIREMENTS

Records are prepared and maintained in accordance with Title 40 CFR §63.1982. The primary location for records storage is the Lynx Renewable Energy Facility (Facility).

The Facility does not own a landfill; however, the following summarizes the requirements of §63.1981(h)(1) through (h)(4). Sections §63.1981(h)(5) through (h)(8) are omitted as they do not apply to a landfill gas processing facility.

§63.1981(h)(1) – Monitoring and Exceedances

Number of times that applicable parameters monitored under §63.1958(b), (c), and (d) were exceeded and when the gas collection and control system was not operating under §63.1958(e), including periods of SSM. For each instance, report the date, time, and duration of each exceedance.

§63.1958(b) – Wellfield Pressure
Operate the collection system with negative pressure at each wellhead.

The Facility does not own a landfill; therefore §63.1958(b) is not applicable.

§63.1958(c) – Wellfield Temperature
Operate each interior wellhead in the collection system as specified in 40 CFR §60.753(c), until the landfill owner or operator elects to meet the operational standard for temperature in paragraph (c)(1) of this section.

The Facility does not own a landfill; therefore §63.1958(c) is not applicable.

§63.1958(d) – Surface Emissions Monitoring
Operate the collection system so that the methane concentration is less than 500 parts per million (ppm) above background at the surface of the landfill. To determine if this level is exceeded, the owner or operator must conduct surface testing around the perimeter of the collection area and along a pattern that traverses the landfill at no more than 30-meter intervals and where visual observations indicate elevated concentrations of landfill gas, such as distressed vegetation and cracks or seeps in the cover. The owner or operator may establish an alternative traversing pattern that ensures equivalent coverage. A surface monitoring design plan must be developed that includes a topographical map with the monitoring route and the rationale for any site-specific deviations from the 30-meter intervals. Areas with steep slopes or other dangerous areas may be excluded from the surface testing.

The Facility does not own a landfill; therefore §63.1958(d) is not applicable.

§63.1958(e) – Work Practice Standards
Operate the system as specified in §60.753(e) of this chapter, except:

(1) Beginning no later than September 27, 2021, operate the system in accordance to §63.1955(c) such that all collected gases are vented to a control system designed and operated in compliance with §63.1959(b)(2)(iii). In the event the collection or control system is not operating:

(i) The gas mover system must be shut down and all valves in the collection and control system contributing to venting of the gas to the atmosphere must be closed within 1 hour of the collection or control system not operating; and

(ii) Efforts to repair the collection or control system must be initiated and completed in a manner such that downtime is kept to a minimum, and the collection and control system must be returned to operation.

§63.1960(e)(2) states that the provisions of this subpart apply at all times, including periods of startup, shutdown, or malfunction. However, during periods of startup, shutdown, or malfunction, the site must follow the work practice standards specified in §63.1958(e) in lieu of compliance with §63.1960.

The site operated the collection and control system in accordance with §63.1958(e) such that all collected gases sent to the control system were controlled per §63.1959(b)(2)(iii). In all incidences when the control system was not operating, as noted in Appendix B, the valve(s) to the control system were closed within one hour to control the venting of gas to the atmosphere.

§63.1981(h)(1)(iii) – Treatment System

Beginning no later than September 27, 2021, number of times the parameters for the site-specific treatment system in §63.1961(g) were exceeded.

§63.1961(g) – Each owner or operator seeking to demonstrate compliance with §63.1959(b)(2)(iii)(C) using a landfill gas treatment system must calibrate, maintain, and operate according to the manufacturer's specifications a device that records flow to the treatment system and bypass of the treatment system (if applicable). Beginning no later than September 27, 2021, each owner or operator must maintain and operate all monitoring systems associated with the treatment system in accordance with the site-specific treatment system monitoring plan required in §63.1983(b)(5)(ii). The owner or operator must:

(1) Install, calibrate, and maintain a gas flow rate measuring device that records the flow to the treatment system at least every 15 minutes; and

(2) Secure the bypass line valve in the closed position with a car-seal or a lock-and-key type configuration. A visual inspection of the seal or closure mechanism must be performed at least once every month to ensure that the valve is maintained in the closed position and that the gas flow is not diverted through the bypass line.

In accordance with §63.1961(g) Lynx Renewable Energy, LLC owns and operates a landfill treatment system at the landfill which processes the collected gas for subsequent sale or beneficial use. There are no vents within the treatment system which allow venting of gas to the atmosphere. The treatment system is not designed or equipped to bypass the control devices. A calibrated flow meter is installed to measure flow to the treatment system. Lynx Renewable Energy, LLC maintains and operates all monitoring systems associated with the treatment system in accordance with the Lynx Renewable Energy, LLC, site-specific treatment system monitoring plan required by §63.1983(b)(5)(ii). During this reporting period there were no parameter exceedances of the Treatment Monitoring Plan. During deep freeze events in January and February there were instances when the differential pressure was not accurately recorded. However, all data indicates the system operated as designed.

§63.1981(h)(2) – Bypass line

> Description and duration of all periods when the gas stream was diverted from the control device or treatment system through a bypass line or the indication of bypass flow as specified under §63.1961.

The gas collection system is not designed nor equipped to bypass the control devices; therefore §63.1961 is not applicable.

§63.1981(h)(3) – Control Device or Treatment System Downtime

> Description and duration of all periods when the control device or treatment system was not operating and length of time the control device or treatment system was not operating.

The table provided in Appendix A summarizes all the periods when the control device and treatment system were not operating.

§63.1981(h)(4) – Collection System Downtime

> All periods when the collection system was not operating.

The table provided in Appendix B summarizes all the periods when the collection system was not operating.

§63.1965 – Deviations

> A deviation is defined in §63.1990. For the purposes of the landfill monitoring and SSM plan requirements, deviations include the items in paragraphs (a) through (c) of this section.

(a) A deviation occurs when the control device operating parameter boundaries described in §63.1983(c)(1) are exceeded.

There were no deviations as described during this reporting period.

(b) A deviation occurs when 1 hour or more of the hours during the 3-hour block averaging period does not constitute a valid hour of data. A valid hour of data must have measured values for at least three 15-minute monitoring periods within the hour.

There were no deviations as described during this reporting period.

(c) Before September 28, 2021, a deviation occurs when a SSM plan is not developed or maintained on site and when an affected source fails to meet any emission limitation, (including any operating limit), or work practice requirement in this subpart during SSM, regardless of whether or not such failure is permitted by this subpart.

The requirement for a SSM Plan is no longer applicable to the site.

3 ADDITIONAL REPORTING / RECORDKEEPING

The information in this section includes additional reporting / recordkeeping within the NESHAP AAAA and / or Federal Plan OOO.

§63.1961(h) / §62.16722(h) – Monitoring System Malfunctions

> The monitoring requirements of paragraphs (b), (c) (d) and (g) of this section apply at all times the affected source is operating, except for periods of monitoring system malfunctions, repairs associated with monitoring system malfunctions, and required monitoring system quality assurance or quality control activities. A monitoring system malfunction is any sudden, infrequent, not reasonably preventable failure of the monitoring system to provide valid data. Monitoring system failures that are caused in part by poor maintenance or careless operation are not malfunctions. You are required to complete monitoring system repairs in response to monitoring system malfunctions and to return the monitoring system to operation as expeditiously as practicable.

During this reporting period there were times when the monitoring system malfunctioned. Repairs were made as expeditiously as practicable to return the monitoring system to operation.

§63.1983(c)(1) / §62.16726(c)(1)(i) – Enclosed Combustors

> (1) The following constitute exceedances that must be recorded and reported under §63.1981(h):
> (i) For enclosed combustors except for boilers and process heaters with design heat input capacity of 44 megawatts (150 million British thermal unit per hour) or greater, all 3-hour periods of operation during which the average temperature was more than 28 degrees Celsius (82 degrees Fahrenheit) below the average combustion temperature during the most recent performance test at which compliance with §63.1959(b)(2)(iii) was determined.

Enclosed Combustor - §63.1983(c)(1) refers to 3-hour periods of operation and stipulates that there should not be a three-hour period of operation where an enclosed combustion device is 28°C below the temperature determined in the most recent performance test. However, the rules do not specify that this is a 3-hour rolling average, 3-hour block average, or 3 hours of average temperature readings continuously and consistently below the minimum temperature from the flare recording device. By nature, temperatures within an enclosed combustion device will fluctuate. These fluctuations are to be expected during normal operations. In compliance with §63.1983(c)(1) each recorded temperature reading, measured at least every 15 minutes within the enclosed combustor, is an average temperature for the time interval between the next reading. As such, the facility counts 3-hour periods of operation of low temperatures using the temperatures which come directly from the data recorder. These average temperatures readings will be taken directly from the data recorder for the control device and any 3-hour period of operation where the recorded average combustion temperatures are continuously and consistently 28°C (82°F) below the temperature determined in the most recent performance test will be reported to the appropriate regulatory agencies if it is not associated with any startup, shutdown, or malfunction.

A performance test was conducted for the thermal oxidizer on June 28, 2022. For future operations in response to this performance test, all periods longer than (3) hours must be recorded and reported where the operation temperature is more than 28°C (82°F) below the average operating temperature recorded during the performance test. There were no such events during this reporting period.

4 LIMITATIONS

This report has been prepared by Weaver Consultants Group, LLC (WCG) as authorized by Lynx Renewable Energy, LLC. The report was prepared based on WCG's review of information provided by Lynx Renewable Energy, LLC. The services described in this report were performed consistent with generally accepted professional consulting principles and practices. No other warranty, expressed or implied, is made. These services were performed consistent with our agreement with our client. Any reliance on this report by a third-party company is at such part's sole risk. We do not warrant the accuracy of the information supplied by others or the use of segregated portions of this report.

APPENDIX A

CONTROL DEVICE DOWNTIME LOG

Control Device Downtime Log
Process Utility Flare
Reporting Period - August 29, 2024 through February 28, 2025

Shutdown Date/Time	Startup Date/Time	Duration (h:mm)	Description
9/2/2024 11:40	9/2/2024 12:40	1:00	Alarm Trip
9/3/2024 8:00	9/3/2024 15:30	7:30	Maintenance
9/3/2024 19:20	9/4/2024 9:00	13:40	Save Fuel
9/4/2024 19:20	9/5/2024 15:50	20:30	Save Fuel
9/5/2024 17:40	9/5/2024 19:00	1:20	Alarm Trip
9/5/2024 19:50	9/6/2024 15:40	19:50	Save Fuel
9/6/2024 18:30	9/7/2024 14:50	20:20	Save Fuel
9/7/2024 18:40	9/8/2024 14:30	19:50	Save Fuel
9/8/2024 19:20	9/9/2024 14:40	19:20	Save Fuel
9/9/2024 19:20	9/10/2024 14:20	19:00	Save Fuel
9/10/2024 19:20	9/11/2024 14:30	19:10	Save Fuel
9/11/2024 21:00	9/12/2024 11:10	14:10	Save Fuel
9/12/2024 22:40	9/13/2024 10:40	12:00	Save Fuel
9/14/2024 2:10	9/14/2024 6:30	4:20	Alarm Trip
9/14/2024 6:50	9/14/2024 7:50	1:00	Alarm Trip
9/14/2024 8:30	9/14/2024 10:00	1:30	Alarm Trip/Maintenance
9/14/2024 22:10	9/15/2024 2:50	4:40	Save Fuel
9/15/2024 5:10	9/15/2024 10:40	5:30	Alarm Trip/Maintenance
9/19/2024 7:50	9/19/2024 13:40	5:50	Maintenance

Control Device Downtime Log
Process Utility Flare
Reporting Period - August 29, 2024 through February 28, 2025

Shutdown Date/Time	Startup Date/Time	Duration (h:mm)	Description
9/19/2024 18:40	9/20/2024 13:50	19:10	Save Fuel
9/20/2024 19:10	9/21/2024 14:10	19:00	Save Fuel
9/21/2024 16:10	9/25/2024 10:50	90:40	Save Fuel
9/25/2024 11:10	9/25/2024 16:20	5:10	Save Fuel
9/25/2024 18:00	9/26/2024 14:50	20:50	Save Fuel
9/26/2024 18:30	9/27/2024 16:30	22:00	Save Fuel
9/27/2024 18:00	9/28/2024 14:10	20:10	Save Fuel
9/29/2024 4:30	9/29/2024 10:30	6:00	Save Fuel
9/30/2024 6:30	9/30/2024 10:30	4:00	Save Fuel
10/1/2024 3:10	10/1/2024 8:00	4:50	Save Fuel
10/1/2024 8:50	10/1/2024 11:10	2:20	Save Fuel
10/1/2024 11:50	10/1/2024 13:00	1:10	Save Fuel
10/2/2024 5:30	10/2/2024 10:20	4:50	Save Fuel
10/4/2024 8:20	10/4/2024 10:00	1:40	Save Fuel
10/8/2024 8:10	10/8/2024 17:40	9:30	Maintenance
10/8/2024 20:40	10/9/2024 14:40	18:00	Alarm Trip
10/9/2024 17:50	10/9/2024 19:30	1:40	Save Fuel
10/9/2024 20:40	10/9/2024 22:00	1:20	Save Fuel
10/9/2024 23:00	10/10/2024 10:30	11:30	Save Fuel

Control Device Downtime Log
Process Utility Flare
Reporting Period - August 29, 2024 through February 28, 2025

Shutdown Date/Time	Startup Date/Time	Duration (h:mm)	Description
10/10/2024 10:40	10/10/2024 11:20	0:40	Save Fuel
10/10/2024 12:10	10/10/2024 15:10	3:00	Save Fuel
10/10/2024 17:30	10/11/2024 15:00	21:30	Save Fuel
10/11/2024 18:30	10/12/2024 14:00	19:30	Save Fuel
10/12/2024 18:10	10/13/2024 10:00	15:50	Save Fuel
10/13/2024 10:40	10/13/2024 11:40	1:00	Maintenance
10/13/2024 12:20	10/14/2024 3:50	15:30	Save Fuel
10/14/2024 7:10	10/14/2024 15:20	8:10	Save Fuel
10/14/2024 17:40	10/16/2024 16:10	46:30	Save Fuel
10/16/2024 17:40	10/17/2024 12:50	19:10	Save Fuel
10/17/2024 19:00	10/17/2024 22:00	3:00	Save Fuel
10/17/2024 22:40	10/18/2024 10:40	12:00	Save Fuel
10/20/2024 8:10	10/20/2024 9:30	1:20	Save Fuel
10/21/2024 8:00	10/21/2024 9:00	1:00	Save Fuel
10/23/2024 8:30	10/23/2024 10:00	1:30	Save Fuel
10/24/2024 7:50	10/24/2024 14:00	6:10	Maintenance
10/24/2024 17:30	10/26/2024 15:00	45:30	Save Fuel
10/26/2024 18:30	10/27/2024 15:30	21:00	Save Fuel
10/27/2024 16:40	10/29/2024 15:10	46:30	Save Fuel

Control Device Downtime Log

Process Utility Flare

Reporting Period - August 29, 2024 through February 28, 2025

Shutdown Date/Time	Startup Date/Time	Duration (h:mm)	Description
10/29/2024 16:10	11/1/2024 16:10	72:00	Save Fuel
11/1/2024 16:40	11/3/2024 8:00	39:20	Save Fuel
11/3/2024 8:30	11/3/2024 9:30	1:00	Save Fuel
11/5/2024 7:40	11/5/2024 15:10	7:30	Save Fuel
11/5/2024 19:10	11/6/2024 9:50	14:40	Save Fuel
11/6/2024 10:20	11/6/2024 11:30	1:10	Save Fuel
11/6/2024 19:20	11/7/2024 7:10	11:50	Save Fuel
11/7/2024 7:50	11/7/2024 16:30	8:40	Maintenance
11/7/2024 20:30	11/8/2024 10:50	14:20	Save Fuel
11/8/2024 11:30	11/13/2024 12:10	120:40	Save Fuel
11/13/2024 12:40	11/13/2024 14:10	1:30	Save Fuel
11/13/2024 15:20	11/14/2024 8:30	17:10	Save Fuel
11/26/2024 8:10	11/26/2024 14:40	6:30	Maintenance
11/26/2024 18:10	12/3/2024 22:40	172:29	Save Fuel
12/4/2024 6:40	12/6/2024 9:20	50:40	Save Fuel
12/10/2024 13:00	12/10/2024 13:20	0:20	Alarm Trip
12/15/2024 7:20	12/15/2024 7:30	0:10	Alarm Trip
12/18/2024 7:50	12/18/2024 16:10	8:20	Maintenance
12/18/2024 19:10	12/26/2024 10:10	183:00	Save Fuel

Control Device Downtime Log
Process Utility Flare
Reporting Period - August 29, 2024 through February 28, 2025

Shutdown Date/Time	Startup Date/Time	Duration (h:mm)	Description
12/26/2024 10:20	12/26/2024 10:40	0:20	Save Fuel
12/26/2024 11:20	12/30/2024 7:20	92:00	Save Fuel
12/30/2024 13:00	12/30/2024 23:20	10:20	Save Fuel
12/31/2024 8:20	12/31/2024 9:20	1:00	Save Fuel
12/31/2024 10:30	12/31/2024 14:30	4:00	Save Fuel
12/31/2024 18:10	12/31/2024 23:30	5:20	Save Fuel
1/1/2025 10:20	1/1/2025 12:30	2:10	Save Fuel
1/2/2025 10:20	1/2/2025 11:50	1:30	Save Fuel
1/2/2025 12:30	1/2/2025 14:30	2:00	Save Fuel
1/7/2025 17:50	1/7/2025 18:20	0:30	Save Fuel
1/8/2025 3:00	1/8/2025 4:50	1:50	Save Fuel
1/8/2025 14:00	1/8/2025 14:10	0:10	Save Fuel
1/8/2025 15:10	1/8/2025 16:00	0:50	Save Fuel
1/10/2025 13:40	1/10/2025 14:30	0:50	Save Fuel
1/15/2025 7:50	1/15/2025 15:10	7:20	Maintenance
1/15/2025 19:20	1/17/2025 7:20	36:00	Save Fuel
1/17/2025 8:20	1/17/2025 16:40	8:20	Save Fuel
1/17/2025 17:20	1/19/2025 4:00	34:40	Save Fuel
1/19/2025 4:10	1/19/2025 4:20	0:10	Alarm Trip

Control Device Downtime Log
Process Utility Flare
Reporting Period - August 29, 2024 through February 28, 2025

Shutdown Date/Time	Startup Date/Time	Duration (h:mm)	Description
1/19/2025 6:10	1/20/2025 7:10	25:00	Save Fuel
1/20/2025 8:20	1/21/2025 8:30	24:10	Save Fuel
1/21/2025 9:30	1/22/2025 11:40	26:10	Save Fuel
1/22/2025 16:00	1/22/2025 16:40	0:40	Save Fuel
1/22/2025 18:20	1/23/2025 12:20	18:00	Save Fuel
1/24/2025 9:40	1/24/2025 10:00	0:20	Power Outage
1/26/2025 9:50	1/26/2025 10:50	1:00	Mechanical Failure
1/26/2025 11:30	1/26/2025 11:40	0:10	Alarm Trip
2/3/2025 8:10	2/3/2025 17:10	9:00	Maintenance
2/3/2025 20:40	2/4/2025 0:30	3:50	Save Fuel
2/5/2025 10:10	2/5/2025 15:30	5:20	Save Fuel
2/5/2025 15:40	2/7/2025 10:20	42:40	Save Fuel
2/7/2025 10:50	2/12/2025 8:20	117:29	Save Fuel
2/12/2025 8:50	2/12/2025 10:10	1:20	Save Fuel
2/12/2025 11:00	2/12/2025 23:40	12:40	Save Fuel
2/13/2025 2:20	2/15/2025 2:40	48:20	Save Fuel
2/15/2025 5:30	2/16/2025 2:50	21:20	Save Fuel
2/16/2025 5:20	2/16/2025 6:50	1:30	Save Fuel
2/16/2025 7:30	2/17/2025 12:40	29:09	Save Fuel

Control Device Downtime Log

Process Utility Flare

Reporting Period - August 29, 2024 through February 28, 2025

Shutdown Date/Time	Startup Date/Time	Duration (h:mm)	Description
2/17/2025 14:50	2/18/2025 0:50	10:00	Save Fuel
2/18/2025 1:50	2/18/2025 6:00	4:10	Save Fuel
2/18/2025 6:50	2/18/2025 14:20	7:30	Save Fuel
2/18/2025 15:20	2/18/2025 16:00	0:40	Save Fuel
2/26/2025 9:30	2/26/2025 17:50	8:20	Maintenance
2/26/2025 18:10	2/26/2025 19:00	0:50	Save Fuel
2/26/2025 21:40	2/27/2025 9:40	12:00	Save Fuel
2/27/2025 10:50	2/28/2025 16:20	29:30	Save Fuel
2/28/2025 16:50	2/28/2025 17:40	0:50	Save Fuel
2/28/2025 18:00	3/1/2025 6:10	12:10	Save Fuel

Thermal Oxidizer Downtime Log

Reporting Period - August 29, 2024 through February 28, 2025

Shutdown Date/Time	Startup Date/Time	Duration (h:mm)	Description
9/2/2024 11:50	9/2/2024 13:10	1:20	Alarm Trip
9/3/2024 7:40	9/3/2024 16:20	8:40	Maintenance
9/5/2024 17:40	9/5/2024 19:10	1:30	Alarm Trip
9/14/2024 6:50	9/14/2024 10:10	3:20	Alarm Trip/Maintenance
9/15/2024 2:10	9/15/2024 11:20	9:10	Alarm Trip/Maintenance
9/19/2024 7:50	9/19/2024 15:30	7:40	Maintenance
10/8/2024 7:50	10/8/2024 18:30	10:40	Maintenance
10/9/2024 19:30	10/9/2024 22:40	3:10	Alarm Trip
10/10/2024 10:40	10/10/2024 11:30	0:50	Maintenance
10/12/2024 15:20	10/12/2024 16:40	1:20	Alarm Trip
10/13/2024 10:40	10/13/2024 11:50	1:10	Maintenance
10/24/2024 7:40	10/24/2024 14:50	7:10	Maintenance
10/26/2024 14:00	10/26/2024 15:30	1:30	Alarm Trip
11/7/2024 7:40	11/7/2024 17:10	9:30	Maintenance
11/26/2024 7:30	11/26/2024 15:20	7:50	Maintenance
12/3/2024 22:50	12/3/2024 23:40	0:50	Alarm Trip
12/6/2024 9:20	12/14/2024 16:00	198:40	Mechanical Failure
12/15/2024 5:10	12/15/2024 7:10	2:00	Alarm Trip
12/15/2024 7:30	12/15/2024 9:00	1:30	Alarm Trip

Thermal Oxidizer Downtime Log

Reporting Period - August 29, 2024 through February 28, 2025

Shutdown Date/Time	Startup Date/Time	Duration (h:mm)	Description
12/16/2024 12:50	12/16/2024 14:30	1:40	Alarm Trip
12/18/2024 7:40	12/18/2024 17:10	9:30	Maintenance
12/26/2024 10:10	12/26/2024 11:00	0:50	Alarm Trip
12/30/2024 7:30	12/30/2024 11:40	4:10	Well Raising
12/30/2024 23:30	12/31/2024 8:20	8:50	Alarm Trip
1/5/2025 6:40	1/5/2025 12:10	5:30	Alarm Trip
1/5/2025 15:40	1/5/2025 17:10	1:30	Alarm Trip
1/5/2025 21:30	1/7/2025 15:50	42:20	Alarm Trip
1/8/2025 14:00	1/8/2025 17:20	3:20	Alarm Trip
1/10/2025 12:20	1/10/2025 12:40	0:20	Alarm Trip
1/10/2025 13:10	1/10/2025 13:20	0:10	Alarm Trip
1/10/2025 13:40	1/10/2025 15:40	2:00	Alarm Trip
1/10/2025 17:10	1/10/2025 18:10	1:00	Alarm Trip
1/15/2025 7:50	1/15/2025 16:20	8:30	Maintenance
1/17/2025 7:30	1/17/2025 8:10	0:40	Poor Quality
1/19/2025 4:10	1/19/2025 5:30	1:20	Mechanical Failure
1/20/2025 7:20	1/20/2025 7:50	0:30	Alarm Trip
1/21/2025 8:50	1/21/2025 9:20	0:30	Alarm Trip
1/22/2025 11:50	1/22/2025 14:30	2:40	Alarm Trip

Thermal Oxidizer Downtime Log

Reporting Period - August 29, 2024 through February 28, 2025

Shutdown Date/Time	Startup Date/Time	Duration (h:mm)	Description
1/22/2025 16:50	1/22/2025 18:10	1:20	Alarm Trip
1/23/2025 13:20	1/23/2025 14:10	0:50	Alarm Trip
1/24/2025 9:40	1/24/2025 10:40	1:00	Power Outage
1/26/2025 9:00	1/26/2025 12:10	3:10	Mechanical Failure
1/27/2025 9:20	1/27/2025 9:30	0:10	Alarm Trip
1/28/2025 4:00	1/28/2025 8:00	4:00	Mechanical Failure
2/3/2025 7:50	2/3/2025 18:30	10:40	Maintenance
2/4/2025 0:40	2/4/2025 8:10	7:30	Mechanical Failure
2/4/2025 8:40	2/5/2025 10:00	25:20	Mechanical Failure
2/12/2025 8:20	2/12/2025 8:40	0:20	Mechanical Failure
2/12/2025 10:20	2/12/2025 10:50	0:30	Mechanical Failure
2/12/2025 23:50	2/13/2025 1:20	1:30	Mechanical Failure
2/15/2025 2:50	2/15/2025 4:10	1:20	Mechanical Failure
2/16/2025 3:00	2/16/2025 4:40	1:40	Mechanical Failure
2/16/2025 7:00	2/16/2025 7:20	0:20	Mechanical Failure
2/17/2025 12:50	2/17/2025 13:30	0:40	Mechanical Failure
2/18/2025 1:00	2/18/2025 1:30	0:30	Alarm Trip
2/18/2025 6:10	2/18/2025 6:40	0:30	Alarm Trip
2/18/2025 14:30	2/18/2025 14:50	0:20	Alarm Trip

Thermal Oxidizer Downtime Log

Reporting Period - August 29, 2024 through February 28, 2025

Shutdown Date/Time	Startup Date/Time	Duration (h:mm)	Description
2/18/2025 16:00	2/25/2025 14:10	166:10	Mechanical Failure
2/26/2025 8:50	2/26/2025 19:50	11:00	Maintenance
2/27/2025 9:50	2/27/2025 10:20	0:30	Alarm Trip

Treatment System Downtime Log

Reporting Period - August 29, 2024 through February 28, 2025

Shutdown Date/Time	Startup Date/Time	Duration (h:mm)	Description
9/2/2024 11:40	9/2/2024 12:40	1:00	Alarm Trip
9/3/2024 7:50	9/3/2024 15:30	7:40	Maintenance
9/5/2024 17:40	9/5/2024 19:00	1:20	Alarm Trip
9/14/2024 6:50	9/14/2024 7:50	1:00	Alarm Trip
9/14/2024 8:20	9/14/2024 10:00	1:40	Alarm Trip
9/15/2024 2:00	9/15/2024 2:50	0:50	Alarm Trip
9/15/2024 5:10	9/15/2024 10:40	5:30	Alarm Trip/Maintenance
9/19/2024 7:50	9/19/2024 13:40	5:50	Maintenance
10/8/2024 8:00	10/8/2024 17:40	9:40	Maintenance
10/9/2024 20:40	10/9/2024 22:00	1:20	Alarm Trip
10/10/2024 10:40	10/10/2024 11:20	0:40	Maintenance
10/12/2024 15:20	10/12/2024 15:30	0:10	Alarm Trip
10/13/2024 10:40	10/13/2024 11:40	1:00	Maintenance
10/24/2024 7:40	10/24/2024 14:00	6:20	Maintenance
10/26/2024 14:00	10/26/2024 15:00	1:00	Alarm Trip
11/7/2024 7:40	11/7/2024 16:30	8:50	Maintenance
11/26/2024 8:00	11/26/2024 14:40	6:40	Maintenance
12/3/2024 22:40	12/3/2024 23:00	0:20	Alarm Trip
12/7/2024 18:00	12/7/2024 18:30	0:30	Alarm Trip

Treatment System Downtime Log

Reporting Period - August 29, 2024 through February 28, 2025

Shutdown Date/Time	Startup Date/Time	Duration (h:mm)	Description
12/10/2024 13:00	12/10/2024 13:20	0:20	Alarm Trip
12/15/2024 7:20	12/15/2024 7:30	0:10	Alarm Trip
12/16/2024 12:40	12/16/2024 13:00	0:20	Alarm Trip
12/18/2024 7:50	12/18/2024 16:10	8:20	Maintenance
12/26/2024 10:10	12/26/2024 10:40	0:30	Alarm Trip
1/8/2025 14:00	1/8/2025 14:10	0:10	Alarm Trip
1/8/2025 15:10	1/8/2025 16:00	0:50	Alarm Trip
1/10/2025 13:40	1/10/2025 14:30	0:50	Alarm Trip
1/15/2025 7:50	1/15/2025 15:10	7:20	Maintenance
1/19/2025 4:10	1/19/2025 4:20	0:10	Alarm Trip
1/24/2025 9:40	1/24/2025 10:00	0:20	Power Outage
1/26/2025 9:50	1/26/2025 10:50	1:00	Mechanical Failure
1/26/2025 11:30	1/26/2025 11:40	0:10	Alarm Trip
2/3/2025 8:00	2/3/2025 17:10	9:10	Maintenance
2/12/2025 23:50	2/13/2025 0:00	0:10	Alarm Trip
2/18/2025 1:00	2/18/2025 1:10	0:10	Alarm Trip
2/18/2025 6:10	2/18/2025 6:20	0:10	Alarm Trip
2/26/2025 9:10	2/26/2025 17:50	8:40	Maintenance
2/26/2025 18:10	2/26/2025 19:00	0:50	Alarm Trip

APPENDIX B

COLLECTION SYSTEM DOWNTIME LOG

Collection System Downtime Log

Reporting Period - August 29, 2024 through February 28, 2025

Shutdown Date/Time	Startup Date/Time	Duration (h:mm)
9/2/2024 11:40	9/2/2024 12:40	1:00
9/5/2024 17:40	9/5/2024 19:00	1:20
9/14/2024 6:50	9/14/2024 7:50	1:00
9/14/2024 8:20	9/14/2024 10:00	1:40
9/15/2024 2:00	9/15/2024 2:50	0:50
9/15/2024 10:35	9/15/2024 10:40	0:04
9/19/2024 13:36	9/19/2024 13:40	0:03
10/8/2024 17:22	10/8/2024 17:40	0:17
10/9/2024 21:52	10/9/2024 22:00	0:07
10/10/2024 10:40	10/10/2024 10:43	0:03
10/10/2024 11:13	10/10/2024 11:20	0:06
10/12/2024 15:20	10/12/2024 15:30	0:10
10/13/2024 10:40	10/13/2024 10:44	0:04
10/13/2024 11:34	10/13/2024 11:40	0:05
10/24/2024 13:57	10/24/2024 14:00	0:02
10/26/2024 14:00	10/26/2024 15:00	1:00
11/7/2024 7:40	11/7/2024 8:01	0:21
11/7/2024 12:41	11/7/2024 13:01	0:20
11/7/2024 16:21	11/7/2024 16:30	0:08

Collection System Downtime Log

Reporting Period - August 29, 2024 through February 28, 2025

Shutdown Date/Time	Startup Date/Time	Duration (h:mm)
11/26/2024 8:00	11/26/2024 8:07	0:07
11/26/2024 14:37	11/26/2024 14:40	0:02
12/3/2024 22:40	12/3/2024 23:00	0:20
12/7/2024 18:00	12/7/2024 18:30	0:30
12/10/2024 13:00	12/10/2024 13:20	0:20
12/15/2024 7:20	12/15/2024 7:30	0:10
12/16/2024 12:40	12/16/2024 13:00	0:20
12/18/2024 15:54	12/18/2024 16:10	0:16
12/26/2024 10:10	12/26/2024 10:40	0:30
1/8/2025 14:00	1/8/2025 14:10	0:10
1/8/2025 15:10	1/8/2025 16:00	0:50
1/10/2025 13:40	1/10/2025 13:50	0:10
1/10/2025 14:20	1/10/2025 14:30	0:09
1/15/2025 15:02	1/15/2025 15:10	0:08
1/19/2025 4:10	1/19/2025 4:20	0:10
1/24/2025 9:40	1/24/2025 10:00	0:20
1/26/2025 10:46	1/26/2025 10:50	0:03
1/26/2025 11:30	1/26/2025 11:40	0:10
2/12/2025 23:50	2/13/2025 0:00	0:10

Collection System Downtime Log

Reporting Period - August 29, 2024 through February 28, 2025

Shutdown Date/Time	Startup Date/Time	Duration (h:mm)
2/18/2025 1:00	2/18/2025 1:10	0:10
2/18/2025 6:10	2/18/2025 6:20	0:10
2/26/2025 9:10	2/26/2025 9:15	0:05
2/26/2025 17:45	2/26/2025 17:50	0:04