CHS Floating Roof Tank-Seal Inspections

Tank Identification A-31 IFR/EFR IFR Diameter 98'6" ft. Height 48 ft.

Applicable Regulation Kb / MACT Construction Date 1991

Seal Inspection (check one) (✓) Primary (__) Secondary (__) Both Seals

Reason for Inspection Annual

Name of Inspector (print) Andy Vogelsberg

Inspection Summary

Primary Seal Type: MSS

Seal Gap Measurements:

Gap Length L (in.)	Maximum Gap Width W_{max} (in.)	Average Gap Width W_{avg}(in.) = (W_{max}+1/8) / 2	Gap Area A (in²) = W_{avg} L	Tank Diameter (ft.) D	Seal Gap Ratio R R=A_{tot}/D
0	0	0	0	98'6"	0

Check one:
(✓) Primary seal passed visual inspection, NO corrective action required.

(__) Primary seal failed visual inspection, corrective action IS required.

Secondary Seal Type: ________

Seal Gap Measurements:

Gap Length L (in.)	Maximum Gap Width W_{max} (in.)	Average Gap Width W_{avg}(in.) = (W_{max}+1/8) / 2	Gap Area A(in²) = W_{avg} L	Tank Diameter (ft.) D	Seal Gap Ratio R R=A_{tot}/D

Check one:
(__) Secondary seal passed visual inspection, NO corrective action required.

(__) Secondary seal failed visual inspection, corrective action IS required.

List any failure type(s) and corrective action taken/to be taken (i.e. liquid on roof, detached seals, visible seal gaps, floating roof/fitting failure, etc. If no failures are listed, all components are compliant)

____

____

____

Signature of Inspector: [signature] Date of Inspection: 6/5/25

CHS Floating Roof Tank-Seal Inspections

Tank Identification J-07 IFR/EFR EFR Diameter 150 ft. Height 48 ft.

Applicable Regulation Kb / RMACT Construction Date 1994

Seal Inspection (check one) ( ) Primary (✓) Secondary ( ) Both Seals

Reason for Inspection Annual

Name of Inspector (print) Shelby Heppes

Inspection Summary

Primary Seal Type: ______

Seal Gap Measurements:

Gap Length L (in.)	Maximum Gap Width W_{max} (in.)	Average Gap Width W_{avg}(in.) = (W_{max}+1/8) / 2	Gap Area A (in^2) = W_{avg} L	Tank Diameter (ft.) D	Seal Gap Ratio R R=A_{tot}/D

Check one:
( ) Primary seal passed visual inspection, NO corrective action required.

( ) Primary seal failed visual inspection, corrective action IS required.

Secondary Seal Type: Wiper

Seal Gap Measurements:

Gap Length L (in.)	Maximum Gap Width W_{max} (in.)	Average Gap Width W_{avg}(in.) = (W_{max}+1/8) / 2	Gap Area A(in^2) = W_{avg} L	Tank Diameter (ft.) D	Seal Gap Ratio R R=A_{tot}/D
0	0	0	0	150	0

Check one:
(✓) Secondary seal passed visual inspection, NO corrective action required.

( ) Secondary seal failed visual inspection, corrective action IS required.

List any failure type(s) and corrective action taken/to be taken (i.e. liquid on roof, detached seals, visible seal gaps, floating roof/fitting failure, etc. If no failures are listed, all components are compliant)

______

______

______

Signature of Inspector: [signature] Date of Inspection: 6-5-25