



April 22, 2025

Connie Ellis
Compliance and Reporting Section
Kansas Department of Health & Environment
1000 SW Jackson, Suite 310
Topeka, KS 66612

**Re: Evergy – Jeffrey Energy Center
(ID No. 1490001) MATs Quarterly Compliance Reports**

Dear Ms. Ellis,

Evergy, Inc. is providing the quarterly compliance reports for our MATs affected units. Enclosed is the information specified in 40 CFR 63.10031(c), for units 1 through 3 at Jeffrey Energy Center.

If there are any questions or comments regarding this report, please contact the me at (816)-652-1163 or melissa.bybee@evergy.com.

A handwritten signature in black ink that reads 'Melissa Bybee'.

Melissa Bybee

Enclosures

Compliance Certification

National Emission Standards for Hazardous Air Pollutants:
Coal and Oil Fired Electric Utility Steam Generating Units
40 CFR Part 63 Subpart UUUUU

Reporting Period: 01/01/2025 To 03/31/2025

Company Name: Evergy, Inc.

Mailing Address: 818 South Kansas, PO Box 889

City: Topeka State: Kansas Zip: 66601

Facility Name: Jeffrey Energy Center Source ID: 1490001

Address: 25905 Jeffrey Road

City: St. Mary's State: Kansas Zip: 66536

Hazardous Air Pollutants monitored: Mercury

EU-BLR01 – 8,262 MMBtu/hr coal-fired EGU				
Pollutant	Emission Limit	Monitoring equipment manufacturer	Monitoring equipment model #	Date of latest CMS certification or audit
PM	0.03 lb/MMBtu	N/A	N/A	
SO ₂	0.2 lb/MMBtu	Teledyne	6444	10-04-2023
Hg	1.2 lb/TBtu	Clean Air	M80-1406-062-04	10-05-2023

EU-BLR02 – 8,262 MMBtu/hr coal-fired EGU				
Pollutant	Emission Limit	Monitoring equipment manufacturer	Monitoring equipment model #	Date of latest CMS certification or audit
PM	0.03 lb/MMBtu	N/A	N/A	
SO ₂	0.2 lb/MMBtu	Teledyne	6442	01-23-2025
Hg	1.2 lb/TBtu	Clean Air	M80-1406-063-04	01-28-2025

EU-BLR03 – 8,262 MMBtu/hr coal-fired EGU				
Pollutant	Emission Limit	Monitoring equipment manufacturer	Monitoring equipment model #	Date of latest CMS certification or audit
PM	0.03 lb/MMBtu	N/A	N/A	
SO ₂	0.2 lb/MMBtu	Teledyne	3505	10-22-2024
Hg	1.2 lb/TBtu	Clean Air	M80-1406-064-04	10-23-2024

Report the total fuel use by each affected source subject to an emission limit, for each calendar month within the semiannual reporting period, including, but not limited to, a description of the fuel, whether the fuel has received a non-waste determination by EPA or your basis for concluding that the fuel is not a waste, has any fuel received a non-waste determination by EPA if not, include the basis for including fuel is not a waste:

The only fuels burned are coal and diesel. No waste fuel is used.

Did you burn new fuel types during the reporting period?

No.

Include the date of the most recent tune-up for each EGU. The date of the tune-up is the date the tune-up provisions specified in §63.10021(e)(6) and (7) were completed.

Unit	Date of most recent tune-up
EU-BLR01	2/28/25
EU-BLR02	8/09/24
EU-BLR03	07/01/22

*the tune-ups were conducted as specified in 63.10021(e)(6) and (7)

Report the which definition of startup the units rely on.

All unit rely on startup definition 1

Emergency bypass information to be reported (LEE units only)?

No unit have Emergency bypass capabilities

Summary of performance test results, include documentation of any operating limits that were reestablished during the tests. (include tables for performance test info for each unit including each emission)

There were no operational changes since the last stack test that could increase emissions on any of the 3 units

Total operating time

Please see attachments

Emission data summary

Please see attachments

CMS performance summary

Please see attachments

Description of any changes in CMS, processes or controls

There were no changes to the CMS, processes or controls

Were there any deviations from any emission limit, work practice standard, or operating limit during the reporting period? If you have a deviation from any emission limit, work practice standard, or operating limit, you must also submit a brief description of the deviation, the duration of the deviation, emissions point identification, and the cause of the deviation. For each excess emissions occurring at an affected source where you are using a CMS to comply with that emission limit or operating limit, you must include the information required in §63.10(e)(3)(v) in the compliance report specified in section (c).

There were no deviations or excess emissions from the emission limit during the reporting period. However, there were deviations for monitoring downtime according to 40 CFR 63.10031(c)(9).

Please see attached.

I certify under the penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on information and belief formed after reasonable inquiry, including the person or persons who manage the system, or those persons directly responsible for gathering the information, the stated information in this document is true, accurate, and complete.

Name of Responsible Official: Daniel R. Wilkus

Title: Director – Environmental Services

Signature: _____

Date: 04/25/2025

Average Data

Plant: Jeffrey Energy Center

Interval: 1 Month

Type: Roll

Report Period: 01/01/2025 00:00 Through 03/31/2025 23:59

Time Online Criteria: 1 minute(s)

Source	BOILER01		BOILER02		BOILER03	
Parameter	CHEATIN (MMBTU/HR)	OHEATIN (MMBTU/HR)	CHEATIN (MMBTU/HR)	OHEATIN (MMBTU/HR)	CHEATIN (MMBTU/HR)	OHEATIN (MMBTU/HR)
Unit						
01/25	3,343,288.2	14,988.3	3,628,769.9	2,634.7	2,960,644.4	77,104.0
02/25	3,171,859.9	0.0	2,496,794.4	35,381.4	1,966,270.0	15,312.8
03/25	1,366,640.5	35,132.0	1,192,334.7	4,477.1	647,326.7	16,711.8
Average	2,627,262.9	16,706.8	2,439,299.7	14,164.4	1,858,080.4	36,376.2
Minimum	1,366,640.5	0.0	1,192,334.7	2,634.7	647,326.7	15,312.8
Maximum	3,343,288.2	35,132.0	3,628,769.9	35,381.4	2,960,644.4	77,104.0
Summation	7,881,788.6	50,120.3	7,317,899.0	42,493.2	5,574,241.1	109,128.6
Geometric Mean	2,438,076.7	19,909.9	2,210,616.8	7,473.1	1,556,148.3	27,022.0
Included Data Points	3	3	3	3	3	3
Total number of Data Points	3	3	3	3	3	3

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

*** = Suspect**

U = Startup

D = Shutdown

Operating Time Duration

Plant: Jeffrey Energy Center
Report Period: 01/01/2025 00:00 Through 03/31/2025 23:59
Time Online Criteria: 1 minute(s)

Source: BOILER01 (Boiler #1)

Parameter: UNITON (Unit on-line)

Interval: 001H

Incident ID	Start Date/Time	End Date/Time	Duration (hours)
1 *	01/01/2025 00:00	03/13/2025 16:59	1,719.82

Number of Events: 1

Total Duration: 1,719.82 hours

* Indicates duration incident could have additional data prior to the start date or following the end date.

Operating Time Duration

Plant: Jeffrey Energy Center
Report Period: 01/01/2025 00:00 Through 03/31/2025 23:59
Time Online Criteria: 1 minute(s)

Source: BOILER02 (Boiler #2)

Parameter: UNITON (Unit on-line)

Interval: 001H

Incident ID	Start Date/Time	End Date/Time	Duration (hours)
1 *	01/01/2025 00:00	01/16/2025 12:59	372.08
2	01/18/2025 01:00	02/01/2025 00:59	335.05
3	02/01/2025 23:00	02/22/2025 20:59	500.82
4 *	03/19/2025 16:00	03/31/2025 23:59	295.42

Number of Events: 4

Total Duration: 1,503.37 hours

* Indicates duration incident could have additional data prior to the start date or following the end date.

Operating Time Duration

Plant: Jeffrey Energy Center
Report Period: 01/01/2025 00:00 Through 03/31/2025 23:59
Time Online Criteria: 1 minute(s)

Source: BOILER03 (Boiler #3)

Parameter: UNITON (Unit on-line)

Interval: 001H

Incident ID	Start Date/Time	End Date/Time	Duration (hours)
1	01/02/2025 21:00	02/16/2025 20:59	1,078.17
2	02/18/2025 19:00	02/22/2025 00:59	76.38
3	03/13/2025 00:00	03/22/2025 01:59	216.17

Number of Events: 3

Total Duration: 1,370.72 hours

* Indicates duration incident could have additional data prior to the start date or following the end date.

CEMS Performance Summary

Company:	Jeffrey Energy Center	Report Period:	01/01/2025 00:00 Through 03/31/2025 23:59
Address:	25905 Jeffrey Road St. Marys, KS 66536	Total Source Time in Report Period:	1719.82 Hours
Source:	BOILER01	Time Online Criteria:	1 Minute(s)
Pollutant:	HG#/T30 (HG LB/TBTU excluding SU/SD for 30d avgs) LB/TBTU	Manufacturer:	Clean Air
Interval:	30 Day	Model Number:	MET 80
Limit:	1.200	Cert. Date:	10/17/22 15:00

Causes of CEMS Excess Emissions	Duration of Excess Emissions (Hours)	Percent of Operating Time
Startup / Shutdown	0.00	0.00
Other Known Causes	0.00	0.00
Process Problems	0.00	0.00
Cleaning / Soot Blowing.	0.00	0.00
Unknown Causes	0.00	0.00
Control Equipment Problems	0.00	0.00
Total duration of excess emission	0.00	0.00

Causes of CEMS Downtime	Duration of Downtime (Hours)	Percent of Operating Time
Monitor Equipment Malfunction	0.00	0.00
Unknown Causes	0.00	0.00
QA Calibrations	0.00	0.00
Other Known Causes	27.00	1.57
Non-Monitor Equipment Malfunction	0.00	0.00
Total duration of downtime	27.00	1.57

--

Downtime Events - Deviation

Plant: Jeffrey Energy Center

Report Period: 01/01/2025 00:00 Through 03/31/2025 23:59

Time Online Criteria: 1 minute(s)

Source: BOILER01

Parameter: HG#/T30

Interval: 001H

Incident ID	Start Date/Time	End Date/Time	Duration (hours)	Reason Code - Description
1	01/13/2025 07:00	01/13/2025 08:59	2.00	13 - Other Known Causes
2	01/14/2025 14:00	01/14/2025 18:59	5.00	13 - Other Known Causes
3	01/15/2025 13:00	01/15/2025 14:59	2.00	13 - Other Known Causes
4	01/15/2025 16:00	01/15/2025 16:59	1.00	13 - Other Known Causes
5	01/25/2025 14:00	01/25/2025 14:59	1.00	13 - Other Known Causes
6	02/06/2025 16:00	02/06/2025 17:59	2.00	13 - Other Known Causes
7	02/11/2025 10:00	02/11/2025 12:59	3.00	13 - Other Known Causes
8	02/16/2025 06:00	02/16/2025 12:59	7.00	13 - Other Known Causes
9	02/24/2025 15:00	02/24/2025 15:59	1.00	13 - Other Known Causes
11	03/13/2025 12:00	03/13/2025 12:59	1.00	13 - Other Known Causes

Number of Events: 10

Total Duration: 25.00 hours

* Indicates duration incident could have additional data prior to the start date or following the end date.

Report Version 4.0

Report Generated: 04/14/25 15:30

KCPL\mb9266

CEMS Performance Summary

Company:	Jeffrey Energy Center	Report Period:	01/01/2025 00:00 Through 03/31/2025 23:59
Address:	25905 Jeffrey Road St. Marys, KS 66536	Total Source Time in Report Period:	1718.00 Hours
Source:	BOILER01	Time Online Criteria:	1 Minute(s)
Pollutant:	SO2#MM30 (SO2#MM_M with startup/shutdown exclusion) LB/MMBTU	Manufacturer:	TELEDYNE ML
Interval:	30 Day	Model Number:	TML 50
Limit:	0.200	Cert. Date:	11/02/22 07:00

Causes of CEMS Excess Emissions	Duration of Excess Emissions (Hours)	Percent of Operating Time
Startup / Shutdown	0.00	0.00
Other Known Causes	0.00	0.00
Process Problems	0.00	0.00
Cleaning / Soot Blowing.	0.00	0.00
Unknown Causes	0.00	0.00
Control Equipment Problems	0.00	0.00
Total duration of excess emission	0.00	0.00

Causes of CEMS Downtime	Duration of Downtime (Hours)	Percent of Operating Time
Monitor Equipment Malfunction	0.00	0.00
Unknown Causes	0.00	0.00
QA Calibrations	0.00	0.00
Other Known Causes	25.00	1.46
Non-Monitor Equipment Malfunction	0.00	0.00
Total duration of downtime	25.00	1.46

--

Downtime Events - Deviation

Plant: Jeffrey Energy Center

Report Period: 01/01/2025 00:00 Through 03/31/2025 23:59

Time Online Criteria: 1 minute(s)

Source: BOILER01

Parameter: SO2#MM30

Interval: 001H

Incident ID	Start Date/Time	End Date/Time	Duration (hours)	Reason Code - Description
1	01/13/2025 07:00	01/13/2025 08:59	2.00	13 - Other Known Causes
2	01/14/2025 14:00	01/14/2025 18:59	5.00	13 - Other Known Causes
3	01/15/2025 13:00	01/15/2025 14:59	2.00	13 - Other Known Causes
4	01/15/2025 16:00	01/15/2025 16:59	1.00	13 - Other Known Causes
5	01/25/2025 14:00	01/25/2025 14:59	1.00	13 - Other Known Causes
6	02/06/2025 16:00	02/06/2025 17:59	2.00	13 - Other Known Causes
8	02/16/2025 06:00	02/16/2025 12:59	7.00	13 - Other Known Causes
9	02/24/2025 15:00	02/24/2025 15:59	1.00	13 - Other Known Causes
10	03/13/2025 12:00	03/13/2025 12:59	1.00	13 - Other Known Causes

Number of Events: 9

Total Duration: 22.00 hours

* Indicates duration incident could have additional data prior to the start date or following the end date.

Report Version 4.0

Report Generated: 04/14/25 15:38

KCPL\mb9266

CEMS Performance Summary

Company:	Jeffrey Energy Center	Report Period:	01/01/2025 00:00 Through 03/31/2025 23:59
Address:	25905 Jeffrey Road St. Marys, KS 66536	Total Source Time in Report Period:	1501.97 Hours
Source:	BOILER02	Time Online Criteria:	1 Minute(s)
Pollutant:	HG#/T30 (HG LB/TBTU excluding SU/SD for 30d avgs) LB/TBTU	Manufacturer:	Clean Air
Interval:	30 Day	Model Number:	MET 80
Limit:	1.200	Cert. Date:	10/18/22 15:00

Causes of CEMS Excess Emissions	Duration of Excess Emissions (Hours)	Percent of Operating Time
Startup / Shutdown	0.00	0.00
Other Known Causes	0.00	0.00
Process Problems	0.00	0.00
Cleaning / Soot Blowing.	0.00	0.00
Unknown Causes	0.00	0.00
Control Equipment Problems	0.00	0.00
Total duration of excess emission	0.00	0.00

Causes of CEMS Downtime	Duration of Downtime (Hours)	Percent of Operating Time
Monitor Equipment Malfunction	0.00	0.00
Unknown Causes	0.00	0.00
QA Calibrations	0.00	0.00
Other Known Causes	17.00	1.13
Non-Monitor Equipment Malfunction	0.00	0.00
Total duration of downtime	17.00	1.13

--

Downtime Events - Deviation

Plant: Jeffrey Energy Center

Report Period: 01/01/2025 00:00 Through 03/31/2025 23:59

Time Online Criteria: 1 minute(s)

Source: BOILER02

Parameter: HG#/T30

Interval: 001H

Incident ID	Start Date/Time	End Date/Time	Duration (hours)	Reason Code - Description
1	01/02/2025 20:00	01/02/2025 21:59	2.00	13 - Other Known Causes
2	01/04/2025 05:00	01/04/2025 07:59	3.00	13 - Other Known Causes
3	01/15/2025 11:00	01/15/2025 11:59	1.00	13 - Other Known Causes
4	01/28/2025 09:00	01/28/2025 14:59	6.00	13 - Other Known Causes
5	02/06/2025 18:00	02/06/2025 18:59	1.00	13 - Other Known Causes
6	02/11/2025 13:00	02/11/2025 13:59	1.00	13 - Other Known Causes
7	02/13/2025 05:00	02/13/2025 06:59	2.00	13 - Other Known Causes
8	03/20/2025 07:00	03/20/2025 07:59	1.00	13 - Other Known Causes

Number of Events: 8

Total Duration: 17.00 hours

* Indicates duration incident could have additional data prior to the start date or following the end date.

Report Version 4.0

Report Generated: 04/14/25 16:30

KCPL\mb9266

CEMS Performance Summary

Company: Jeffrey Energy Center

Address: 25905 Jeffrey Road
St. Marys, KS 66536

Source: BOILER02

Pollutant: SO2#MM30 (SO2#MM_M with startup/shutdown exclusion) LB/MMBTU

Interval: 30 Day

Limit: 0.200

Report Period: 01/01/2025 00:00 Through 03/31/2025 23:59

Total Source Time in Report Period: 1490.00 Hours

Time Online Criteria: 1 Minute(s)

Manufacturer: TELEDYNE ML

Model Number: TML 50

Cert. Date: 11/01/22 08:00

Causes of CEMS Excess Emissions	Duration of Excess Emissions (Hours)	Percent of Operating Time
Startup / Shutdown	0.00	0.00
Other Known Causes	0.00	0.00
Process Problems	0.00	0.00
Cleaning / Soot Blowing.	0.00	0.00
Unknown Causes	0.00	0.00
Control Equipment Problems	0.00	0.00
Total duration of excess emission	0.00	0.00

Causes of CEMS Downtime	Duration of Downtime (Hours)	Percent of Operating Time
Monitor Equipment Malfunction	0.00	0.00
Unknown Causes	0.00	0.00
QA Calibrations	1.00	0.07
Other Known Causes	31.00	2.08
Non-Monitor Equipment Malfunction	0.00	0.00
Total duration of downtime	32.00	2.15

Downtime Events - Duration

Plant: Jeffrey Energy Center
Report Period: 01/01/2025 00:00 Through 03/31/2025 23:59
Time Online Criteria: 1 minute(s)

Source: BOILER02
Parameter: SO2#MM30
Interval: 001H

Incident ID	Start Date/Time	End Date/Time	Duration (hours)	Reason Code - Description
1	01/02/2025 20:00	01/02/2025 21:59	2.00	13 - Other Known Causes
2	01/04/2025 05:00	01/04/2025 07:59	3.00	13 - Other Known Causes
3	01/15/2025 11:00	01/15/2025 11:59	1.00	13 - Other Known Causes
4	01/15/2025 15:00	01/16/2025 11:59	21.00	13 - Other Known Causes
5	02/06/2025 18:00	02/06/2025 18:59	1.00	13 - Other Known Causes
6	02/11/2025 13:00	02/11/2025 13:59	1.00	13 - Other Known Causes
7	02/13/2025 05:00	02/13/2025 06:59	2.00	13 - Other Known Causes

Number of Events: 7
Total Duration: 31.00 hours

* Indicates duration incident could have additional data prior to the start date or following the end date.

CEMS Performance Summary

Company: Jeffrey Energy Center
Address: 25905 Jeffrey Road
 St. Marys, KS 66536
Source: BOILER03
Pollutant: HG#/T30 (HG LB/TBTU excluding SU/SD for
 30d avgs) LB/TBTU
Interval: 30 Day
Limit: 1.200

Report Period: 01/01/2025 00:00 Through 03/31/2025 23:59
Total Source Time in Report Period: 1363.92 Hours
Time Online Criteria: 1 Minute(s)
Manufacturer: Clean Air
Model Number: Met 80
Cert. Date: 01/01/24 00:00

Causes of CEMS Excess Emissions	Duration of Excess Emissions (Hours)	Percent of Operating Time
Startup / Shutdown	0.00	0.00
Other Known Causes	0.00	0.00
Process Problems	0.00	0.00
Cleaning / Soot Blowing.	0.00	0.00
Unknown Causes	0.00	0.00
Control Equipment Problems	0.00	0.00
Total duration of excess emission	0.00	0.00

Causes of CEMS Downtime	Duration of Downtime (Hours)	Percent of Operating Time
Monitor Equipment Malfunction	67.00	4.91
Unknown Causes	0.00	0.00
QA Calibrations	0.00	0.00
Other Known Causes	0.00	0.00
Non-Monitor Equipment Malfunction	0.00	0.00
Total duration of downtime	67.00	4.91

Downtime Events - Deviation

Plant: Jeffrey Energy Center

Report Period: 01/01/2025 00:00 Through 03/31/2025 23:59

Time Online Criteria: 1 minute(s)

Source: BOILER03

Parameter: HG#/T30

Interval: 001H

Incident ID	Start Date/Time	End Date/Time	Duration (hours)	Reason Code - Description
1	01/03/2025 21:00	01/03/2025 21:59	1.00	10 - Monitor Equipment Malfunction
2	01/09/2025 05:00	01/09/2025 09:59	5.00	10 - Monitor Equipment Malfunction
3	01/16/2025 09:00	01/16/2025 09:59	1.00	10 - Monitor Equipment Malfunction
4	02/01/2025 11:00	02/01/2025 11:59	1.00	10 - Monitor Equipment Malfunction
5	02/14/2025 05:00	02/14/2025 07:59	3.00	10 - Monitor Equipment Malfunction
6	02/14/2025 13:00	02/14/2025 14:59	2.00	10 - Monitor Equipment Malfunction
7	02/14/2025 16:00	02/16/2025 19:59	52.00	10 - Monitor Equipment Malfunction
8	02/19/2025 08:00	02/19/2025 08:59	1.00	10 - Monitor Equipment Malfunction
9	03/19/2025 12:00	03/19/2025 12:59	1.00	10 - Monitor Equipment Malfunction

Number of Events: 9

Total Duration: 67.00 hours

* Indicates duration incident could have additional data prior to the start date or following the end date.

Report Version 4.0

Report Generated: 04/14/25 16:42

KCPL\mb9266

CEMS Performance Summary

Company:	Jeffrey Energy Center	Report Period:	01/01/2025 00:00 Through 03/31/2025 23:59
Address:	25905 Jeffrey Road St. Marys, KS 66536	Total Source Time in Report Period:	1342.00 Hours
Source:	BOILER03	Time Online Criteria:	1 Minute(s)
Pollutant:	SO2#MM30 (SO2#MM_M with startup/shutdown exclusion) LB/MMBTU	Manufacturer:	TELEDYNE ML
Interval:	30 Day	Model Number:	TML 50
Limit:	0.200	Cert. Date:	01/01/24 00:00

Causes of CEMS Excess Emissions	Duration of Excess Emissions (Hours)	Percent of Operating Time
Startup / Shutdown	0.00	0.00
Other Known Causes	0.00	0.00
Process Problems	0.00	0.00
Cleaning / Soot Blowing.	0.00	0.00
Unknown Causes	0.00	0.00
Control Equipment Problems	0.00	0.00
Total duration of excess emission	0.00	0.00

Causes of CEMS Downtime	Duration of Downtime (Hours)	Percent of Operating Time
Monitor Equipment Malfunction	67.00	4.99
Unknown Causes	0.00	0.00
QA Calibrations	0.00	0.00
Other Known Causes	0.00	0.00
Non-Monitor Equipment Malfunction	0.00	0.00
Total duration of downtime	67.00	4.99

--

Downtime Events - Deviation

Plant: Jeffrey Energy Center

Report Period: 01/01/2025 00:00 Through 03/31/2025 23:59

Time Online Criteria: 1 minute(s)

Source: BOILER03

Parameter: SO2#MM30

Interval: 001H

Incident ID	Start Date/Time	End Date/Time	Duration (hours)	Reason Code - Description
1	01/03/2025 16:00	01/03/2025 19:59	4.00	10 - Monitor Equipment Malfunction
2	01/03/2025 21:00	01/03/2025 21:59	1.00	10 - Monitor Equipment Malfunction
3	01/09/2025 06:00	01/09/2025 08:59	3.00	10 - Monitor Equipment Malfunction
4	01/16/2025 09:00	01/16/2025 09:59	1.00	10 - Monitor Equipment Malfunction
5	02/01/2025 11:00	02/01/2025 11:59	1.00	10 - Monitor Equipment Malfunction
6	02/14/2025 05:00	02/14/2025 07:59	3.00	10 - Monitor Equipment Malfunction
7	02/14/2025 14:00	02/16/2025 19:59	54.00	10 - Monitor Equipment Malfunction

Number of Events: 7

Total Duration: 67.00 hours

* Indicates duration incident could have additional data prior to the start date or following the end date.

Report Version 4.0

Report Generated: 04/14/25 16:16

KCPL\mb9266



EPA Method 5 : Determination of Particulate Emissions from Stationary Sources
Jeffrey Energy Center - Unit 1

Field Data

	Run #1	Run #2	Run #3	Averages
Date:	5/24/2022	5/24/2022	5/24/2022	
Start time:	9:00	11:35	14:11	
Stop time:	11:21	13:57	16:33	
Filterable PM (lb/MMBtu):	0.0029	0.0021	0.0039	0.00294

Permit Limit	0.030	PASS
--------------	-------	------

MATS LEE Status	
0.015	YES



EPA Method 5 : Determination of Particulate Emissions from Stationary Sources
Jeffrey Energy Center - Unit 2

Field Data

	Run #1	Run #2	Run #3	Averages
Date:	5/26/2022	5/26/2022	5/26/2022	
Start time:	10:15	12:50	15:30	
Stop time:	12:33	15:14	17:52	
Filterable PM (lb/MMBtu):	0.0062	0.0042	0.0043	0.00490

Permit Limit	0.030	PASS
--------------	-------	------

MATS LEE Status	
0.015	YES



EPA Method 5 : Determination of Particulate Emissions from Stationary Sources
Jeffrey Energy Center - Unit 3

Field Data

	Run #1	Run #2	Run #3	Averages
Date:	6/7/2022	6/7/2022	6/7/2022	
Start time:	8:20	11:05	13:45	
Stop time:	10:34	13:21	16:00	
Filterable PM (lb/MMBtu):	0.0045	0.0060	0.0038	0.00479

Permit Limit	0.030	PASS
--------------	-------	------

MATS LEE Status	0.015	YES
-----------------	-------	-----