

National Emission Standards for Hazardous Air Pollutants: Coal and Oil-Fired Electric Utility Steam Generating Units (40 CFR 63, Subpart UUUUU)

Holcomb Steam Generating Unit 1 Quarterly Compliance Report

Reporting Period:
January 01, 2025 through March 31, 2025

This report provides the required information for the Quarterly Compliance Report specified in §63.10031 and Appendix E of 40 CFR Part 63, Subpart UUUUU — National Emission Standards for Hazardous Air Pollutants: Coal and Oil-Fired Electric Utility Steam Generating Units (also known as the Mercury and Air Toxics Standards, or “MATS”).

SECTION I. FACILITY INFORMATION

Responsible Official's Name/Title

Emily Vsetecka / Manager, Environmental & Laboratory Services

Street Address

2440 Holcomb Lane

City

Holcomb

State

KS

ZIP Code

67851

Facility Name

Holcomb Station

Facility Street Address

2440 Holcomb Lane

Facility City

Holcomb

State

KS

ZIP Code

67851

Facility Local Contact Name

Justine Sullivan

Title

Environmental Compliance Supervisor

Phone

620-277-4783


Pollutant/ Parameter	Selected Emission Standard	Averaging Period	Selected Compliance Method	Emissions Averaging	Startup Definition
Mercury (Hg)	1.2 lb/TBtu	30-Day Rolling	☐ HG CEMS ☒ HG ST	☐ Yes ☒ No	☒ #1 ☐ #2
Filterable Particulate Matter (fPM)	0.030 lb/MMBtu	N/A	☒ LEE ☐ PM QST	☐ Yes ☒ No	☒ #1 ☐ #2
Hydrogen Chloride (HCl)	0.0020 lb/MMBtu	N/A	☒ LEE ☐ HCL QST	☐ Yes ☒ No	☒ #1 ☐ #2

Based upon information and belief formed after a reasonable inquiry, I, as a responsible official of the above-mentioned facility, certify the information contained in this report is accurate and true to the best of my knowledge.

Name of Responsible Official Title Date (mm/dd/yyyy)

Emily Vsetecka	Manager, Environmental & Laboratory Services	04/28/2025
----------------	--	------------

Signature of Responsible Official

Signed by:  9074B851CAAC492

SECTION II. ROOT DATA ELEMENTS – 40 CFR 63, SUBPART UUUUU, APPENDIX E (2)

2.1 ORIS Code	108
2.2 Facility Name	Holcomb Station
2.3 Facility Registry Identifier	110009570259
2.4 Title 40 Part	63
2.5 Applicable Subpart	UUUUU
2.6 Calendar Year	2025
2.7 Calendar Quarter	1
2.8 Submission Comment	

SECTION III. PERFORMANCE STACK TEST SUMMARY – 40 CFR 63, SUBPART UUUUU, APPENDIX E (3)

3.1 Parameter	HCl
3.2 Test Location ID	Unit 1 Stack (SGU1)
3.3 Test Number	N/A – Performance stack test was not performed during reporting period
3.4 Test Begin (date, hour, minute)	07/16/2024 08:20
3.5 Test End (date, hour, minute)	07/16/2024 15:46
3.6 Timing of Test	☒ On-Schedule ☐ Late
3.7 Averaging Plan Indicator	N/A
3.8 Averaging Group ID	N/A
3.9 EPA Test Method Code	Method 26A
3.10 Emission Limit (units)	0.0020 lb/mmBtu
3.11 Average Pollutant Emission Rate	≤ 0.0001 lb/MMBtu
3.12 LEE Indicator	☒ HCl ☐ fPM
3.13 LEE Basis	63.10005(h)(1)(i) and (h)(2)
3.14 Submission Comment	Initially qualified for LEE status on 02/13/2019

3.1 Parameter	fPM
3.2 Test Location ID	Unit 1 Stack (SGU1)
3.3 Test Number	N/A – Performance stack test was not performed during reporting period
3.4 Test Begin (date, hour, minute)	07/16/2024 08:20
3.5 Test End (date, hour, minute)	07/16/2024 16:10
3.6 Timing of Test	☒ On-Schedule ☐ Late
3.7 Averaging Plan Indicator	N/A
3.8 Averaging Group ID	N/A
3.9 EPA Test Method Code	“MATS Modified” Method 5
3.10 Emission Limit (units)	0.030 lb/MMBtu
3.11 Average Pollutant Emission Rate	0.001 lb/MMBtu
3.12 LEE Indicator	☐ HCl ☒ fPM
3.13 LEE Basis	63.10005(h)(1)(i) and (h)(2)
3.14 Submission Comment	Initially qualified for LEE status on 02/13/2019

SECTION IV. OPERATING LIMIT DATA – 40 CFR 63, SUBPART UUUUU, APPENDIX E (4)

N/A- applies to PM CPMS only.

SECTION V. PERFORMANCE TEST RUN DATA – 40 CFR 63, SUBPART UUUUU, APPENDIX E (5)

N/A – Performance stack test was not performed during the reporting period.

5.1 Run Number	5.2 Run Begin (date, hour, minute)	5.3 Run End (date, hour, and minute)	5.4 Pollutant Concentrati on (units)	5.5 Emission Rate (units)	5.6 EPA Test Method 19 Equation	5.7 Total Sampling Time	5.8 Total Sample Volume (units)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

SECTION VI. CONVERSION PARAMETERS – 40 CFR 63, SUBPART UUUUU, APPENDIX E (6)

6.1 Parameter Type	6.2 Parameter Source	6.3 Parameter Value (units)
Performance Test CO ₂	N/A – Performance stack test was not performed during the reporting period	N/A – Performance stack test was not performed during the reporting period
Performance Test Flow Rate	N/A – Performance stack test was not performed during the reporting period	N/A – Performance stack test was not performed during the reporting period
Performance Test Moisture Content	N/A – Performance stack test was not performed during the reporting period	N/A – Performance stack test was not performed during the reporting period
Continuous CO ₂	CEMS	Refer to hourly XML output in ECMPS emissions file (%)
Continuous Moisture Content	Site-specific Default Moisture	Refer to hourly XML output in ECMPS emissions file (%)
F-Factor	Default F _c fuel factor for subbituminous coal	Refer to hourly XML output in ECMPS emissions file (scf CO ₂ /MMBtu)

SECTION VII. REFERENCE METHOD QUALITY ASSURANCE PARAMETERS – 40 CFR 63, SUBPART UUUUU, APPENDIX E (7)

N/A – Performance stack test was not performed during the reporting period.

7.1 Parameter Type	7.2 Parameter Source	7.3 Parameter Value (units)
N/A	N/A	N/A

SECTION VIII. AVERAGING GROUP CONFIGURATION – 40 CFR 63, SUBPART UUUUU, APPENDIX E (8)

N/A – Emission unit is not part of an averaging group.

SECTION IX. COMPLIANCE AVERAGES – 40 CFR 63, SUBPART UUUUU, APPENDIX E (9)

9.1 Unit ID	Unit 1 Stack (SGU1)
9.2 Averaging Group ID	N/A
9.3 Parameter Being Averaged	Hg
9.4 Date	See Stack Vision Report in Appendix
9.5 Average Type	30 Boiler Operating Day Rolling Average
9.6 Units of Measure	lb/TBtu
9.7 Average Value	See Stack Vision Report in Appendix
9.8 Comment Field	N/A

SECTION X. UNIT INFORMATION – 40 CFR 63, SUBPART UUUUU, APPENDIX E (10)

10.1 Unit ID	Unit 1 Stack (SGU1)
10.2 Date of Last Tune-up	07/11/2024
10.3 Emergency Bypass Information	N/A

SECTION XI. FUEL USAGE INFORMATION – 40 CFR 63, SUBPART UUUUU, APPENDIX E (11)

11.1 Calendar Month:	See table below		
11.2 Permitted Fuel Types:	Primary Fuel: Sub-Bituminous Coal Secondary Fuel: PNG Bituminous and/or subbituminous coal is considered a traditional fuel, and, therefore, exempt from the definition of solid waste provided in the Resource Recovery and Conservation Act (RCRA).		
11.3 Total Fuel Use for Each Calendar Month:	Month	Coal Use (tons)	PNG Use (MCF)
	Jan – 2025	87,888.30	12,250.00
	Feb – 2025	97,040.50	6,302.00
	Mar – 2025	78,955.70	13,255.00
11.4 New Fuel(s) Burned During Reporting Period:	None		
11.5 Date of Performance Testing Using the New Fuel(s):	N/A		

SECTION XII. MALFUNCTION INFORMATION – 40 CFR 63, SUBPART UUUUU, APPENDIX E (12)

12.1	12.2	12.3	12.4
Event Begin (date, hour)	Event End (date, hour)	Malfunction Description	Corrective Action
None	None	None	None

SECTION XIII. DEVIATIONS AND MONITOR DOWNTIME – 40 CFR 63, SUBPART UUUUU, APPENDIX E (13)

13.1 Unit ID	13.2 Nature of Deviation	13.3 Description of Deviation	13.3.3 Monitored Parameter	13.3.3 Total Operating Time (hours)	13.3.3 Total Downtime (hours)	13.4 Corrective Action
Unit 1 Stack (SGU1)	Monitoring Downtime	Monitoring System Malfunction (Downtime and Deviation)	CO ₂	1,968	3	DAHS Firmware Update
Unit 1 Stack (SGU1)	Monitoring Downtime	Routine Maintenance (Downtime)	HGC	1,968	1	Quarterly MET-80 Maintenance
*Unit 1 Stack (SGU1)	Monitoring Downtime	Monitoring System Malfunction (Downtime and Deviation)	HGC	1,968	16	DAHS Firmware Update

* These hours are listed in the hourly XML output file in ECMPS as valid. Although these hours are listed as valid, Sunflower experienced 16 hours in which the Hg MET-80 Sorbent Trap System was not sampling. These hours are being listed in the quarterly MATS report as monitoring downtime and a deviation.

Deviations: No periods were recorded in excess to the emission limitation and 19 hours of downtime were considered a deviation under §63.10020(d). These hours do not necessarily reflect violations of the Mercury and Air Toxic Standards (MATS) rule.

SECTION XIV-XXXI. 40 CFR 63, Subpart UUUUU, Appendix E sections 14 through 31 are not applicable due to no performance testing being performed during the reporting period.

SECTION XXXII. APPENDIX

MATS 30 Day Rolling Average

Plant: HOLCOMB

Report Period: 01/01/2025 Through 03/31/2025

Source: H1_STACK Parameter: HG#/T_M

Date	30-Day Avg
1/1/2025	5.1E-01
1/2/2025	5.0E-01
1/3/2025	5.0E-01
1/4/2025	4.9E-01
1/5/2025	4.9E-01
1/6/2025	4.8E-01
1/7/2025	4.7E-01
1/8/2025	N/A
1/9/2025	N/A
1/10/2025	N/A
1/11/2025	N/A
1/12/2025	4.8E-01
1/13/2025	4.7E-01
1/14/2025	4.7E-01
1/15/2025	4.7E-01
1/16/2025	4.6E-01
1/17/2025	4.6E-01
1/18/2025	4.6E-01
1/19/2025	4.6E-01
1/20/2025	4.5E-01
1/21/2025	4.4E-01
1/22/2025	4.3E-01
1/23/2025	4.2E-01
1/24/2025	4.2E-01
1/25/2025	4.0E-01
1/26/2025	4.0E-01
1/27/2025	4.1E-01
1/28/2025	4.1E-01
1/29/2025	4.1E-01
1/30/2025	4.1E-01
1/31/2025	4.1E-01
2/1/2025	4.1E-01
2/2/2025	4.1E-01
2/3/2025	4.1E-01
2/4/2025	4.1E-01
2/5/2025	4.0E-01
2/6/2025	4.0E-01
2/7/2025	4.0E-01
2/8/2025	3.9E-01
2/9/2025	3.9E-01
2/10/2025	3.8E-01

Value = Offline Data**Value* = Average represents a building 30D Average****Value = Exceedance**

Report Generated: 04/21/25 15:14

Report Version 5.2

HLS-DMZ_INT_CEM\\reportuser

MATS 30 Day Rolling Average

Plant: HOLCOMB

Report Period: 01/01/2025 Through 03/31/2025

Source: H1_STACK Parameter: HG#/T_M

2/11/2025	3.6E-01
2/12/2025	3.6E-01
2/13/2025	3.5E-01
2/14/2025	3.5E-01
2/15/2025	3.5E-01
2/16/2025	3.4E-01
2/17/2025	3.4E-01
2/18/2025	3.3E-01
2/19/2025	3.3E-01
2/20/2025	3.3E-01
2/21/2025	3.3E-01
2/22/2025	3.2E-01
2/23/2025	3.2E-01
2/24/2025	3.2E-01
2/25/2025	3.2E-01
2/26/2025	3.2E-01
2/27/2025	3.2E-01
2/28/2025	3.3E-01
3/1/2025	3.3E-01
3/2/2025	3.3E-01
3/3/2025	3.3E-01
3/4/2025	3.4E-01
3/5/2025	3.4E-01
3/6/2025	3.5E-01
3/7/2025	3.5E-01
3/8/2025	3.6E-01
3/9/2025	3.6E-01
3/10/2025	3.7E-01
3/11/2025	3.8E-01
3/12/2025	3.8E-01
3/13/2025	3.9E-01
3/14/2025	N/A
3/15/2025	4.1E-01
3/16/2025	4.2E-01
3/17/2025	4.3E-01
3/18/2025	N/A
3/19/2025	4.4E-01
3/20/2025	4.4E-01
3/21/2025	4.5E-01
3/22/2025	4.5E-01
3/23/2025	4.5E-01
3/24/2025	4.5E-01

Value = Offline Data

Value* = Average represents a building 30D Average

Value = Exceedance

Report Generated: 04/21/25 15:14

Report Version 5.2

HLS-DMZ_INT_CEM\\reportuser

MATS 30 Day Rolling Average

Plant: HOLCOMB

Report Period: 01/01/2025 Through 03/31/2025

Source: H1_STACK Parameter: HG#/T_M

3/25/2025	4.6E-01
3/26/2025	4.6E-01
3/27/2025	4.7E-01
3/28/2025	4.8E-01
3/29/2025	4.9E-01
3/30/2025	4.9E-01
3/31/2025	5.0E-01

Value = Offline Data

Value* = Average represents a building 30D Average

Value = Exceedance

Report Generated: 04/21/25 15:14

Report Version 5.2

HLS-DMZ_INT_CEM\\reportuser