

Chicago Park District Water Fountain Testing Results

Ensuring the health and safety of all park patrons and staff is a top priority of the Park District. In light of recent national and local concern regarding lead in water, the Park District initiated a comprehensive testing program to test all indoor and outdoor water fountain, as well as kitchen sinks. The Park District has completed this sampling with the results posted below.

<u>Park</u>	<u>Sample Location</u>	<u>Result (in parts per billion)</u>
Abbott		
	Indoor	
	Fitness Center	<0.120 U
	Main Lobby	0.579 J
	Outdoor	
	Fountain 1 High	<0.120 U
	Fountain 1 Low	<0.120 U
	Fountain 2	<0.120 U
	Fountain 3	0.245 J
	Fountain 4	4.48 J
Ada		
	Indoor	
	Main Lobby	<2.0 U
	Kitchen Sink	<2.0 U
	Outdoor	
	Fountain 1	11.7
	Fountain 2	<0.120 U
	Fountain 3	9.63
	Fountain 4	7.57
Adams (George & Adelle)		
	Indoor	
	Hallway	4.34 J
	Kitchen Sink	5.3
	Outdoor	
	Fountain 1	<2.0 U
	Fountain 2 High*	75
	Fountain 2 Low*	75
Adams (John)		
	Indoor	
	Hallway Outside Washroom	4.02 J
Addam/Medil		
	Outdoor	
	Fountain 1	7.5

Addams Memorial (Jane)		
Outdoor		
Fountain 1		<2.0 U
Aiello		
Outdoor		
Fountain 1 High		2.9 J
Fountain 1 Middle		2.88 J
Fountain 1 Low		3.3 J
Algonquin		
Outdoor		
Fountain 1 High		6.64
Fountain 1 Middle		6.65
Fountain 1 Low		6.67
Altgeld		
Indoor		
Main Lobby - High		4.91 J
Main Lobby - Low		2.31 J
Basement Fitness Center		0.35 J
Outdoor		
Fountain 2		2.1 J
Fountain 3 High		2.01 J
Fountain 3 Low		<0.120 U
Amundsen		
Indoor		
Club Room		0.204 J
Men's Locker Room		2.01 J
Women's Locker Room*		53.1
Outdoor		
Fountain 1*		156
Anderson (Fred)		
Outdoor		
Fountain 1 High		<2.0 U
Fountain 1 Low		<2.0 U
Fountain 2 High		<2.0 U
Fountain 2 Low		<2.0 U
Fountain 3 High		<2.0 U
Fountain 3 Low		<2.0 U
Anderson (Louis)		
Indoor		
Lobby		1.29 J

Outdoor		
Fountain 1*		20
Andersonville		
Outdoor		
Fountain 1*		72.7
Arcade		
Outdoor		
Fountain 1*		16.6
Archer		
Indoor		
Men's Restroom		0.845 J
Women's Restroom		0.771 J
Main Lobby		0.561 J
Kitchen Sink		<2.0 U
Outdoor		
Fountain 1 High		0.731 J
Fountain 1 Low		1.2 J
Fountain 2*		38
Fountain 3 High		1.5 J
Fountain 3 Middle		1.53 J
Fountain 3 Low		1.57 J
Fountain 4		1.18 J
Armour Square		
Indoor		
Main Lobby		0.597 J
Girl's Gym Hallway		<0.120 U
Game Room		<0.120 U
Kitchen Sink		<2.0 U
Outdoor		
Fountain 1		0.167 J
Fountain 2 High		1.53 J
Fountain 2 Middle		3.81 J
Fountain 2 Low		3.37 J
Fountain 3 High		2.51 J
Fountain 3 Low		1.63 J
Fountain 4 High		6.44
Fountain 4 Low		6.25
Armstrong		
Outdoor		
Fountain 1		<2.0 U
Ashe Beach		

Outdoor		
Fountain 1 High		<2.0 U
Fountain 1 Middle		<2.0 U
Fountain 1 Low		<2.0 U
Ashmore		
Outdoor		
Fountain 1*		32.9
Aspen		
Outdoor		
Fountain 1 High		<2.0 U
Fountain 1 Low		2.2
Aster		
Outdoor		
Fountain 1		9.7
Athletic Field		
Indoor		
Main Lobby		2.25 J
Outdoor		
Fountain 1*		47.5
Fountain 2 High		<0.120 U
Fountain 2 Middle		<0.120 U
Fountain 2 Low		<0.120 U
Augusta		
Indoor		
Lobby		10.4
Outdoor		
Fountain 1 High		0.769 J
Fountain 1 Middle		0.769 J
Fountain 1 Low		0.789 J
Austin-Foster		
Outdoor		
Fountain 1 High*		20.6
Fountain 1 Low*		51
Austin Town Hall		
Indoor		
Main Lobby		<0.120 U
2nd Floor Outside Gym		1.16 J
2nd Floor Inside Gym		1.82 J
Pool Area		<0.120 U
Basement Girl's Locker Room		0.365 J

Basement Boy's Locker Room	0.233 J
Preschool	<0.120 U
Preschool Sink	0.176 J
Outdoor	
Fountain 1	2.41 J

Avalon

Indoor	
Main Lobby	0.274 J
Near Kitchen	2.52 J
Girl's Locker Room	1.65 J
Boy's Locker Room	5.01
Outdoor	
Fountain 1	7.9
Fountain 2 High	<2.0 U
Fountain 2 Low	2.7
Fountain 3 High*	1800
Fountain 3 Low*	1200
Fountain 4 High*	270
Fountain 4 Low*	400
Fountain 5 High*	150
Fountain 5 Low*	170
Fountain 6 High*	8.2
Fountain 6 Low*	15

Avondale

Indoor	
Main Lobby	0.909 J
Outdoor	
Fountain 1	0.457 J
Fountain 2	9.52

Barnard

Outdoor	
Fountain 1	14
Fountain 2 High*	6.11
Fountain 2 Low*	15.5

Barrett

Outdoor	
Fountain 1	2.6

Bartelme

Outdoor	
Fountain 1 High	<2.0 U
Fountain 1 Middle	<2.0 U
Fountain 1 Low	<2.0 U

	Fountain 2 High	<2.0 U
	Fountain 2 Dog	<2.0 U
Bauler		
	Outdoor	
	Fountain 1*	38
Beehive		
	Outdoor	
	Fountain 1 High	7.41
	Fountain 1 Low	6.14
Bell		
	Indoor	
	Game Room	2.82 J
	Outdoor	
	Fountain 1*	16.6
Berger Cultural Ctr Annex		
	Indoor	
	Basement Hallway	0.239 J
Berger		
	Outdoor	
	Fountain 1 High	<2.0 U
	Fountain 1 Middle	<2.0 U
	Fountain 1 Low	<2.0 U
Bessemer		
	Indoor	
	North Entrance Lobby	0.342 J
	South Entrance Lobby	0.24 J
	Outdoor	
	Fountain 1	<2.0 U
	Fountain 2	<2.0 U
	Fountain 3	<2.0 U
	Fountain 4	6.4
	Fountain 5	<2.0 U
Beverly		
	Indoor	
	Kitchen Sink	3.3 J
	Outdoor	
	Fountain 1	13.9
	Fountain 2 High	0.519 J
	Fountain 2 Low	0.523 J
	Fountain 2 Dog	0.549 J

	Fountain 3*	91.4
Birch		
	Outdoor	
	Fountain 1 High	<2.0 U
	Fountain 1 Low	<2.0 U
Bixler		
	Outdoor	
	Fountain 1 High	0.176 J
	Fountain 1 Low	0.185 J
Blackhawk		
	Indoor	
	Women's Restroom	0.263 J
	Outside Preschool Room	0.193 J
	Outdoor	
	Fountain 1*	22.1
	Fountain 2*	23.3
Blackwelder		
	Outdoor	
	Fountain 1 High	0.299 J
	Fountain 1 Middle	0.311 J
	Fountain 1 Low	0.361 J
Bogan		
	Indoor	
	Outside Office	2.11 J
	Outdoor	
	Fountain 2	0.662 J
	Fountain 3 High	2.69 J
	Fountain 3 Low	3.09 J
Bosley		
	Outdoor	
	Fountain 1	3.11 J
Boswell		
	Outdoor	
	Fountain 1 High*	17.8
	Fountain 1 Low*	17.7
Brainerd		
	Indoor	
	Main Lobby	0.747 J
	Women's Locker Room	1.65 J

Men's Locker Room	3.39 J
Outdoor	
Fountain 1 High	<0.120 U
Fountain 1 Middle	<0.120 U
Fountain 1 Low	<0.120 U
Fountain 3	5.31
Fountain 4	0.694 J
Bradley	
Outdoor	
Fountain 2	3
Fountain 3*	17
Brands	
Indoor	
Main Lobby	1.62 J
Men's Locker Room	9.77
Women's Locker Room	2.44 J
Outdoor	
Fountain 2 High	2.11 J
Fountain 2 Middle	2.19 J
Fountain 2 Low	2.08 J
Fountain 3*	27.8
Brighton	
Outdoor	
Fountain 1 High	12
Fountain 1 Middle	13
Fountain 1 Low	11.8
Broadway Armory	
Indoor	
Main Lobby	<0.120 U
East Side Vestibule	0.189 J
Kitchen Sink	6.9
Bromann	
Outdoor	
Fountain 1 High	<2.0 U
Fountain 1 Middle	<2.0 U
Fountain 1 Low	<2.0 U
Bronco Billy	
Outdoor	
Fountain 1 High	4.1
Fountain 1 Low	<2.0 U

Brooks (Gwendolyn)

Outdoor

Fountain 1 High	8.1
Fountain 1 Low	8.7

Brooks (Oscar)

Indoor

North Foyer	0.617 J
2nd Floor Club Room	0.793 J

Outdoor

Fountain 1 High*	145
Fountain 1 Low*	83
Fountain 2*	46.5

Brown Memorial

Outdoor

Fountain 1*	41.6
Fountain 2*	76.2

Brynford

Outdoor

Fountain 1 High	3.91
Fountain 1 Low	3.96

Burnham

Outdoor

Fountain 1 High	<2.0 U
Fountain 1 Low	<2.0 U
Fountain 2 High	<2.0 U
Fountain 2 Middle	<2.0 U
Fountain 2 Low	<2.0 U
Fountain 3 High	2.4
Fountain 3 Low	<2.0 U
Fountain 4 High	<2.0 U
Fountain 4 Low	<2.0 U
Fountain 5 High	<2.0 U
Fountain 5 Low	<2.0 U
Fountain 6 High	<2.0 U
Fountain 6 Low	<2.0 U
Fountain 7 High	<2.0 U
Fountain 7 Low	<2.0 U
Fountain 8 High	<2.0 U
Fountain 8 Low	<2.0 U
Fountain 5.1 High	<2.0 U
Fountain 5.1 Low	<2.0 U
Fountain 5.2 High	<2.0 U
Fountain 5.2 Low	<2.0 U

Fountain 9*	24
Fountain 10	2.8
Fountain 11*	60
Fountain 12 High	<2.0 U
Fountain 12 Low	<2.0 U
Fountain 13 High	<2.0 U
Fountain 13 Low	<2.0 U
Fountain 14 High	<2.0 U
Fountain 14 Low	<2.0 U
Fountain 15 High	<2.0 U
Fountain 15 Low	<2.0 U
Fountain 15-Dog	<2.0 U
Fountain 16 High	<2.0 U
Fountain 16 Low	<2.0 U
Fountain 17	<2.0 U
Fountain 18	<2.0 U
Fountain 19 High*	37
Fountain 19 Middle*	42
Fountain 19 Low*	40
Fountain 20	2.5
Fountain 21*	24
Fountain 22	<2.0 U
Fountain 23	<2.0 U
Fountain 24*	21
Fountain 25	<2.0 U
Fountain 26	3.9
Fountain 27 South	<2.0 U
Fountain 27 East	<2.0 U
Fountain 27 North	<2.0 U
Fountain 28 High	<2.0 U
Fountain 28 Low	<2.0 U

Burnside

Outdoor

Fountain 1	<2.0 U
Fountain 2	3.3
Fountain 3	7.4

Buttercup

Outdoor

Fountain 1 High	<2.0 U
Fountain 1 Middle	<2.0 U
Fountain 1 Low	<2.0 U

Catalpa

Outdoor

Fountain 1	5.49
------------	------

California

Outdoor

Fountain 1 High	<0.120 U
Fountain 1 Middle	<0.120 U
Fountain 1 Low	<0.120 U
Fountain 2 High	0.137 J
Fountain 2 Low	<0.120 U
Fountain 3*	29.5

Calumet

Indoor

Hall Outside of Women's Room	0.55 J
Hall Outside of Preschool Room	1.05 J
Girl's Locker Room	12.4
Boy's Locker Room	1.48 J
Basement Near Train Room	1.82 J

Outdoor

Fountain 2*	16
Fountain 3	<2.0 U
Fountain 4 High	<2.0 U
Fountain 4 Low	<2.0 U
Fountain 5	<2.0 U
Fountain 6	<2.0 U
Fountain 7	7.2
Fountain 8	9.2
Fountain 9	9.7
Fountain 10	<2.0 U
Fountain 11 High	<2.0 U
Fountain 11 Low	<2.0 U
Fountain 12	<2.0 U
Fountain 13	<2.0 U

Carver

Indoor

Main Hallway	<0.120 U
Between Locker Rooms	2.23 J
Pool Deck	1.28 J
Kitchen Sink	2.1

Outdoor

Fountain 1	<2.0 U
Fountain 2	<2.0 U
Fountain 4	13

Cedar

Outdoor

Fountain 1 High	<2.0 U
-----------------	--------

Fountain 1 Middle	<2.0 U
Fountain 1 Low	<2.0 U

Central Playlot

Outdoor

Fountain 1 High	2.0 J
Fountain 1 Low	2.28 J

Challenger

Outdoor

Fountain 1 High	<2.0 U
Fountain 1 Middle	<2.0 U
Fountain 1 Low	<2.0 U

Chase

Indoor

1st Floor Lobby	0.838 J
2nd Floor by Bathrooms	0.757 J

Outdoor

Fountain 1 High	<2.0 U
Fountain 1 Low	<2.0 U
Fountain 2*	25
Fountain 3	11
Fountain 4 High	<2.0 U
Fountain 4 Middle	<2.0 U
Fountain 4 Low	<2.0 U
Fountain 5 High*	42
Fountain 5 Low*	41

Chestnut

Outdoor

Fountain 1 High*	23.1
Fountain 1 Low*	23.5

Chicago Women's

Indoor

1st Floor	<0.120 U
2nd Floor	<0.120 U
3rd Floor	<0.120 U

Chippewa

Indoor

Front Hallway	2.3 J
---------------	-------

Outdoor

Fountain 1	0.522 J
------------	---------

Chopin

Indoor

Main Lobby	1.37 J
------------	--------

Outdoor

Fountain 1	0.965 J
Fountain 2	5.2
Fountain 3	0.491 J
Fountain 4*	21.5

Churchill

Indoor

Fountain 1 High	<2.0 U
Fountain 1 Middle	<2.0 U
Fountain 1 Low	<2.0 U
Fountain 2 High	<2.0 U
Fountain 2 Middle	<2.0 U
Fountain 2 Low	<2.0 U

Citizens Memorial

Outdoor

Fountain 1*	58
-------------	----

Clarendon

Indoor

Game Room East Wall - High	1.37 J
Game Room East Wall - Low	0.447 J
2nd Floor Bathrooms	1.09 J
Fitness Center	0.186 J

Outdoor

Fountain 1	<2.0 U
Fountain 2*	45
Fountain 3 High	<2.0 U
Fountain 3 Middle	<2.0 U
Fountain 3 Low	2.1
Fountain 4 High	<2.0 U
Fountain 4 Middle	<2.0 U
Fountain 4 Low	<2.0 U

Clark (John)

Indoor

Lobby	0.837 J
-------	---------

Outdoor

Fountain 1	0.291 J
------------	---------

Clark (Richard)

Outdoor

Fountain 1 High	0.124 J
-----------------	---------

	Fountain 1 Low	0.127 J
	Fountain 2 High	0.994 J
	Fountain 2 Low	0.291 J
Clark Boathouse		
	Indoor	
	Main Lobby	<0.120 U
	By Washrooms	<0.120 U
Claremont		
	Outdoor	
	Fountain 1 High	1.11 J
	Fountain 1 Middle	1.1 J
	Fountain 1 Low	0.893 J
Clover		
	Outdoor	
	Fountain 1 High*	66
	Fountain 1 Low*	58
Clybourn		
	Outdoor	
	Fountain 1 High*	30
	Fountain 1 Low*	31
Cochran		
	Outdoor	
	Fountain 1 High*	41
	Fountain 1 Low*	42
Cole		
	Indoor	
	Main Lobby	0.364 J
	Outdoor	
	Fountain 1*	42.4
	Fountain 2 High	0.599 J
	Fountain 2 Middle	0.388 J
	Fountain 2 Low	0.519 J
	Fountain 3*	140
	Fountain 4*	15.5
Coleman		
	Outdoor	
	Fountain 1*	27.9
Coliseum		
	Outdoor	

Fountain 1 High	<2.0 U
Fountain 1 Low	2.1
Fountain 1 Dog	<2.0 U
Fountain 2	<2.0 U

Columbus

Indoor

Front Lobby	0.688 J
-------------	---------

Outdoor

Fountain 1	6.5
Fountain 2	0.436 J
Fountain 3	2.26 J
Fountain 4	1.55 J
Fountain 5	0.593 J
Fountain 6	14
Fountain 7 High	0.491 J
Fountain 7 Low	0.283 J
Fountain 8 High	6.96
Fountain 8 Low	7.09
Fountain 9	3.08 J
Fountain 10 High	0.244 J
Fountain 10 Low	1.35 J
Fountain 11 Low	2.05 J

Columbus Athletic Building

Indoor

By Large Gym	0.123 J
--------------	---------

Columbus Refectory

Indoor

East Foyer	0.66 J
------------	--------

Commercial Club

Indoor

Lobby	0.438 J
Kitchen Sink	<2.0 U

Outdoor

Fountain 1 High	0.661 J
Fountain 1 Middle	0.614 J
Fountain 1 Low	0.46 J

Cooper

Indoor

Main Lobby	1.85 J
------------	--------

Outdoor

Fountain 1	0.916 J
Fountain 2 High	0.205 J

	Fountain 2 Low	1.07 J
Cornell		
	Outdoor	
	Fountain 1 High*	97.5
	Fountain 1 Low*	116
Cornell Square		
	Indoor	
	Near Women's Room	2.62 J
	Near Entrance	0.227 J
	Kitchen Sink	<2.0 U
	Outdoor	
	Fountain 1	<0.120 U
	Fountain 2	6.36
	Fountain 3 High	<0.120 U
	Fountain 3 Low	<0.120 U
	Fountain 4	3.98 J
Cosme		
	Outdoor	
	Fountain 1 High	0.334 J
	Fountain 1 Dog	0.363 J
	Fountain 2	10.5
Cotton Tail		
	Outdoor	
	Fountain 1	<2.0 U
	Fountain 2	<2.0 U
	Fountain 3 High	<2.0 U
	Fountain 3 Low	<2.0 U
Cragin		
	Indoor	
	Hallway	10.9
	Outdoor	
	Fountain 1	1.35 J
	Fountain 2	1.72 J
Cresent		
	Outdoor	
	Fountain 1	4.21 J
Daley (Richard)		
	Oudoor	
	Fountain 1 High	0.333 J
	Fountain 1 Low	1.11 J

Davis (M.)

Outdoor

Fountain 1 0.142 J

Davis Square

Indoor

1st Floor Near Elevator <0.120 U

2nd Floor Near Special Rec 0.138 J

Kitchen Sink <2.0 U

Kitchen Sink 2nd Floor <2.0 U

Outdoor

Fountain 1 High 0.623 J

Fountain 1 Low 0.428 J

Fountain 2* 15.7

Fountain 3 High <0.120 U

Fountain 3 Low <0.120 U

Dawes

Indoor

Near Office* 26.5

Kitchen Sink 0.358 J

Slop Sink 0.83 J

Outdoor

Fountain 1 High 11.9

Fountain 1 Low 10.1

Fountain 2* 0.516 J

Dean

Outdoor

Fountain 1 High 0.911 J

Fountain 1 Middle 1.05 J

Fountain 1 Low 0.943 J

Dearborn

Outdoor

Fountain 1 High* 52

Fountain 1 Low* 18

Fountain 2 High* 120

Fountain 2 Low* 110

Debow

Outdoor

Fountain 1* 29

De Burgos

Outdoor

	Fountain 1 High	0.3
	Fountain 1 Middle	0.311
	Fountain 1 Low	0.31
DeJulio		
	Outdoor	
	Fountain 1 High*	24.1
	Fountain 1 Low*	30.7
D'Elia		
	Outdoor	
	Fountain 1 High*	33
	Fountain 1 Low*	33
Dickinson		
	Outdoor	
	Fountain 1 High	0.231 J
	Fountain 1 Middle	0.211 J
	Fountain 1 Low	0.227 J
Dixon		
	Outdoor	
	Fountain 1 High	12.1
	Fountain 1 Low	12
Dogwood		
	Outdoor	
	Fountain 1*	17.8
Donahue		
	Outdoor	
	Fountain 1 High	2
	Fountain 1 Middle	2.7
	Fountain 1 Low	<2.0 U
Don Nash Community Center		
	Indoor	
	1st Floor Between Room	0.16 J
	2nd Floor by Fitness Center	<0.120 U
	Pool Level Women's Washroom	0.462 J
	Pool Level Men's Washroom	<0.120 U
	Pool Deck	0.198 J
Donovan		
	Indoor	
	Club Room	3.01 J
	Outdoor	

Fountain 1*	16.4
Dougherty	
Outdoor	
Fountain 1	5.2
Douglas	
Indoor	
Main Lobby	0.219 J
Outdoor	
Fountain 1*	21.7
Fountain 2	2.21 J
Fountain 4 High	0.572 J
Fountain 4 Low	0.128 J
Fountain 5	2.49 J
Fountain 6	1.04 J
Fountain 7 High	7.1
Fountain 7 Low	6.67
Fountain 8	3.39 J
Fountain 9*	16.6
Fountain 10 High	9.22
Fountain 10 Middle	9.96
Fountain 10 Low	9.09
Drexel	
Outdoor	
Fountain 1*	70
Dubkin	
Outdoor	
Fountain 1 High	<2.0 U
Fountain 1 Low	<2.0 U
Dunbar	
Outdoor	
Fountain 1*	130
Fountain 2	<2.0 U
Fountain 3*	26
Fountain 4 High	<2.0 U
Fountain 4 Middle	<2.0 U
Fountain 4 Low	<2.0 U
Fountain 5 High	<2.0 U
Fountain 5 Middle	<2.0 U
Fountain 5 Low	<2.0 U
Dunham	
Indoor	

Main Hall South	0.486 J
Women's Locker Room	10
Men's Locker Room	3.89 J
Kitchen Sink	<2.0 U

Outdoor

Fountain 1*	30.5
Fountain 2*	21.9
Fountain 3 High	7.66
Fountain 3 Middle	5.78
Fountain 3 Low	6.06

Durkin

Outdoor

Fountain 2	2.72 J
Fountain 3 High	<0.120 U
Fountain 3 Low	<0.120 U

Dvorak

Indoor

Main Lobby - High	0.922 J
Main Lobby - Low	1.44 J
Kitchen Sink	<2.0 U

Outdoor

Fountain 1*	17
Fountain 2 High	7.4
Fountain 2 Middle	4.8
Fountain 2 Low	3.8
Fountain 3 High*	17
Fountain 3 Low*	20
Fountain 4 High	<2.0 U
Fountain 4 Low	<2.0 U
Fountain 5 High	<2.0 U
Fountain 5 Low	<2.0 U

Eckersall

Outdoor

Fountain 1 High	14
Fountain 1 Low	13

Eckhart

Indoor

Lobby	0.396 J
Pool Deck	0.691 J
Men's Locker Room	4.01 J
Kitchen Sink	<2.0 U

Outdoor

Fountain 1 High	14.1
-----------------	------

	Fountain 1 Low	14.6
	Fountain 2 High	5.6
	Fountain 2 Middle	5.91
	Fountain 2 Low	6.8
Edgebrook		
	Outdoor	
	Fountain 1 High	0.793 J
	Fountain 1 Low	0.689 J
Edison		
	Indoor	
	Main Lobby	12.2
Edmonds		
	Outdoor	
	Fountain 1 High	12.5
	Fountain 1 Low	14.1
Ellis		
	Indoor	
	Outside Gym	<2.0 U
	Fitness Center	<2.0 U
	Pool Deck	<2.0 U
	1st Floor Kitchen	<2.0 U
	2nd Floor Kitchen	<2.0 U
	Outdoor	
	Fountain 1*	16
	Fountain 2*	92
Elm		
	Outdoor	
	Fountain 1	5.3
Emerald		
	Outdoor	
	Fountain 1*	30.2
Emmerson		
	Indoor	
	Main Lobby	1.61 J
	Outdoor	
	Fountain 1*	102
Erhler		
	Outdoor	

	Fountain 1	2.5
Essex		
	Outdoor	
	Fountain 1 High	5.6
	Fountain 1 Middle	5.8
	Fountain 1 Low	5.9
Euclid		
	Indoor	
	Main Lobby	0.871 J
	Outdoor	
	Fountain 1	12.5
	Fountain 2 High	0.76 J
	Fountain 2 Low	0.77 J
	Fountain 3 High	13.2
	Fountain 3 Low	11.2
Eugene Field		
	Indoor	
	1st Floor by Men's Washroom	1.05 J
	2nd Floor by Women's Washroom	0.462 J
	Basement Hallway	0.497 J
	Women's Locker Room*	58.2
	Men's Locker Room*	71.3
	Outdoor	
	Fountain 1 High	9.18
	Fountain 1 Low	9.5
	Fountain 2 High	<0.120 U
	Fountain 2 Middle	<0.120 U
	Fountain 2 Low	<0.120 U
	Fountain 3 High*	6.74
	Fountain 3 Low*	15.4
	Fountain 4 High	11.9
	Fountain 4 Low	14.3
Fellger		
	Outdoor	
	Fountain 1 High	<2.0 U
	Fountain 1 Low	<2.0 U
Fernwood		
	Indoor	
	Lobby by Gym	<0.120 U
	Main Lobby	0.232 J
	Outdoor	
	Fountain 1	<0.120 U

Fountain 2*	33.2
Filbert	
Outdoor	
Fountain 1 High	2.5
Fountain 1 Middle	2.2
Fountain 1 Low	2.3
Flower	
Outdoor	
Fountain 1 High	<2.0 U
Fountain 1 Middle	<2.0 U
Fountain 1 Low	<2.0 U
Flying Squirrel	
Outdoor	
Fountain 1	6.58
Forest Glen	
Outdoor	
Fountain 1 High	4.53 J
Fountain 1 Low	4.57 J
Fountain 1 Dog	5.39
Fosco	
Indoor	
Main Hall - High	<0.120 U
Main Hall - Low	<0.120 U
Outside Locker Room	<0.120 U
Outside Gym Near Pool - High	<0.120 U
Outside Gym Near Pool - Low	<0.120 U
Pool Area - High	<0.120 U
Pool Area - Low	<0.120 U
Outside Daycare - High	<0.120 U
Outside Daycare - Low	<0.120 U
Daycare Entrance - High	<0.120 U
Daycare Entrance - Low	<0.120 U
Daycare Sink	<2.0 U
Daycare Employee Sink	<2.0 U
Senior Room Sink	<2.0 U
Warming Kitchen Sink	<2.0 U
Outdoor	
Fountain 1 High	<2.0 U
Fountain 1 Low	<2.0 U
Fountain 2 High	<2.0 U
Fountain 2 Low	<2.0 U

Foster

Indoor

Lobby - High	0.34 J
Lobby - Low	0.672 J
Men's Locker Room	0.733 J
Kitchen Sink	<2.0 U

Outdoor

Fountain 1 High	0.419 J
Fountain 1 Low	0.325 J
Fountain 2 High	7.52
Fountain 2 Low	7.89
Fountain 3*	159
Fountain 4 High	<0.120 U
Fountain 4 Low	2.06 J
Fountain 5 High*	50
Fountain 5 Low*	73
Fountain 6 High	0.182 J
Fountain 6 Low	0.28 J

Franklin

Indoor

Main Lobby	0.505 J
Women's Locker Room	1.42 J
Men's Locker Room	<0.120 U
Kitchen Sink	2.5

Outdoor

Fountain 1	2.32 J
Fountain 2 High	<0.120 U
Fountain 2 Low	<0.120 U
Fountain 3	1.12 J
Fountain 4*	37.2

Fuller

Indoor

Main Lobby	0.413 J
West Gym Hallway	0.977 J
East Gym Hallway	2.58 J
Boxing Gym	3.15 J
Kitchen Sink	3.9

Outdoor

Fountain 1 High*	10.6
Fountain 1 Middle*	10.9
Fountain 1 Low*	16.9
Fountain 2	0.126 J
Fountain 3	0.584 J
Fountain 4*	472
Fountain 5*	82.1

Gage

Indoor

Basement	0.203 J
Women's Locker Room	1.2 J
Men's Locker Room	0.524 J
Lobby - High	0.343 J
Lobby - Low	0.378 J
Kitchen Sink West	<2.0 U
Kitchen Sink East	<2.0 U

Outdoor

Fountain 1	1.24 J
Fountain 2	1.07 J
Fountain 3	2.09 J
Fountain 4*	48.8
Fountain 5 High	0.12 J
Fountain 5 Middle	0.17
Fountain 5 Low	0.22
Fountain 6*	30.5
Fountain 7*	124

Galewood

Indoor

Lobby	0.563 J
Bathroom Adaptor	0.218 J

Outdoor

Fountain 1	2.29
------------	------

Garfield

Indoor

Main Floor North Near Offices	0.281 J
Main Floor South Near Fitness	1.65 J
2nd Floor Near Rotunda	4.18 J
Basement Boy's Locker Room	0.856 J
Basement Girl's Locker Room	1.4 J
Basement Near Gym	6.06
Kitchen Sink	<2.0 U

Outdoor

Fountain 1	0.387 J
Fountain 2*	43.7
Fountain 3 High	<0.120 U
Fountain 3 Middle	<0.120 U
Fountain 3 Low	<0.120 U
Fountain 4 High	1.17 J
Fountain 4 Low	1.22 J
Fountain 5	<0.120 U
Fountain 6	2.48 J

Fountain 7	0.781 J
Fountain 8	7.06
Fountain 9*	72.4
Fountain 10	13
Fountain 11	4.11 J

Garibaldi

Outdoor

Fountain 1	3.3
------------	-----

Gately

Outdoor

Fountain 1*	30
Fountain 2	<2.0 U

Gill

Indoor

1st Floor - High	<0.120 U
1st Floor - Low	1.12 J
Basement Men's Locker Room	1.2 J
Basement Women's Locker Room	1.79 J

Outdoor

Fountain 1 High*	31
Fountain 1 Middle*	32
Fountain 1 Low*	28

Gladstone

Outdoor

Fountain 1 High*	44.9
Fountain 1 Middle*	0.812 J
Fountain 1 Low*	28.3

Gladys

Outdoor

Fountain 1	4.66 J
------------	--------

Goldberg

Outdoor

Fountain 1 High*	69
Fountain 1 Low*	53

Golden Gate

Outdoor

Fountain 1 High	4
Fountain 1 Low	8.8

Gooseberry

Outdoor

Fountain 1*	60
-------------	----

Gompers

Indoor

Main Hallway	0.832 J
Women's Locker Room	2.26 J
Men's Locker Room	4.34 J

Outdoor

Fountain 1*	16.2
Fountain 2*	43.8
Fountain 2A*	49.4
Fountain 3 High	6.66
Fountain 3 Middle	6.78
Fountain 3 Low	6.82
Fountain 4*	24.1
Fountain 5 High	0.431 J
Fountain 5 Low	0.472 J
Fountain 6	0.988 J
Fountain 7	<0.120 U
Fountain 8*	39.8
Fountain 9*	61.7

Goudy

Outdoor

Fountain 1 High	<2.0 U
Fountain 1 Middle	<2.0 U
Fountain 1 Low	<2.0 U

Grand Playlot

Outdoor

Fountain 1*	54.2
-------------	------

Grand Crossing

Indoor

Lobby South	1.57 J
Lobby North	<0.120 U

Outdoor

Fountain 1	2.43 J
Fountain 2	9
Fountain 3	1.05 J
Fountain 4	0.975 J
Fountain 5	0.674 J
Fountain 6 High	4.87 J
Fountain 6 Low	4.14 J
Fountain 7 High	10.1
Fountain 7 Low	6.18

Grant

Outdoor

Fountain 1	<2.0 U
Fountain 2	<2.0 U
Fountain 3	4.3
Fountain 4 High	<2.0 U
Fountain 4 Low	<2.0 U
Fountain 5 (Bond)	<2.0 U
Fountain 5a (Trough)	<2.0 U
Fountain 5b (Trough)	<2.0 U
Fountain 5c (Trough)	<2.0 U
Fountain 5d (Trough)	<2.0 U
Fountain 6	<2.0 U
Fountain 7	<2.0 U
Fountain 8 High	<2.0 U
Fountain 8 Low	2.3
Fountain 9 High	11
Fountain 9 Low	5.4
Fountain 10	<2.0 U
Fountain 11	<2.0 U
Fountain 13 High	20
-Retest after repair	2.3
Fountain 13 Low	20
-Retest after repair	2.4
Fountain 14 High	29
-Retest after repair	<2.0 U
Fountain 14 Low	29
-Retest after repair	<2.0 U
Fountain 15 High	<2.0 U
Fountain 15 Low	<2.0 U
Fountain 16	<2.0 U
Fountain 17	<2.0 U
Fountain 18 High	<2.0 U
Fountain 18 Low	<2.0 U
Fountain 19 High	2.7
Fountain 19 Low	7.4
Fountain 20	<2.0 U
Fountain 21	11
Fountain 22*	1200
Fountain 23*	80
Fountain 24*	81
Fountain 25	2.2
Fountain 26*	46
Fountain 27 High	9.1
Fountain 27 Low	10

Fountain 28 High*	69
Fountain 28 Low*	75
Fountain 30 High	5.8
Fountain 30 Low	5.5
Fountain 31*	560
Fountain 32	5.4
Fountain 33 High	<2.0 U
Fountain 33 Dog	<2.0 U
Fountain 34	<2.0 U
Fountain 35	<2.0 U
Fountain 36 High	<2.0 U
Fountain 36 Low	<2.0 U
Fountain 37	<2.0 U
Fountain 38 High	<2.0 U
Fountain 38 Low	<2.0 U
Fountain 39 High	<2.0 U
Fountain 39 Low	<2.0 U
Fountain 40 High	2.5
Fountain 40 Low	<2.0 U
Fountain 41 High	<2.0 U
Fountain 41 Low	<2.0 J
Fountain 42 High	<2.0 U
Fountain 42 Low	<2.0 U
Fountain 43 High	<2.0 U
Fountain 43 Low	<2.0 U
Fountain 44 High	<2.0 U
Fountain 44 Low	<2.0 U

Grape

Outdoor	
Fountain 1*	21.1

Graver

Indoor	
Main Lobby	<0.120 U
Kitchen Sink	<2.0 U
Outdoor	
Fountain 2	0.151 J

Green

Outdoor	
Fountain 1*	76.9

Greenbaum

Outdoor	
Fountain 1 High	0.178 J
Fountain 1 Low	0.178 J

Fountain 2 High	<0.120 U
Fountain 2 Middle	<0.120 U
Fountain 2 Low	<0.120 U

Green Briar

Indoor

Lobby East	0.904 J
Lobby West	0.574 J

Outdoor

Fountain 1*	24.4
Fountain 2*	59.1
Fountain 3	0.853 J

Griffin

Outdoor

Fountain 1*	16
-------------	----

Gross

Outdoor

Fountain 1 High*	34.3
Fountain 1 Low*	34.4

Haas

Indoor

Outside Gym - High	<0.120 U
Outside Gym - Low	<0.120 U
Kitchen Sink	<2.0 U

Outdoor

Fountain 1 High	<2.0 U
Fountain 1 Middle	<2.0 U
Fountain 1 Low	<2.0 U

Hale

Indoor

Lobby - High	<0.120 U
Lobby - Low	<0.120 U
Near Locker Rooms	<0.120 U
Pool Building Entrance	0.43 J

Outdoor

Fountain 1 High	0.774 J
Fountain 1 Low	0.65 J
Fountain 2*	44.7
Fountain 3 Low	<0.120 U
Fountain 3 High	<0.120 U
Fountain 4	0.268 J

Hamilton

Indoor

Main Lobby - East Side	0.19 J
Main Lobby - West Side	0.464 J
Kitchen Sink	<2.0 U

Outdoor

Fountain 1	8.49
Fountain 2 High	0.137 J
Fountain 2 Middle	<0.120 U
Fountain 2 Low	0.906 J
Fountain 3 High	1.95 J
Fountain 3 Low	1.35 J

Hamlin

Indoor

Main Lobby	1.63 J
Women's Locker Room	0.888 J

Outdoor

Fountain 1*	72
Fountain 2*	48
Fountain 3	4.4
Fountain 4*	41

Hansberry

Outdoor

Fountain 1	7.42
------------	------

Harding (Frederick)

Outdoor

Fountain 1	<0.120 U
------------	----------

Harding (George)

Outdoor

Fountain 1	3.1
------------	-----

Harris

Indoor

Near Gym	<0.120 U
2nd Floor Dance Room	2.53 J
1st Floor Southwest	<0.120 U
Africa Office	1.38 J
Basement Back Entrance	4.43 J

Outdoor

Fountain 1 High	<0.120 U
Fountain 1 Low	<0.120 U

Harrison

Indoor

	Fitness Center	<0.120 U
	Pool Deck	4.07 J
	North Gym Entrance	<0.120 U
	South Gym Entrance	<0.120 U
	Kitchen Sink	<2.0 U
Outdoor		
	Fountain 1 High	<2.0 U
	Fountain 1 Low	<2.0 U
	Fountain 3	<2.0 U
Hartigan Beach		
Outdoor		
	Fountain 1	<2.0 U
	Fountain 2 High	<2.0 U
	Fountain 2 Low	<2.0 U
Hayes		
Indoor		
	Hallway Near Lobby	1.22 J
	Fitness Center - High	<0.120 U
	Fitness Center - Low	<0.120 U
	Outside Men's Locker - High	0.24 J
	Outside Men's Locker - Low	0.213 J
	Pool Area - High	0.288 J
	Pool Area - Middle	1.35 J
	Pool Area - Low	<0.120 U
	Kitchen Sink	<2.0 U
Outdoor		
	Fountain 2*	243
	Fountain 3*	156
Hazelnut		
Outdoor		
	Fountain 1	6.16
Hermitage		
Indoor		
	Club Room	10.5
Outdoor		
	Fountain 1 High	3.49 J
	Fountain 1 Middle	3.54 J
	Fountain 1 Low	3.26 J
Hermosa		
Indoor		
	Lobby - High	0.911 J
	Lobby - Low	0.945 J

Outdoor		
Fountain 2		0.729 J
Hiawatha		
Indoor		
Main Lobby - Low		0.936 J
Outdoor		
Fountain 1		12
Fountain 2*		80.7
Fountain 3 High		0.157 J
Fountain 3 Middle		0.143 J
Fountain 3 Low		0.166 J
Fountain 4		7.75
Hickory		
Outdoor		
Fountain 1 High		2.5
Fountain 1 Low		<2.0
Hoard		
Outdoor		
Fountain 1		12.9
Hollywood		
Indoor		
Game Room		5.16
Outdoor		
Fountain 1		4.85 J
Fountain 2*		32
Holstein		
Indoor		
Main Lobby		<0.120 U
Kitchen Sink		<2.0 U
Outdoor		
Fountain 1 High		<2.0 U
Fountain 1 Low		<2.0 U
Fountain 2*		210
Homan Square		
Indoor		
North Wing Near Club Room - High		<0.120 U
North Wing Near Club Room - Low		0.12 J
South Wing Near Gym - High		<0.120 U
South Wing Near Gym - Low		<0.120 U
Pool Area		<0.120 U
Kitchen Sink		<2.0 U

Honeysuckle

Outdoor

Fountain 1 High*	27
Fountain 1 Low*	28

Horan

Outdoor

Fountain 1 High	3.67
Fountain 1 Low	3.71

Hornbeam

Outdoor

Fountain 1	0.526 J
------------	---------

Horner

Indoor

Lobby Outside Gym	0.531 J
Inside Gym - High	1.62 J
Inside Gym - Low	1.65 J
2nd Floor	1.09 J

Outdoor

Fountain 1*	34
Fountain 2 High	13
Fountain 2 Low	12.9
Fountain 3 High	10.9
Fountain 3 Low	10.8
Fountain 4 High*	25.9
Fountain 4 Middle*	26.4
Fountain 4 Low*	25.6
Fountain 5 High*	43.2
Fountain 5 Low*	39
Fountain 6 High*	61.2
Fountain 6 Low*	67.3
Fountain 7 High	3.13 J
Fountain 7 Low	6.06
Fountain 8 High	1.74 J
Fountain 8 Low*	16.3
Fountain 9 High	0.176 J
Fountain 9 Low	0.165 J
Fountain 10 High*	110
Fountain 10 Low*	116
Fountain 11 High*	135
Fountain 11 Low*	126

Houston

Outdoor

	Fountain 1	<2.0 U
	Fountain 2	2.8
Hoyne		
	Indoor	
	Club Room	2.80 J
	Outdoor	
	Fountain 1	2.55 J
Huckleberry		
	Outdoor	
	Fountain 1	12.2
Humbert		
	Outdoor	
	Fountain 1 High	10.4
	Fountain 1 Low	11
Humboldt		
	Indoor	
	Main Floor East Side	1.34 J
	Main Floor West Side	4.22 J
	Basement West Side*	16.8
	Basement Game Room	14.4
	Kitchen Sink	<2.0 U
	Outdoor	
	Fountain 1*	23.3
	Fountain 2	5.65
	Fountain 3*	21.6
	Fountain 5	<0.120 U
	Fountain 7	1.51 J
	Fountain 8 High	0.437 J
	Fountain 8 Middle	0.431 J
	Fountain 9	5.65
	Fountain 10	1.38 J
	Fountain 11 High	0.18 J
	Fountain 11 Middle	0.176 J
	Fountain 11 Low	0.191 J
	Fountain 12 High	10.1
	Fountain 12 Low	8.93
	Fountain 13 High	0.2 J
	Fountain 13 Low	0.383 J
	Fountain 13 - Dog	0.126 J
	Fountain 14*	15.1
	Fountain 15	1.85 J
	Fountain 16	1.13 J

Fountain 17	6.73
Fountain 18 High	0.197 J
Fountain 18 Middle	<0.120 U
Fountain 18 Low	<0.120 U
Fountain 20	2.53 J
Fountain 21*	15.7
Fountain 22*	30.4
Fountain 23	3.58 J
Fountain 24*	28.8

Hurley

Outdoor

Fountain 1 High	2.17 J
Fountain 1 Middle	1.26 J
Fountain 1 Low	1.77 J

Independence

Indoor

Special Rec Room	<0.120 U
Main Lobby	<0.120 U
Pool Area	<0.120 U
Fitness Center	0.948 J

Outdoor

Fountain 1 High	6.88
Fountain 1 Low	7.39
Fountain 2 High*	17.8
Fountain 2 Low*	22.2
Fountain 3 High	3.06 J
Fountain 3 Low	2.84 J
Fountain 3 Middle	3.09J

Indian Boundary

Indoor

Main Lobby	3.81 J
------------	--------

Outdoor

Fountain 1 High*	15.6
Fountain 1 Middle*	16.7
Fountain 1 Low*	16.2
Fountain 2 High*	52.3
Fountain 2 Low*	51.8
Fountain 3 High	10.5
Fountain 3 Low	8.38

Indian Road

Indoor

Preschool Room	6.66
----------------	------

Outdoor

Fountain 1 High	2.37 J
Fountain 1 Low	2.96 J
Fountain 2*	38.9
Fountain 3 High*	14.9
Fountain 3 Middle*	17.6
Fountain 3 Low*	15.2

Jackson (Andrew)

Indoor

Hallway	0.536 J
Men's Locker Room	8.72
Women's Locker Room*	36.9

Outdoor

Fountain 1 High	<0.120 U
Fountain 1 Low	<0.120 U
Fountain 2 High	0.783 J
Fountain 2 Low	0.812 J
Fountain 3	0.345 J
Fountain 4	0.905 J
Fountain 5 High	6.67
Fountain 5 Low	6.77
Fountain 6*	25.2
Fountain 7*	70.5
Fountain 8 High	1.38 J
Fountain 8 Low	1.16 J
Fountain 9*	69.2
Fountain 10	12.2
Fountain 11	2.56 J
Fountain 12	3.15 J
Fountain 13*	60
Fountain 15	10.5
Fountain 16*	18.8
Fountain 17 High	0.985
Fountain 20 High	<0.120 U
Fountain 20 Low	<0.120 U
Fountain 21 high	<0.120 U
Fountain 22*	18.9
Fountain 23*	208
Fountain 24	1.94 J
Fountain 25*	95
Fountain 26*	30.1
Fountain 27	13.9

Jackson (Mahalia)

Outdoor

Fountain 1*	361
-------------	-----

Fountain 2*	44
Jackson Playlot	
Outdoor	
Fountain 1*	30
Jacob	
Outdoor	
Fountain 1 High*	16
Fountain 1 Low*	16.4
Jefferson	
Outdoor	
Fountain 1*	24.6
Jefferson Memorial	
Indoor	
Main Lobby	2.47 J
Downstairs	6.51
Upstairs	4.77 J
Pool Building	0.576 J
Outdoor	
Fountain 1	0.894 J
Fountain 2	0.343 J
Fountain 3 High*	35.4
Fountain 3 Middle*	2.18 J
Fountain 3 Low*	2.28 J
Jefferson Playlot	
Outdoor	
Fountain 1 High	<2.0 U
Fountain 1 Middle	<2.0 U
Fountain 1 Low	<2.0 U
Jensen	
Outdoor	
Fountain 1 High	<0.120 U
Fountain 1 Low	<0.120 U
Fountain 2 High	0.179 J
Fountain 2 Low	0.196 J
Jesse White Comm Ctr	
Indoor	
Outside Gym - High	<0.120 U
Outside Gym - Low	<0.120 U
Gymnastics Center - High	0.263 J
Gymnastics Center - Low	0.341 J

Jones		
	Outdoor	
	Fountain 1	<2.0 U
Jonquil		
	Outdoor	
	Fountain 1*	180
	Fountain 2 High	<2.0 U
	Fountain 2 Middle	<2.0 U
	Fountain 2 Low	<2.0 U
	Fountain 3*	58
Junction Grove		
	Outdoor	
	Fountain 1*	61.3
Juneway Beach		
	Outdoor	
	Fountain 1*	62
Juniper		
	Outdoor	
	Fountain 1*	18
Kedvale		
	Indoor	
	Lobby	10.4
	Outdoor	
	Fountain 1 Low	<0.120 U
	Fountain 1 Middle	<0.120 U
Kelly		
	Outdoor	
	Fountain 1 High	6.56
	Fountain 1 Low	5.52
	Fountain 2	0.516 J
	Fountain 3	5.39
Kells		
	Outdoor	
	Fountain 1*	18.1
Kelvyn		
	Indoor	
	Gym Hallway	3.94 J
	Front Lobby	5.91

Auditorium	0.371 J
Outdoor	
Fountain 1	5.08
Fountain 2	12.4
Fountain 3	7.08
Fountain 4*	25

Kennedy

Indoor	
Near Women's Locker Room	0.184 J
Kitchen Sink	<2.0 U
Outdoor	
Fountain 1*	36.9
Fountain 2	1.29 J
Fountain 3 High	0.204 J
Fountain 3 Middle	0.284 J
Fountain 3 Low	0.534 J
Fountain 4*	28
Fountain 5	4.4 J
Fountain 6*	68
Fountain 7	3.11 J
Fountain 8	4.04 J

Kennicott

Indoor	
Main Lobby	0.749 J
Fitness Center	0.673 J
Near Girl's Restroom	1.86 J
1st Floor Near Preschool Room*	26.3
-Follow Up Sample 1	2.85 J
-Follow Up Sample 2	2.08 J
-Follow Up Sample 3	1.87 J
-Follow Up Sample 4	2.22 J
-Follow Up Sample 5	2.29 J
2nd Floor Near Restrooms	0.868 J
2nd Floor Back of Building	5.53
Large Kitchen Sink	4.03 J
Senior Room Sink	0.344 J

Kensington

Outdoor	
Fountain 1*	28.5

Ken-Well

Indoor	
Club Room	2.49 J
Outdoor	

Fountain 1*	42
Kenwood	
Outdoor	
Fountain 1 High*	36
Fountain 1 Low*	24
Fountain 2	3.5
Fountain 3	<2.0 U
Kilborn	
Indoor	
Main Lobby	1.18 J
Gym Hallway West	0.191 J
Gym Hallway East	0.307 J
Outdoor	
Fountain 1*	51.2
Fountain 2*	31.9
Fountain 3*	31.7
Fountain 4	12.9
King	
Outdoor	
Fountain 1 High	0.309 J
Fountain 1 Low	0.322 J
King-Lockhart	
Outdoor	
Fountain 1 High	13.6
Fountain 1 Low	14.3
Klein	
Outdoor	
Fountain 1 High	<2.0 U
Fountain 1 Low	<2.0 U
Fountain 1 Middle	<2.0 U
Kolmar	
Outdoor	
Fountain 1*	38.7
Korczak	
Outdoor	
Fountain 1*	16
Kosciuszko	
Indoor	
Lobby South Wall - High	0.168 J

	Lobby South Wall - Low	0.161 J
	Lobby West Wall	0.138 J
Outdoor		
	Fountain 1 High*	92.1
	Fountain 1 Low*	105
	Fountain 2 High	0.145 J
	Fountain 2 Low	0.163 J
	Fountain 3 High	<0.120 U
	Fountain 3 Middle	<0.120 U
	Fountain 3 Low	<0.120 U
Krause		
Outdoor		
	Fountain 1 High	<2.0 U
	Fountain 1 Middle	<2.0 U
	Fountain 1 Low	<2.0 U
Kucinski-Murphy		
Outdoor		
	Fountain 1	0.342 J
LaFollette		
Indoor		
	Main Lobby	1.13 J
	Pool Area	0.534 J
	Kitchen Sink	2.1
Outdoor		
	Fountain 1 High	<0.120 U
	Fountain 1 Middle	0.304 J
	Fountain 1 Low	<0.120 U
	Fountain 2	9.8
	Fountain 3	7.16
	Fountain 4	8.72
	Fountain 5 High	0.554 J
	Fountain 5 Low	0.52 J
Lake Shore		
Indoor		
	Main Hallway	0.161 J
	Kitchen Sink	2.8
Outdoor		
	Fountain 1 High	<2.0 U
	Fountain 1 Low	2.1
	Fountain 2 High	<2.0 U
	Fountain 2 Middle	<2.0 U
	Fountain 2 Low	<2.0 U

Lamb		
Outdoor		
Fountain 1*		41.8
Lane Beach		
Outdoor		
Fountain 1 High*		15
Fountain 1 Middle*		12
Fountain 1 Low*		8.5
Langdon		
Outdoor		
Fountain 1*		20
Langley		
Outdoor		
Fountain 1 High		4.61
Fountain 1 Low		5.82
Fountain 2 High		6.05
Fountain 2 Middle		6.1
Fountain 2 Low		6.7
LaVillita		
Outdoor		
Fountain 1 High		<0.120 U
Fountain 1 Middle		<0.120 U
Fountain 1 Low		<0.120 U
Fountain 2 High		<0.120 U
Fountain 2 Low		<0.120 U
Fountain 3 High		<0.120 U
Fountain 3 Middle		<0.120 U
Fountain 3 Low		<0.120 U
Lawler		
Indoor		
Club Room		5.83
Outdoor		
Fountain 1 High*		42.1
Fountain 1 Low*		44.8
Fountain 2 High		0.807 J
Fountain 2 Low		0.708 J
Fountain 2 Middle		0.54 J
Lazarus		
Outdoor		
Fountain 1		120

LeClaire Court

Indoor

Girl's Locker Room	0.373 J
Boy's Locker Room	0.25 J
Hallway to Gym	1.36 J
Kitchen Sink	<2.0 U

Outdoor

Fountain 1	1.38 J
Fountain 2*	65.8
Fountain 3	7.71

Lee

Outdoor

Fountain 1 High	6.52
Fountain 1 Low	6.83

Legion

Outdoor

Fountain 1*	118
Fountain 2*	88.2
Fountain 3	12.6
Fountain 4*	101
Fountain 5*	73.9
Fountain 6*	91.7

Leone Beach

Indoor

Near Bathroom	9.2
---------------	-----

Outdoor

Fountain 1*	18
-------------	----

Lerner

Outdoor

Fountain 1	1.67 J
Fountain 2	1.09 J
Fountain 3	5.71
Fountain 4	1.46 J

Levin

Outdoor

Fountain 1	0.21 J
------------	--------

Lincoln

Outdoor

Fountain 1 High	<2.0 U
Fountain 1 Low	<2.0 U
Fountain 2	<2.0 U

Fountain 3	8.6
Fountain 4	3.2
Fountain 5	<2.0 U
Fountain 6 High	<2.0 U
Fountain 6 Low	<2.0 U
Fountain 7	<2.0 U
Fountain 8	<2.0 U
Fountain 9*	95
Fountain 10	4.2
Fountain 11 High	<2.0 U
Fountain 11 Middle	<2.0 U
Fountain 11 Low	2.9
Fountain 12*	16
Fountain 13	<2.0 U
Fountain 15 North	<2.0 U
Fountain 15 East	<2.0 U
Fountain 15 South	<2.0 U
Fountain 15 West	<2.0 U
Fountain 16	<2.0 U
Fountain 18 High	<2.0 U
Fountain 18 Low	<2.0 U
Fountain 19	14
Fountain 20 North	2.7
Fountain 20 East	2.4
Fountain 20 South	2.1
Fountain 20 West	2.8
Fountain 21	13
Fountain 22*	39
Fountain 23*	140
Fountain 24	<2.0 U
Fountain 25*	16
Fountain 26	<2.0 U
Fountain 27 North *	12
Fountain 27 East*	20
Fountain 27 South*	15
Fountain 27 West*	11
Fountain 30	<2.0 U
Fountain 31 High	<2.0 U
Fountain 31 Low	<2.0 U
Fountain 31 North	2.8
Fountain 32 East	3.7
Fountain 32 South	3.7
Fountain 32 West	24
Fountain 33*	110
Fountain 34 North*	15
Fountain 34 East*	18
Fountain 34 South*	14

Fountain 34 West*	15
Fountain 35 North	9.6
Fountain 35 East	11
Fountain 35 South	11
Fountain 35 West	9.7
Fountain 36	4.2
Fountain 37*	36
Fountain 38*	22
Fountain 39 North	<2.0 U
Fountain 39 East	<2.0 U
Fountain 39 South	<2.0 U
Fountain 39 West	<2.0 U
Fountain 40	<2.0 U
Fountain 41	<2.0 U
Fountain 42	<2.0 U
Fountain 43	<2.0 U
Fountain 44	<2.0 U
Fountain 46	<2.0 U
Fountain 47 North	<2.0 U
Fountain 47 South	<2.0 U
Fountain 47 East	<2.0 U
Fountain 47 West	<2.0 U
Fountain 48	2.7
Fountain 49 North	<2.0 U
Fountain 49 East	<2.0 U
Fountain 49 South	<2.0 U
Fountain 49 West	<2.0 U
Fountain 50 North	<2.0 U
Fountain 50 East	<2.0 U
Fountain 50 South	<2.0 U
Fountain 50 West	<2.0 U
Fountain 51	<2.0 U
Fountain 52 High	<2.0 U
Fountain 52 Low	<2.0 U
Fountain 53	<2.0 U
Fountain 54 High	<2.0 U
Fountain 54 Middle	<2.0 U
Fountain 54 Low	<2.0 U
Fountain 56 High	<2.0 U
Fountain 56 Middle	<2.0 U
Fountain 56 Low	<2.0 U
Fountain 57*	22
Fountain 58*	41
Fountain 59*	44
Fountain 60	<2.0 U
Fountain 61	14
Fountain 62	5.6

Fountain 63	4.1
Fountain 64	2.9
Fountain 65	<2.0 U
Fountain 67	<2.0 U
Fountain 68*	20
Fountain 69 High	<2.0 U
Fountain 69 Middle	<2.0 U
Fountain 69 Low	<2.0 U
Fountain 70	2.1
Fountain 71	2.0
Fountain 72	12
Fountain 73	<2.0 U
Fountain 74 High	<2.0 U
Fountain 74 Low	<2.0 U
Fountain 74 Dog	<2.0 U
Fountain 75 High	<2.0 U
Fountain 75 Middle	<2.0 U
Fountain 75 Low	<2.0 U
Fountain 76 High	<2.0 U
Fountain 76 Low	<2.0 U
Fountain 77	4.6
Fountain 78*	130
Fountain 79 High	<2.0 U
Fountain 79 Low	<2.0 U
Fountain 79 Dog	<2.0 U
Fountain 80	9.7

Lincoln Park Cultural Center

Indoor

Main Lobby	0.309 J
Basement by EC Room	0.165 J

Lincoln Park Margate

Indoor

South Hallway	0.154 J
---------------	---------

Lincoln Park South Athletic Fieldhouse

Indoor

Between Bathrooms	0.948 J
-------------------	---------

Lindbloom

Indoor

Main Lobby - High	0.189 J
Main Lobby - Low	0.15 J

Outdoor

Fountain 1 High*	16.4
Fountain 1 Low*	13.3

	Fountain 2	3.25
	Fountain 3*	27.4
Linden		
	Outdoor	
	Fountain 1	0.19 J
Limas		
	Outdoor	
	Fountain 1*	27.7
Little Venice		
	Outdoor	
	Fountain 1	1.69 J
Livingston		
	Outdoor	
	Fountain 1 High	0.511 J
	Fountain 1 Low	0.563 J
Logan : Outdoor		
	Fountain 1 High	<2.0 U
	Fountain 1 Low	<2.0 U
Lowe		
	Indoor	
	Main Lobby	0.347 J
	Outdoor	
	Fountain 1 High	7.95
	Fountain 1 Middle	1.17 J
	Fountain 1 Low	0.992 J
Loyola		
	Indoor	
	1st Floor Near Office	0.46 J
	2nd Floor Main Hallway	0.543 J
	Men's Locker Room	2.49 J
	Women's Locker Room	0.94 J
	Outdoor	
	Fountain 2*	38
	Fountain 3	<2.0 U
	Fountain 4	<2.0 U
	Fountain 5	14
	Fountain 6 High*	13
	Fountain 6 Low*	15
	Fountain 7*	26

Luella		
	Outdoor	
	Fountain 1*	37
	Fountain 2 High*	18
	Fountain 2 Low*	12
Luna		
	Outdoor	
	Fountain 1*	92.4
Lunt		
	Outdoor	
	Fountain 1	3.61 J
Maggie Daley		
	Indoor	
	Lobby - High	<0.120 U
	Lobby - Low	<0.120 U
	Kitchen Sink	<2.0 U
Magnolia		
	Outdoor	
	Fountain 1	2.43 J
Malus		
	Outdoor	
	Fountain 1 High*	34.8
	Fountain 1 Low*	36.3
Mandrake		
	Indoor	
	Kitchen Sink	<2.0 U
	Outdoor	
	Fountain 1 High	<2.0 U
	Fountain 1 Low	<2.0 U
	Fountain 2	<2.0 U
	Fountain 3	<2.0 U
	Fountain 4 High	<2.0 U
	Fountain 4 Low	<2.0 U
	Fountain 5	<2.0 U
	Fountain 6	<2.0 U
Mann		
	Indoor	
	Pool Deck	3.44 J
	Women's Upstairs Locker	2.2 J

Men's Upstairs Locker	2.58 J
Downstairs Near Washrooms	1.71 J

Outdoor

Fountain 1 Low	2.4
Fountain 1 High	<2.0 U
Fountain 2 Low	12
Fountain 2 High	12
Fountain 3 High	5.3
Fountain 3 Low	<2.0 U
Fountain 4 High	6.9
Fountain 4 Low	12

Maple

Outdoor

Fountain 1*	86.6
-------------	------

Maplewood

Outdoor

Fountain 1 High*	66
Fountain 1 Middle*	70
Fountain 1 Low*	52

Marquette

Indoor

East Washroom - High	0.142 J
East Washroom - Low	0.18 J
Women's Locker Room - High	0.714 J
Women's Locker Room - Low	0.512 J
Main Hallway - High*	27.4
Main Hallway - Low*	51.6
Basement	2.1 J
Kitchen Sink	<2.0 U

Outdoor

Fountain 1 High	3.41 J
Fountain 1 Middle	1.05 J
Fountain 1 Low	2.53 J
Fountain 2	2.57 J
Fountain 3 High	1.65 J
Fountain 3 Low	1.64 J
Fountain 4*	30.4
Fountain 5	1.61 J
Fountain 6	9.18
Fountain 7	8.37
Fountain 8	0.425 J
Fountain 9	0.535 J
Fountain 10 High	8.85
Fountain 10 Low	12.3

	Fountain 11	0.543 J
	Fountain 12 High	<0.120 U
	Fountain 12 Low	<0.120 U
Marshfield		
	Outdoor	
	Fountain 1 High	1.52 J
	Fountain 1 Low	1.57 J
Mason		
	Outdoor	
	Fountain 1	<0.120 U
	Fountain 2	<0.120 U
Matanky		
	Outdoor	
	Fountain 1	8
Mather		
	Indoor	
	Main Lobby	0.379 J
	Outdoor	
	Fountain 1 High	0.316 J
	Fountain 1 Middle	0.325 J
	Fountain 1 Low	0.302 J
	Fountain 3	5.62
Mayfair		
	Indoor	
	By Women's Washroom	2.77 J
	Outdoor	
	Fountain 1 High	0.316 J
	Fountain 1 Middle	0.308 J
	Fountain 1 Low	0.343 J
McFetridge		
	Indoor	
	Men's Locker Room	0.227 J
	Women's Locker Room	0.256 J
	Pool Deck - High	<0.120 U
	Pool Deck - Low	0.27 J
McGuane		
	Indoor	
	Near Gym	0.481 J
	Pool Area	<0.120 U
	Balcony by Table Tennis	0.717 J

Outside Meeting Room	1.0 J
Kitchen Sink	2.3
Outdoor	
Fountain 1 High	14.6
Fountain 1 Low	12.5
Fountain 2 High*	52.9
Fountain 2 Middle *	53.7
Fountain 2 Low*	57.2
Fountain 3 High*	46
Fountain 3 Low*	54.5
Fountain 4 High	1.68 J
Fountain 4 Low	1.37 J
Fountain 5 High	0.555 J
Fountain 5 Low	0.662 J

McInerney

Outdoor	
Fountain 1	<0.120 U

McKiernan

Indoor	
Club Room - High	1.01 J
Club Room - Low	0.579 J
Outdoor	
Fountain 1*	23.6

McKinley

Indoor	
Outside Men's Room	0.888 J
Outside Women's Room	1.14 J
Outside Gymnastics Center	1.64 J
Outside Gym	6.35
Kitchen Sink	<2.0 U
Outdoor	
Fountain 1*	16.4
Fountain 2	11.8
Fountain 3*	26
Fountain 4	1.48
Fountain 5	1.04

Mellin

Outdoor	
Fountain 1 High	4.93 J
Fountain 1 Middle	6.3
Fountain 1 Low	5.17

Memorial Playlot

Outdoor

Fountain 1 High*	7.96
Fountain 1 Low*	59.8
Fountain 2	8.31

Merrill

Outdoor

Fountain	<2.0 U
----------	--------

Merrimac

Indoor

Hall Near Lobby	0.956 J
Hall Furthest from Lobby	0.977 J

Outdoor

Fountain 1 High	0.814 J
Fountain 1 Low	0.692 J
Fountain 2 High	0.676 J
Fountain 2 Middle	0.588 J
Fountain 2 Low	0.645 J
Fountain 3 High	0.858 J
Fountain 3 Low	2.33 J

Merryman

Outdoor

Fountain 1 High	<2.0 U
Fountain 1 Middle	<2.0 U
Fountain 1 Low	<2.0 U

Metcalf

Outdoor

Fountain 1 High*	22
Fountain 1 Low*	27
Fountain 2*	16
Fountain 3*	41

Meyering

Indoor

Near Entrance	4.59 J
---------------	--------

Outdoor

Fountain 1	0.594 J
Fountain 2 High	0.738 J
Fountain 2 Low	0.762 J

Miami

Outdoor

Fountain 1 High	1.31 J
Fountain 1 Middle	1.28 J

Fountain 1 Lowe	1.37 J
Micek	
Outdoor	
Fountain 1 High	<0.120 U
Fountain 1 Middle	<0.120 U
Fountain 1 Low	<0.120 U
Midway Plaisance	
Indoor	
Kitchen Sink	<2.0 U
Outdoor	
Fountain 1	0.746 J
Fountain 2	0.655 J
Fountain 4	0.146 J
Fountain 5*	54.9
Fountain 6	0.809 J
Miller	
Outdoor	
Fountain 1 High*	21
Fountain 1 Low*	22
Minuteman	
Outdoor	
Fountain 1 High*	15.7
Fountain 1 Middle*	15.7
Fountain 1 Low*	15.7
Fountain 2*	31.7
Moccasin Ranch	
Outdoor	
Fountain 1*	59.8
Monticello	
Outdoor	
Fountain 1	1.01
Monument	
Outdoor	
Fountain 1*	21.6
Moore	
Indoor	
Lobby - High	<0.120 U
Lobby - Low	<0.120 U
Outdoor	

Fountain 1 High	<0.120 U
Fountain 1 Middle	<0.120 U
Fountain 1 Low	<0.120 U

Moran

Indoor	
Club Room	1.82 J
Outdoor	
Fountain 1*	73.1
Fountain 2	1.92
Fountain 3*	49.4

Morgan Field

Outdoor	
Fountain 1	10.6

Morgan Park Sports Center

Indoor	
Lobby - High	<0.120 U
Lobby - Low	<0.120 U
Upstairs - High	<0.120 U
Upstairs - Low	<0.120 U

Mozart

Indoor	
Lobby	0.587 J
Hallway by Bathrooms	0.272 J
Outdoor	
Fountain 1*	16.6

Mt. Greenwood

Indoor	
Main Hallway	15.1
Follow-Up #1	0.271 J
Follow-Up #2	0.383 J
Follow-Up #3	0.518 J
Follow-Up #4	0.684 J
Follow-Up #5	0.670 J
Follow-Up #6	0.638 J
Women's Locker Room	2.55 J
Kitchen Sink	<2.0 U
Outdoor	
Fountain 1 High*	35.8
Fountain 1 Low*	38.7
Fountain 2 High	2.49 J
Fountain 2 Middle	2.97 J
Fountain 2 Low	2.31 J

	Fountain 3*	46.7
	Fountain 4 High	7.1
	Fountain 4 Low	5.09
Mulberry		
	Outdoor	
	Fountain 1	11.5
Munroe		
	Indoor	
	Club Room	9.71
	Outdoor	
	Fountain 1 High	0.472 J
	Fountain 1 Middle	0.592 J
	Fountain 1 Low	0.577 J
	Fountain 2	3.41 J
Murray		
	Indoor	
	Club Room East*	88.2
	Club Room West*	78.2
Nichols		
	Outdoor	
	Fountain 1 High	<0.120 U
	Fountain 1 Low	<0.120 U
	Fountain 2	1.32 J
	Fountain 3*	157
	Fountain 4	2.21 J
Ninebark		
	Outdoor	
	Fountain 1	20
Noethling		
	Outdoor	
	Fountain 1*	18
	Fountain 2 Dog	9.7
Normandy		
	Indoor	
	Club Room	10.3
	Outdoor	
	Fountain 1*	59.4
	Fountain 2 High	7.89
	Fountain 2 Middle	9.29
	Fountain 2 Low	6.33

North Mayfair		
Outdoor		
Fountain 1*		37.2
North Park Village Nature Center		
Indoor		
Hallway East		<0.120 U
Northerly Island		
Outdoor		
Fountain 1		6.1
Fountain 2 High		<2.0 U
Fountain 2 Low		<2.0 U
Fountain 3 High		<2.0 U
Fountain 3 Low		<2.0 U
Norwood Park		
Indoor		
Lobby		0.273 J
Fitness Center		<0.120 U
Women's Locker Room*		23.5
Kitchen Sink		2.1
Outdoor		
Fountain 1 High		0.332 J
Fountain 1 Low		0.228 J
Fountain 1 Dog		0.239 J
Fountain 2 High*		20.5
Fountain 2 Low*		16
Fountain 3		3.86 J
Fountain 4		0.174 J
Fountain 5		2.21 J
Fountain 6*		20.5
Fountain 7 High*		39.2
Fountain 7 Low*		14.1
Nottingham		
Outdoor		
Fountain 1 High		1.54 J
Fountain 1 Low		2.0 J
Oakdale		
Indoor		
Front Entrance		<0.120 U
Kitchen Sink		<2.0 U
Outdoor		
Fountain 1 High		<0.120 U

Fountain 1 Low	0.164 J
Fountain 2 High	3.7 J
Fountain 2 Low	3.73 J
Fountain 3*	141

Ogden

Indoor	
Lobby - High	0.525 J
Lobby - Low	<0.120 U
Outdoor	
Fountain 2	5.96
Fountain 3 High	<0.120 U
Fountain 3 Low	<0.120 U
Fountain 4 High	0.143 J
Fountain 4 Low	0.133 J
Fountain 5	3.32 J

O'Hallaren

Indoor	
Kitchen Sink	3.9
Outdoor	
Fountain 1 High*	15.1
Fountain 1 Middle*	15
Fountain 1 Low*	12.3
Fountain 2 High	3.35 J
Fountain 2 Low	3.39 J

Ohio

Outdoor	
Fountain 1 High	0.571 J
Fountain 1 Middle	0.665 J
Fountain 1 Low	0.57 J

Ohio and Harding

Outdoor	
Fountain 1 High*	22.7
Fountain 1 Low*	21.3

Olympia

Indoor	
Front Lobby Test 1	2.53 J
Front Lobby Test 2	3.7
Middle of Building	2.5
Kitchen Sink	11
Outdoor	
Fountain 1*	34.3

Fountain 2	2.18 J
Fountain 3*	43.9

Oriole

Indoor	
Inside Front Entrance	0.822 J
Outdoor	
Fountain 1	6.18
Fountain 2 High	2.07 J
Fountain 2 Middle	4.44 J
Fountain 2 Low	3.76 J
Fountain 3*	36.5
Fountain 4	2.52 J
Fountain 5	4.54 J
Fountain 6 High*	26.8
Fountain 6 Low*	20.7

Owens

Indoor	
Fitness Area	<0.120 U
Hallway	<0.120 U
Outdoor	
Fountain 1	<2.0
Fountain 2 High	2.2
Fountain 2 Middle	2.3
Fountain 2 Low	2.2

Oz

Outdoor	
Fountain 1 High*	18
Fountain 1 Low*	19
Fountain 2 High*	33
Fountain 2 Middle*	29
Fountain 2 Low*	18
Fountain 3 High	4.2
Fountain 3 Middle	4.2
Fountain 3 Low	4.9

Packingtown

Outdoor	
Fountain 1*	311

Palmer

Indoor	
Main Lobby	0.19 J
Main Level Hallway	0.267 J

Outdoor

Fountain 1 High	0.211 J
Fountain 1 Low	0.183 J
Fountain 2 High	<0.120 U
Fountain 2 Low	0.152 J
Fountain 3 High	<0.120 U
Fountain 3 Low	<0.120 U
Fountain 4	14.6
Fountain 5*	15.1
Fountain 6	0.513 J
Fountain 7	0.921 J
Fountain 8*	22.9

Palmer Ceramics Building

Indoor

Club Room	2.24 J
-----------	--------

Palmer Men's Gym Building

Indoor

Lobby Area	<0.120 U
------------	----------

Palmer Square

Outdoor

Fountain 1 High	0.266 J
Fountain 1 Middle	0.343 J
Fountain 1 Low	0.209 J
Fountain 2	0.426 J

Palmisano

Outdoor

Fountain 1 High	0.156 J
Fountain 1 Low	0.164 J

Park 399

Outdoor

Fountain 1 High	0.231 J
Fountain 1 Low	0.177 J

Park 442

Outdoor

Fountain 1*	49.2
-------------	------

Park 500

Outdoor

Fountain 1	<0.120 U
------------	----------

Park 514

Outdoor

Fountain 1 High	0.564 J
Fountain 1 Low	0.535 J

Park 517

Outdoor

Fountain 1 High	<2.0 U
Fountain 1 Low	<2.0 U

Park 519

Outdoor

Fountain 1 High	1.19 J
Fountain 1 Middle	0.461 J
Fountain 1 Low	0.533 J

Park 529

Outdoor

Fountain 1 High	<2.0 U
Fountain 1 Low	<2.0 U

Park 534

Outdoor

Fountain 1 High	0.757 J
Fountain 1 Low	0.419 J
Fountain 2 High	<0.120 U
Fountain 2 Low	<0.120 U

Park 535

Outdoor

Fountain 1	<2.0 U
------------	--------

Park 540

Outdoor

Fountain 1 High	<2.0 U
Fountain 1 Middle	<2.0 U
Fountain 1 Low	<2.0 U
Fountain 2 High	<2.0 U
Fountain 2 Middle	<2.0 U
Fountain 2 Low	<2.0 U

Park 546

Outdoor

Fountain 1 High	<2.0 U
Fountain 1 Low	2.6
Fountain 2 High	<2.0 U
Fountain 2 Low	<2.0 U
Fountain 3 Dog	<2.0 U

Fountain 4 High	<2.0 U
Fountain 4 Low	<2.0 U
Fountain 5 High	2.6
Fountain 5 Low	2

Park 551

Outdoor

Fountain 1 High	<2.0 U
Fountain 1 Middle	<2.0 U
Fountain 1 Low	<2.0 U
Fountain 2 Dog	<2.0 U

Park 552

Outdoor

Fountain 1 High	5.16
Fountain 1 Middle	1.22 J

Park 556

Outdoor

Fountain 1 High	<2.0 U
Fountain 1 Low	<2.0 U
Fountain 1 Middle	<2.0 U

Park 568

Outdoor

Fountain 1 High	<0.120 U
Fountain 1 Middle	<0.120 U

Park 569

Outdoor

Fountain 1 High	<2.0 U
Fountain 1 Low	<2.0 U
Fountain 1 Dog	<2.0 U

Park 572

Outdoor

Fountain 1 High	<0.120 U
Fountain 1 Middle	<0.120 U
Fountain 1 Low	<0.120 U
Fountain 2 High	0.284 J
Fountain 2 Middle	0.32 J
Fountain 2 Low	0.39 J
Fountain 3 High	0.186 J
Fountain 3 Middle	0.248 J
Fountain 3 Low	0.167 J

Park 574

Outdoor

Fountain 1 High	<2.0 U
Fountain 1 Middle	<2.0 U
Fountain 1 Low	<2.0 U

Park View

Outdoor

Fountain 1 High*	120
Fountain 1 Low*	109

Park West

Outdoor

Fountain 1 High*	83
Fountain 1 Low*	66

Parsons

Outdoor

Fountain 1 High	0.629 J
Fountain 1 Middle	0.514 J
Fountain 1 Low	0.493 J

Paschen

Outdoor

Fountain 1*	77
-------------	----

Pasteur

Indoor

Club Room	<0.120 U
-----------	----------

Outdoor

Fountain 1	5.03
Fountain 2*	30.1

Periwinkle

Outdoor

Fountain 1 High*	77.4
Fountain 1 Low*	67.3

Peterson

Indoor

Hallway East	2.45 J
2nd Floor	0.343 J

Outdoor

Fountain 1*	50.5
Fountain 2*	53.1
Fountain 3	2.61 J

Pietrowski

Outdoor

Fountain 1 - High	7.7
Fountain 1 - Low	7.8

Pine

Outdoor

Fountain 1 High	2.8
Fountain 1 Low	2.8

Ping Tom

Indoor

Near Washrooms	<0.120 U
Fitness Center	<0.120 U
Pool Deck Women's	<0.120 U
Pool Deck Men's	<0.120 U
Kitchen Sink	<2.0 U

Outdoor

Fountain 1 High	2.1
Fountain 1 Low	2.1
Fountain 2 High	<2.0 U
Fountain 2 Low	<2.0 U
Fountain 3 High	<2.0 U
Fountain 3 Low	<2.0 U
Fountain 4 High	<2.0 U
Fountain 4 Low	<2.0 U

Piotrowski

Indoor

Main Lobby - High	0.128 J
Main Lobby - Low	<0.120 U
Lower Level Nera Fitness - High	<0.120 U
Lower Level Nera Fitness - Low	0.271 J
Pool Area	<0.120 U
Men's Locker Room	0.481 J
Women's Locker Room	0.363 J
Pool Deck	3.43 J
Women's Washroom	0.153 J
Men's Washroom	1.12 J

Outdoor

Fountain 1 High	<0.120 U
Fountain 1 Low	<0.120 U
Fountain 2 High	<0.120 U
Fountain 2 Middle	<0.120 U
Fountain 2 Low	<0.120 U
Fountain 3 High*	12.5
Fountain 3 Low*	22
Fountain 4 High*	52.6

Fountain 4 Low*	31.6
Fountain 5 High	1.75 J
Fountain 5 Low	1.22 J
Fountain 6 High*	12
Fountain 6 Low*	15.7

Pleasant Point

Outdoor

Fountain 1 High	2.16 J
Fountain 1 Middle	2.55 J
Fountain 1 Low	2.16 J

Poplar

Outdoor

Fountain 1 High*	15
Fountain 1 Low*	15

Portage

Outdoor

Fountain 1 High*	92.4
Fountain 1 Low*	102
Fountain 2 High	0.372 J
Fountain 2 Low	0.345 J
Fountain 2 Dog	0.575 J
Fountain 3*	59
Fountain 4 High	1.83 J
Fountain 4 Low	1.58 J
Fountain 5 High	1.85 J
Fountain 5 Low	2.43 J
Fountain 6*	39.5
Fountain 7 High*	7.07
Fountain 7 Low*	15.7
Fountain 8 High	0.269 J
Fountain 8 Middle	0.129 J
Fountain 8 Low	0.159 J
Fountain 9	6.73
Fountain 10*	36.8
Fountain 11*	22.3
Fountain 12 East*	23.2
Fountain 12 South*	24.5
Fountain 12 West*	23.3
Fountain 12 North *	29.9
Fountain 13*	75.8
Fountain 14*	43.7

Portage Senior Center

Indoor

	Lobby - High	0.149 J
	Lobby - Low	0.142 J
Pottawatomie		
Indoor		
	Hallway by Bathroom	0.293 J
Outdoor		
	Fountain 1 High	4.5
	Fountain 1 Low	8.7
	Fountain 1 Dog	<2.0
	Fountain 2	3.7
	Fountain 3*	30
	Fountain 4	2.8
	Fountain 5 High	<2.0
	Fountain 5 Low	<2.0
Pritzker		
Outdoor		
	Fountain 1 High	<2.0 U
	Fountain 1 Low	<2.0 U
Privet		
Outdoor		
	Fountain 1*	130
Prospect Gardens		
Outdoor		
	Fountain 1	3.3 J
	Fountain 2*	23.3
Pulaski		
Indoor		
	East Corridor	2.32 J
	West Corridor	0.122 J
	Pool Deck	1.5 J
	Outside Pool Area	0.236 J
	Kitchen Sink	2.9
Outdoor		
	Fountain 1	0.582 J
	Fountain 2	1.43 J
	Fountain 3	<0.120
	Fountain 5 High	1.19 J
	Fountain 5 Low	0.635 J
Railroad Junction		
Outdoor		
	Fountain 1*	27.7

Rainbow Beach

Indoor

Near Gym	<0.120 U
Fitness Center	<0.120 U

Outdoor

Fountain 1	<2.0 U
Fountain 2	<2.0 U
Fountain 3	2.6
Fountain 4	<2.0 U
Fountain 5	<2.0 U
Fountain 6	7.3
Fountain 7*	40

Rainer

Outdoor

Fountain 1	0.207 J
Fountain 2	0.237 J
Fountain 3	10.8

Ravenswood Manor

Outdoor

Fountain 1	0.128 J
------------	---------

Renaissance

Outdoor

Fountain 1	<0.120 U
------------	----------

Revere

Indoor

Main Lobby	0.885 J
Basement by Locker Rooms*	17.6

Outdoor

Fountain 1	<0.120 U
Fountain 2*	32.3
Fountain 3 High	0.16 J
Fountain 3 Middle	0.192 J
Fountain 3 Low	0.298 J
Fountain 4	13.8

Revere Boys & Girls Club

Indoor

Game Room	0.351 J
Kitchen	0.603 J

Reyes

Outdoor

	Fountain 1*	41
Ridge		
	Indoor	
	Entrance Near Counter	0.123 J
	Outside 2nd Floor Gym - High	0.33 J
	Outside 2nd Floor Gym - Low	0.341 J
	Pool Area - High	8.64
	Pool Area - Low	9.05
	Kitchen Sink	5.1
	Outdoor	
	Fountain 2	12
	Fountain 3*	104
Riis		
	Indoor	
	Entrance	0.516 J
	Outdoor	
	Fountain 2	13.1
	Fountain 3	2.64 J
	Fountain 4*	15.4
	Fountain 5	2.79 J
	Fountain 6	8.36
	Fountain 7	10.1
	Fountain 8	5.36
	Fountain 9	0.308 J
	Fountain 10*	27.7
	Fountain 11 High	<0.120 U
	Fountain 11 Low	<0.120 U
	Fountain 12 High*	70.8
	Fountain 12 Low*	71.7
	Fountain 13	0.179 J
	Fountain 14	<0.120 U
	Fountain 15	<0.120 U
	Fountain 16	2.21 J
River		
	Indoor	
	Outside Bathrooms	0.236 J
	Main Lobby	<0.120 U
	Outdoor	
	Fountain 1	0.462 J
	Fountain 2 High	0.219 J
	Fountain 2 Low	0.445 J
	Fountain 3	0.17 J
	Fountain 4 High	<0.120 U
	Fountain 4 Middle	<0.120 U

Fountain 4 Low	<0.120 U
Fountain 5 High	<0.120 U
Fountain 5 Low	<0.120 U
Fountain 5 Dog	<0.120 U
Fountain 6	2.68 J
Fountain 7	4.13 J
Fountain 8 High	0.593 J
Fountain 8 Low	0.654 J

Roberts Square

Outdoor

Fountain 1	3.72 J
------------	--------

Robichaux

Indoor

Lobby - High	1.01 J
Lobby - Low	0.46 J
Women's Locker Room	4.12 J
Men's Locker Room	7.46

Outdoor

Fountain 1	11.3
Fountain 2	0.782 J
Fountain 3*	38.4

Robinson

Indoor

Main Lobby	4
Kitchen Sink	<2.0 U

Outdoor

Fountain 1 High	0.635 J
Fountain 1 Middle	4.26 J
Fountain 1 Low	2.99 J
Fountain 2	14.6

Rogers

Indoor

Main Lobby	0.154 J
------------	---------

Outdoor

Fountain 1*	28.3
Fountain 2	14.7
Fountain 3	5.19
Fountain 4*	16

Rogers Beach

Outdoor

Fountain 1 High*	37
Fountain 1 Low*	35

Ronan

Outdoor

Fountain 1 High	0.261 J
Fountain 1 Low	0.145 J
Fountain 1 Dog	0.204 J
Fountain 2 High	0.194 J
Fountain 2 Low	0.229 J

Roosevelt

Outdoor

Fountain 1*	22
-------------	----

Rosedale

Indoor

Lobby	0.819 J
-------	---------

Outdoor

Fountain 1 High	2.28 J
Fountain 1 Middle	0.479 J
Fountain 1 Low	0.546 J
Fountain 2	0.99 J

Rosenblum

Outdoor

Fountain 1 High	1.99 J
Fountain 1 Low	0.487 J
Fountain 2 High	2.6 J
Fountain 2 Low	2.06 J
Fountain 3 High	0.941 J
Fountain 3 Low	0.842 J

Rowan

Indoor

By East Gym Doors	0.39 J
By West Gym Doors	0.489 J

Outdoor

Fountain 1*	67
Fountain 2*	17
Fountain 3 High	<2.0 U
Fountain 3 Low	<2.0 U

Russell Square

Indoor

Northwest Hallway	0.721 J
-------------------	---------

Outdoor

Fountain 1*	76
Fountain 2*	18

Fountain 4*	17
Fountain 5	3
Fountain 6	13

Rutherford Sayre

Indoor	
Outside Gym	8.28
Outdoor	
Fountain 1 High	0.304 J
Fountain 1 Low	0.349 J
Fountain 2 High	<0.120 U
Fountain 2 Middle	<0.120 U
Fountain 2 Low	<0.120 U
Fountain 3	10.1

Sacramento

Outdoor	
Fountain 1 High*	19
Fountain 1 Low*	19.5

Sauganash

Indoor	
Hallway	0.474 J
Outdoor	
Fountain 1	1.28 J
Fountain 2 High	<0.120 U
Fountain 2 Middle	<0.120 U
Fountain 2 Low	<0.120 U
Fountain 3	1.12 J

Schaefer

Outdoor	
Fountain 1*	34

Schreiber

Outdoor	
Fountain 1 High	3.3
Fountain 1 Middle	3.2
Fountain 1 Low	3.5
Fountain 2 High	<2.0 U
Fountain 2 Low	<2.0 U

Scottsdale

Indoor	
Hallway by Gym	0.531 J
Outdoor	
Fountain 1	6.44

Seneca

Outdoor

Fountain 1 High	<2.0 U
Fountain 1 Low	<2.0 U

Senka

Outdoor

Fountain 1 High	<0.120 U
Fountain 1 Middle	0.168 J
Fountain 1 Low	0.482 J
Fountain 2 High	0.168 J
Fountain 2 Middle	0.202 J
Fountain 2 low	0.295 J
Fountain 3 High	<0.120 U
Fountain 3 Middle	0.179 J
Fountain 3 Low	<0.120 U
Fountain 4 High	0.37 J
Fountain 4 Low	0.263 J

Senn

Outdoor

Fountain 1 High	<2.0 U
Fountain 1 Low	<2.0 U
Fountain 2 High*	26
Fountain 2 Low*	8.5
Fountain 3 High*	35
Fountain 3 Low*	36
Fountain 4 high	6.6
Fountain 4 Low	7.2
Fountain 5 High	<2.0 U
Fountain 5 Low	<2.0 U

Seward

Indoor

Main Lobby	<0.120 U
Kitchen Sink	<2.0 U

Outdoor

Fountain 1 High	<2.0 U
Fountain 1 Low	<2.0 U
Fountain 1 Dog	<2.0 U
Fountain 2*	110
Fountain 3	<2.0 U

Shabonna

Indoor

Lobby	0.55 J
-------	--------

Basement by TR Room	<0.120 U
Women's Locker Room	0.96 J
Men's Locker Room	<0.120 U

Outdoor

Fountain 1 High	0.243J
Fountain 1 Middle	0.227 J
Fountain 1 Low	0.208 J
Fountain 2 High*	16.8
Fountain 2 Low*	17
Fountain 3 High	8.25
Fountain 3 Low	8.41
Fountain 4 High	0.716 J
Fountain 4 Low	0.718 J

Shedd

Indoor

By Gym	0.679 J
By Lobby	1.33 J
Kitchen Sink	<2.0 U

Outdoor

Fountain 1	3.73 J
------------	--------

Sheil

Indoor

1st Floor by Restrooms	0.489 J
2nd Floor by Theater Room	0.962 J
Kitchen Sink	<2.0 U

Outdoor

Fountain 1	<2.0 U
------------	--------

Sheridan

Indoor

1st Floor Lobby	<0.120 U
2nd Floor North Gym Entrance	13.1
2nd Floor South Gym Entrance	1.49 J
Men's Locker Room	1.01 J
Pool Area - High	0.465 J
Pool Area - Low	0.46 J
Kitchen Sink	<2.0 U

Outdoor

Fountain 1 High*	35
Fountain 1 Low*	31
Fountain 2 High	3.3
Fountain 2 Middle	3.3
Fountain 2 Low	3.2

Sherman

Indoor

Main Lobby	0.241 J
Women's Locker Room	<0.120 U
Men's Locker Room	0.152 J

Outdoor

Fountain 1 High*	58.6
Fountain 1 Low*	69
Fountain 2 High	<0.120 U
Fountain 2 Middle	<0.120 U
Fountain 2 Low	<0.120 U
Fountain 3	8.32
Fountain 4*	19.6
Fountain 5*	69.3
Fountain 6 High	6.14
Fountain 6 Low	7.55

Sherwood

Indoor

Lobby	1.54 J
Kitchen Sink	<2.0 U

Outdoor

Fountain 1	0.246 J
Fountain 2	<0.120 U
Fountain 3 High	0.132 J
Fountain 3 Low	0.156 J

Simons

Indoor

Lobby	0.482 J
-------	---------

Outdoor

Fountain 1 High*	16.6
Fountain 1 Low*	18.9

Skinner

Indoor

Lobby	0.195 J
Kitchen Sink	<2.0 U

Outdoor

Fountain 1 High	<2.0 U
Fountain 1 Low	<2.0 U
Fountain 1 Dog	<2.0 U
Fountain 2 High	<2.0 U
Fountain 2 Middle	<2.0 U
Fountain 2 Low	<2.0 U
Fountain 3 High	<2.0 U
Fountain 3 Low	<2.0 U
Fountain 3 Dog	<2.0 U

Smith (Joseph Higgins)

Indoor

East End	1.48 J
West End	0.862 J
Kitchen Sink	<2.0 U

Outdoor

Fountain 1 High*	23.9
Fountain 1 Middle*	23.7
Fountain 1 Low*	23.2
Fountain 2*	21.9
Fountain 3	3.28 J
Fountain 4	7.69

Smith (Wendell)

Indoor

Main Lobby	0.831 J
------------	---------

Outdoor

Fountain 1	2.49 J
Fountain 2*	67.5
Fountain 3*	30.9

Snapping Turtle

Outdoor

Fountain 1	13.2
------------	------

Snowberry

Outdoor

Fountain 1	7.31
------------	------

South Lakeview

Outdoor

Fountain 1 High*	18
Fountain 1 Low*	17

South Shore Cultural Center

Indoor

Basement Near Restrooms	<0.120 U
Near Art Gallery	0.359 J
Near Restaurant	0.373 J
Mezzanine Near Men's Room	1.2 J
Oak Room Sink	<2.0 U
CAN Sink	<2.0 U
Dinning Room Sink	<2.0 U

Spikings Farm

Outdoor

	Fountain 1 High	8.93
	Fountain 1 Low	9.91
Spruce		
	Outdoor	
	Fountain 1*	24.8
Stanton		
	Indoor	
	Pool Area	<0.120 U
	Gym Entrance - High	<0.120 U
	Gym Entrance - Low	<0.120 U
	Kitchen Sink	<2.0 U
	Outdoor	
	Fountain 1	<2.0 U
Starr		
	Outdoor	
	Fountain 1 High	<2.0 U
	Fountain 1 Middle	<2.0 U
	Fountain 1 Low	<2.0 U
Stars and Stripes		
	Outdoor	
	Fountain 1 High	5.88
	Fountain 1 Middle	7.58
	Fountain 1 Low	6.66
Stout		
	Outdoor	
	Fountain 1 High*	169
	Fountain 1 Low*	174
	Fountain 2*	19.9
Strohacker		
	Outdoor	
	Fountain 1*	39.6
Sumac		
	Outdoor	
	Fountain 1 High	9.2
	Fountain 1 Middle	9.6
	Fountain 1 Low	9.0
Sun-Yet Sen		
	Outdoor	
	Fountain 1 High	<2.0 U

Fountain 1 Low	<2.0 U
Supera	
Outdoor	
Fountain 1 High	6.9
Fountain 1 Middle	6.7
Fountain 1 Low	6.6
Superior	
Outdoor	
Fountain 1 High*	15.4
Fountain 1 Low*	13.3
Sweet Clover	
Outdoor	
Fountain 1 High	5.73
Fountain 1 Low	6.4
Sycamore	
Outdoor	
Fountain 1*	142
Taylor	
Indoor	
Lobby	<0.120 U
1st Floor Hallway	0.191 J
2nd Floor Hallway	1.82 J
Kitchen Sink	<2.0 U
Outdoor	
Fountain 1	14
Fountain 2	9.5
Taylor Lauridsen	
Indoor	
Lobby	<0.750 U
Fitness Center	0.198 J
Kitchen Sink	<2.0 U
Outdoor	
Fountain 1 High	<0.120 U
Fountain 1 Middle	0.157 J
Fountain 1 Low	0.127 J
Fountain 2	14.8
Throop	
Outdoor	
Fountain 1	<2.0 U

Thuis		
	Outdoor	
	Fountain 1*	125
Till-Mobley		
	Outdoor	
	Fountain 1	13.4
Tilton		
	Outdoor	
	Fountain 1	<0.120 U
Touhy		
	Indoor	
	Game Room	1.04 J
	Outdoor	
	Fountain 1 High	<2.0
	Fountain 1 Middle	<2.0
	Fountain 1 Low	<2.0
	Fountain 2 High*	52
	Fountain 2 Low*	100
	Fountain 3*	73
Touhy-Herbert		
	Outdoor	
	Fountain 1	12
	Fountain 2	3.9
Trebes		
	Outdoor	
	Fountain 2	<2.0 U
Triangle		
	Outdoor	
	Fountain 1 High	<2.0
	Fountain 1 Low	9
Trumbull		
	Indoor	
	Main Lobby	<0.120 U
	2nd Floor Near Washrooms	0.247 J
	North Lobby Near Gym	1.28 J
	Men's Locker Room	4.90 J
	Outdoor	
	Fountain 1	<2.0 U
	Fountain 2	<2.0 U
	Fountain 4	<2.0 U

Fountain 5 High	<2.0 U
Fountain 6 High	3.3
Fountain 6 Low	9.4

Tuley

Indoor

Lobby - High	0.424 J
Lobby - Low	0.609 J
Men's Locker Room	9.75
Women's Locker Room	1.97 J

Outdoor

Fountain 1	4.49 J
Fountain 2 High	0.291 J
Fountain 2 Low	0.304 J
Fountain 3	<0.120 U
Fountain 4	10.3
Fountain 5	0.153 J
Fountain 6	0.389 J
Fountain 7 High	<0.120 U
Fountain 7 Middle	0.296 J
Fountain 7 Low	<0.120 U

Union

Indoor

2nd Floor Lobby	1.77 J
Near Game Room	5.98
1st Floor Lobby	0.235 J
Kitchen Sink	<2.0 U

Outdoor

Fountain 1*	77
Fountain 2 High	<2.0 U
Fountain 2 Middle	<2.0 U
Fountain 2 Low	<2.0 U
Fountain 3	<2.0 U
Fountain 4	<2.0 U

Union Gym Building

Indoor

Near Entrance	<0.120 U
---------------	----------

Unity

Outdoor

Fountain 1	<0.120 U
Fountain 2	0.248 J
Fountain 3	0.157 J
Fountain 4	1.08 J

Valley Forge

Indoor

Lobby - High	<0.120 U
Lobby - Low	<0.120 U
Fitness Center - High	0.17 J
Fitness Center - Low	0.135 J

Outdoor

Fountain 1*	36.5
Fountain 2 High	3.66
Fountain 2 Middle	3.43
Fountain 2 Low	4.56

Veteran's Memorial

Indoor

Club Room	2.85 J
-----------	--------

Outdoor

Fountain 1 High	<2.0 U
Fountain 1 Middle	<2.0 U
Fountain 1 Low	<2.0 U

Violet

Outdoor

Fountain 1	3.41 J
------------	--------

Vittum

Indoor

1st Floor by Office - High	0.521 J
1st Floor by Office - Low	0.459 J
2nd Floor by Special Rec - High	0.542 J
2nd Floor by Special Rec - Low	0.481 J
Kitchen Sink	<2.0 J

Outdoor

Fountain 1 High	10.5
Fountain 1 Low	9.19
Fountain 2 High	12.4
Fountain 2 Middle	11.8
Fountain 2 Low	10.3
Fountain 3 High	12.4
Fountain 3 Low	13.5

Vogle

Outdoor

Fountain 1*	51.6
-------------	------

Wallace

Outdoor

Fountain 1 High	4.03 J
-----------------	--------

	Fountain 1 Low	4.45 J
Walnut		
	Outdoor	
	Fountain 1 High*	34.9
	Fountain 1 Low*	33.8
Walsh		
	Outdoor	
	Fountain 1 High	<2.0 U
	Fountain 1 Middle	<2.0 U
	Fountain 1 Low	<2.0 U
	Fountain 2 High	<2.0 U
	Fountain 2 Middle	<2.0 U
	Fountain 2 Low	<2.0 U
	Fountain 3 High	<2.0 U
	Fountain 3 Middle	<2.0 U
	Fountain 3 Low	<2.0 U
	Fountain 4 High*	15
	Fountain 4 Low*	13
Wang		
	Outdoor	
	Fountain 1 High	<2.0 U
	Fountain 1 Middle	<2.0 U
	Fountain 1 Low	<2.0 U
Ward		
	Outdoor	
	Fountain 1 High	<2.0 U
	Fountain 1 Low	<2.0 U
	Fountain 1 Dog	<2.0 U
	Fountain 2 High	<2.0 U
	Fountain 2 Middle	<2.0 U
	Fountain 2 Low	<2.0 U
Warren		
	Indoor	
	Main Lobby	0.24 J
	Outside Locker Room	1.43 J
	Outdoor	
	Fountain 1*	41
	Fountain 2*	186
	Fountain 3*	163
	Fountain 3.5*	21.4
	Fountain 3.7*	19.3
	Fountain 4*	50.4

Fountain 5*	17.7
Fountain 6*	40.9

Washington (George)

Indoor

1st Floor Near Men's Room	1.21 J
1st Floor Near Women's Room	1.27 J
1st Floor North Hallway	1.43 J
Women's Locker Room	1.18 J
Men's Locker Room	3.32 J
Dance Studio	0.629 J

Outdoor

Fountain 1	3.84 J
Fountain 2	4.85 J
Fountain 3*	24
Fountain 4*	22.7
Fountain 5*	15.4
Fountain 6*	46.6
Fountain 7	5.13
Fountain 8	0.424 J
Fountain 9*	35.9
Fountain 10	5.04
Fountain 11	0.749 J
Fountain 12	9
Fountain 13*	30.8
Fountain 14 High	0.177 J
Fountain 14 Low	0.191 J
Fountain 15 High	<0.120 U
Fountain 15 Middle	<0.120 U
Fountain 15 Low	<0.120 U
Fountain 16*	24.9
Fountain 18 High	0.12 J
Fountain 18 Low	0.243 J

Washington (Harold)

Outdoor

Fountain 1	2.09 J
Fountain 2	<0.120 U
Fountain 3	1.66 J

Washington Memorial

Outdoor

Fountain 1 High	<2.0 U
Fountain 1 Low	<2.0 U

Washington Square

Outdoor

Fountain 1 High	<2.0 U
Fountain 1 Low	<2.0 U

Washtenaw

Indoor

Club Room*	21
------------	----

Outdoor

Fountain 1 High*	10.3
Fountain 1 Middle*	25.4
Fountain 1 Low*	23.4

Webster

Outdoor

Fountain 1 High	<2.0 U
Fountain 1 Low	<2.0 U

Weisman

Outdoor

Fountain 1 High	2.0
Fountain 1 Middle	<2.0 U
Fountain 1 Low	2.2

Welles

Indoor

Main Hallway	0.414 J
Men's Locker Room	8.98
Women's Locker Room	2.3 J
Pool Deck	0.555 J

Outdoor

Fountain 1 High	<0.120 U
Fountain 1 Midle	<0.120 U
Fountain 1 Low	<0.120 U
Fountain 2 High	5.06
Fountain 2 Low	5.38
Fountain 3 High	2.9 J
Fountain 3 Middle	1.13 J
Fountain 3 Low	2.28 J
Fountain 4 High	0.39 J
Fountain 4 Low	0.397 J
Fountain 4 Dog	0.125 J

Wendt

Outdoor

Fountain 1	3.6
------------	-----

Wentworth

Indoor

Lobby	<0.120 U
Outdoor	
Fountain 1	14.5
Fountain 2 High	<0.120 U
Fountain 2 Middle	<0.120 U
Fountain 2 Low	<0.120 U
Fountain 3*	54.7
Wentworth Garden	
Indoor	
Near Lobby	<2.0 U
Kitchen Sink	<2.0 U
Outdoor	
Fountain 1 High	<0.120 U
Fountain 1 Low	<0.120 U
Wesolek	
Outdoor	
Fountain 1 High*	30
Fountain 1 Low*	21
West Chatham	
Indoor	
Main Lobby	1.37 J
Outdoor	
Fountain 1	0.96 J
Fountain 2 High	<0.120 U
Fountain 2 Low	<0.120 U
West Lawn	
Indoor	
Hallway by Kitchen - High	0.659 J
Hallway by Kitchen - Low	0.417 J
Men's Locker Room - North	1.07 J
Men's Locker Room - South	0.996 J
Women's Locker Room - High	1.1 J
Women's Locker Room - Low	0.867 J
Outdoor	
Fountain 1 High	4.50 J
Fountain 1 Middle	5.48
Fountain 1 Low	8.1
Fountain 2 High*	15.3
Fountain 2 Low*	14
Fountain 3 High	2.47 J
Fountain 3 Low	2.47 J
Fountain 4 High	2.71 J
Fountain 4 Low	3.44 J

	Fountain 5 High*	38.6
	Fountain 5 Low*	39
West Pullman		
Indoor		
	Pool Deck Area	2.19 J
	Main Lobby	<0.120 U
	Main Level Near Gym	0.289 J
	Lower Level Club Room	0.744 J
Outdoor		
	Fountain 1*	19.9
Western		
Outdoor		
	Fountain 1 High	8.16
	Fountain 1 Low	8.36
White		
Outdoor		
	Fountain 1*	28.2
Wicker		
Indoor		
	Lobby	0.194 J
	Kitchen Sink	<2.0 U
Outdoor		
	Fountain 1 High	0.53 J
	Fountain 1 Low	1.23 J
	Fountain 2*	34.8
	Fountain - Dog	<0.120 U
	Fountain 5	5.31
Wieboldt		
Outdoor		
	Fountain 1*	60
Wildwood		
Outdoor		
	Fountain 1 High*	21.9
	Fountain 1 Low*	22.4
	Fountain 2 High*	31.8
	Fountain 2 Low*	16.1
Williams		
Outdoor		
	Fountain 2	4.1

Williams-Davis		
Outdoor		
Fountain 1 High		<2.0 U
Fountain 1 Low		<2.0 U
Willye White		
Indoor		
Lobby		<0.120 U
Gym Hallway West		<0.120 U
Outdoor		
Fountain 1 High		<2.0
Fountain 1 Low		<2.0 U
Wilson (Frank)		
Indoor		
Club Room		0.201 J
Outdoor		
Fountain 1*		51.2
Fountain 2 High*		1.21 J
Fountain 2 Middle*		49.6
Fountain 2 Low*		<0.120 U
Fountain 3*		23.9
Wilson (John) Community Center		
Indoor		
Hallway Near Washrooms		0.789 J
Outdoor		
Fountain 1 High		4.11 J
Fountain 1 Low		5.26
Winnemac		
Outdoor		
Fountain 1 High		0.121 J
Fountain 1 Middle		0.121 J
Fountain 1 Low		<0.120 U
Wolcott		
Outdoor		
Fountain 1 High		14.8
Fountain 1 Low		14.4
Wolfe		
Indoor		
Main Lobby		1.18 J
Outdoor		
Fountain 1		4

Woodhull

Indoor

Main Lobby 0.231 J

Outdoor

Fountain 1 High 0.381 J

Fountain 1 Middle 0.717 J

Fountain 1 Low 0.284 J

Wrightwood

Outdoor

Fountain 1 Low* 26

Fountain 1 Middle* 31

Fountain 1 High* 26

Fountain 2* 24

Zatterberg

Outdoor

Fountain 1* 86

U - Not detected at the laboratory reporting limit and/or method detection limit

J - Estimate value below the laboratory reporting

* - Fountain taken out of service for repair. Remediation plan is being created.

Additional Notes:

- 1) Many water fountain are multi-tiered with different levels of drinking bowls on the same fountain. Each individual bowl was tested and labeled according to their bowl height.
For example: Fountain 1 High, Fountain 1 Middle, and Fountain 1 Low for a 3 tiered fountain.
- 2) EPA standard for lead in drinking water is 15 parts per billion (ppb).
- 3) The Park District used two different Illinois EPA accredited laboratories to complete the analysis.
 - STAT Analysis Corporation has a reporting limit and method detection limit of 2 ppb.
 - Environmental Monitoring Technologies has a reporting limit of 5 ppb and a method detection limit of 0.120 ppb.