



August 2, 2016

Dear CPS family,

In light of national events that have brought increased attention to the issue of water quality, the City of Chicago announced several additional precautionary measures that will be added to the City's water testing protocol, continuing the City's track record of complying with current state and federal regulations as well as exceeding industry standards.

As part of this announcement, Chicago Public Schools (CPS) began testing the water for levels of lead from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe. Schools are being tested based on a priority criteria that includes the age of the school, age of the students (with priority given to schools with pre-K programs), presence of a kitchen (where meals are prepared) and presence of pipes that could need repairs or replacement.

The results of all the schools are coming in on a rolling basis, and the majority have had levels under the EPA's action level of 15 parts per billion (ppb). We wanted to let you know that no lead was found above the action level in your child's school. The full results of your school's water samples can be found online at cps.edu/leadtesting.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician for testing. Additionally, CDPH's lead hotline can address any health related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

Forrest Claypool
CEO, Chicago Public Schools

Dr. Julie Morita
Commissioner, Chicago Department of Public Health





2 de agosto de 2016

Estimadas familias de CPS,

Ante los eventos nacionales que han incrementado la atención en el tema de la calidad del agua, la Alcaldía de Chicago anunció varias medidas adicionales de precaución que serán agregadas al protocolo de prueba del agua de la ciudad, continuando con el cumplimiento de las regulaciones estatales y federales, que exceden los estándares industriales.

Como parte de este anuncio, las Escuelas Públicas de Chicago (CPS) comenzaron a medir los niveles de plomo en el agua de todas las escuelas del distrito. Nuestra principal prioridad es la salud y seguridad de todos nuestros estudiantes y personal, y estas pruebas fueron iniciadas solamente para extremar las precauciones y estar seguros de que el agua es segura. Las escuelas son examinadas con base a un criterio de prioridad que incluye la antigüedad del edificio, edad de los estudiantes (con prioridad para las escuelas con programas preescolares), presencia de una cocina (donde se preparan alimentos) y la presencia de cañerías que necesiten reparación o reemplazo.

Los resultados de todas las escuelas se están conociendo, y la mayoría ha registrado niveles por debajo del nivel de acción de la EPA, que es de 15 partículas por billón (ppb). Queremos hacerles saber que no se encontraron rastros de plomo por encima del nivel de acción en la escuela de su niño. Los resultados completos de las pruebas en su escuela se pueden ver en línea en cps.edu/leadtesting.

Los lineamientos federales indican que los niños menores de seis años son los que corren mayores riesgos con la exposición al plomo, algo que puede ocurrir de varias fuentes, incluyendo pintura, tierra y algunos productos de consumo. Si están preocupados por la posible exposición de su hijo al plomo, el Departamento de Salud Pública de la ciudad de Chicago (CDPH) recomienda visitar a su pediatra o a alguno de los centros de salud listados en el material adjunto, para una prueba. Además, la línea directa del CDPH puede responder cualquier pregunta que tengan, o ayudarlos a decidir si su niño debe ser examinado; por preguntas o más información, llame por favor al 312-747-5323. Por información adicional sobre el plomo y los niños, visite www.cdc.gov/lead.

La seguridad de sus hijos es nuestra principal prioridad, y hacemos todo lo que está en nuestro poder para resolver esta situación de una manera rápida y rigurosa. Continuaremos informándoles sobre este proceso.

Atentamente,

Forrest Claypool
CEO, Escuelas Públicas de Chicago

Dra. Julie Morita, Comisionada
Departamento de Salud Pública de Chicago





School Lead Water Testing - Data Collection Form

School Name

Edwards

Sample ID #	Sample Location	Sample Collection Time & Date	Test Result (ppb)	Test Results
23081-B-E-F01-001	Boiler House, Fountain	5/26/16 5:00 AM	2.09	BA
23081-B-E-F01-002	Boiler House, Fountain	5/26/16 5:00 AM	1.47	BA
23081-B-E-F01-003	Boiler House, Fountain	5/26/16 5:00 AM	1.66	BA
23081-B-E-F01-004	Boiler House, Fountain	5/26/16 5:00 AM	1.43	BA
23081-B-E-F01-005	Boiler House, Fountain	5/26/16 5:00 AM	1.47	BA
23081-1-N-S01-001	Main Building Kitchen, Sink	5/26/16 5:00 AM	0.554	BA
23081-1-N-S01-002	Main Building Kitchen, Sink	5/26/16 5:00 AM	0.307	BA
23081-1-N-S01-003	Main Building Kitchen, Sink	5/26/16 5:00 AM	0.473	BA
23081-1-N-S01-004	Main Building Kitchen, Sink	5/26/16 5:00 AM	0.542	BA
23081-1-N-S01-005	Main Building Kitchen, Sink	5/26/16 5:00 AM	0.458	BA
23081-1-N-F04-001	Outside office, Fountain 1	5/26/16 5:00 AM	0.689	BA
23081-1-N-F04-002	Outside office, Fountain 1	5/26/16 5:00 AM	0.323	BA
23081-1-N-F04-003	Outside office, Fountain 1	5/26/16 5:00 AM	0.354	BA
23081-1-N-F04-004	Outside office, Fountain 1	5/26/16 5:00 AM	0.452	BA
23081-1-N-F04-005	Outside office, Fountain 1	5/26/16 5:00 AM	0.431	BA
23081-1-N-F05-001	Outside Office, Fountain 2	5/26/16 5:00 AM	0.683	BA
23081-1-N-F05-002	Outside Office, Fountain 2	5/26/16 5:00 AM	0.444	BA
23081-1-N-F05-003	Outside Office, Fountain 2	5/26/16 5:00 AM	0.463	BA
23081-1-N-F05-004	Outside Office, Fountain 2	5/26/16 5:00 AM	0.445	BA
23081-1-N-F05-005	Outside Office, Fountain 2	5/26/16 5:00 AM	0.467	BA
23081-1-S-F06-001	Outside Room 113, Fountain 1	5/26/16 5:00 AM	0.835	BA
23081-1-S-F06-002	Outside Room 113, Fountain 1	5/26/16 5:00 AM	0.934	BA
23081-1-S-F06-003	Outside Room 113, Fountain 1	5/26/16 5:00 AM	0.79	BA
23081-1-S-F06-004	Outside Room 113, Fountain 1	5/26/16 5:00 AM	1.03	BA
23081-1-S-F06-005	Outside Room 113, Fountain 1	5/26/16 5:00 AM	1.35	BA
23081-1-S-F07-001	Outside Room 113, Fountain 2	5/26/16 5:00 AM	1.12	BA
23081-1-S-F07-002	Outside Room 113, Fountain 2	5/26/16 5:00 AM	1.16	BA
23081-1-S-F07-003	Outside Room 113, Fountain 2	5/26/16 5:00 AM	1.55	BA
23081-1-S-F07-004	Outside Room 113, Fountain 2	5/26/16 5:00 AM	1.33	BA
23081-1-S-F07-005	Outside Room 113, Fountain 2	5/26/16 5:00 AM	1.25	BA
23081-1-E-F02-001	Across from Room 104, Fountain 1	5/26/16 5:00 AM	0.992	BA
23081-1-E-F02-002	Across from Room 104, Fountain 1	5/26/16 5:00 AM	1.36	BA
23081-1-E-F02-003	Across from Room 104, Fountain 1	5/26/16 5:00 AM	1.13	BA
23081-1-E-F02-004	Across from Room 104, Fountain 1	5/26/16 5:00 AM	0.998	BA
23081-1-E-F02-005	Across from Room 104, Fountain 1	5/26/16 5:00 AM	0.869	BA
23081-1-E-F03-001	Across from Room 104, Fountain 2	5/26/16 5:00 AM	1.09	BA
23081-1-E-F03-002	Across from Room 104, Fountain 2	5/26/16 5:00 AM	1	BA
23081-1-E-F03-003	Across from Room 104, Fountain 2	5/26/16 5:00 AM	1.02	BA
23081-1-E-F03-004	Across from Room 104, Fountain 2	5/26/16 5:00 AM	1.06	BA
23081-1-E-F03-005	Across from Room 104, Fountain 2	5/26/16 5:00 AM	1.12	BA
23081-2-S-F05-001	Outside room 213, Fountain 1	5/26/16 5:00 AM	2.88	BA
23081-2-S-F05-002	Outside room 213, Fountain 1	5/26/16 5:00 AM	1.99	BA
23081-2-S-F05-003	Outside room 213, Fountain 1	5/26/16 5:00 AM	2.09	BA
23081-2-S-F05-004	Outside room 213, Fountain 1	5/26/16 5:00 AM	2.02	BA
23081-2-S-F05-005	Outside room 213, Fountain 1	5/26/16 5:00 AM	2.9	BA
23081-2-S-F06-001	Outside Room 213, Fountain 2	5/26/16 5:00 AM	3.19	BA
23081-2-S-F06-002	Outside Room 213, Fountain 2	5/26/16 5:00 AM	1.11	BA
23081-2-S-F06-003	Outside Room 213, Fountain 2	5/26/16 5:00 AM	2.08	BA
23081-2-S-F06-004	Outside Room 213, Fountain 2	5/26/16 5:00 AM	1.67	BA
23081-2-S-F06-005	Outside Room 213, Fountain 2	5/26/16 5:00 AM	1.65	BA
23081-2-N-F03-001	Outside Room 207, Fountain 1	5/26/16 5:00 AM	0.978	BA
23081-2-N-F03-002	Outside Room 207, Fountain 1	5/26/16 5:00 AM	0.728	BA
23081-2-N-F03-003	Outside Room 207, Fountain 1	5/26/16 5:00 AM	0.745	BA
23081-2-N-F03-004	Outside Room 207, Fountain 1	5/26/16 5:00 AM	0.714	BA
23081-2-N-F03-005	Outside Room 207, Fountain 1	5/26/16 5:00 AM	0.704	BA
23081-2-N-F04-001	Outside Room 207, Fountain 2	5/26/16 5:00 AM	0.616	BA
23081-2-N-F04-002	Outside Room 207, Fountain 2	5/26/16 5:00 AM	0.563	BA
23081-2-N-F04-003	Outside Room 207, Fountain 2	5/26/16 5:00 AM	0.482	BA
23081-2-N-F04-004	Outside Room 207, Fountain 2	5/26/16 5:00 AM	0.39	BA
23081-2-N-F04-005	Outside Room 207, Fountain 2	5/26/16 5:00 AM	0.378	BA
23081-2-E-F01-001	Outside Room 203, Fountain 1	5/26/16 5:00 AM	0.898	BA
23081-2-E-F01-002	Outside Room 203, Fountain 1	5/26/16 5:00 AM	0.995	BA
23081-2-E-F01-003	Outside Room 203, Fountain 1	5/26/16 5:00 AM	0.979	BA
23081-2-E-F01-004	Outside Room 203, Fountain 1	5/26/16 5:00 AM	1.02	BA
23081-2-E-F01-005	Outside Room 203, Fountain 1	5/26/16 5:00 AM	1.06	BA
23081-2-E-F02-001	Outside Room 203, Fountain 2	5/26/16 5:00 AM	0.991	BA
23081-2-E-F02-002	Outside Room 203, Fountain 2	5/26/16 5:00 AM	0.756	BA
23081-2-E-F02-003	Outside Room 203, Fountain 2	5/26/16 5:00 AM	0.869	BA
23081-2-E-F02-004	Outside Room 203, Fountain 2	5/26/16 5:00 AM	0.842	BA
23081-2-E-F02-005	Outside Room 203, Fountain 2	5/26/16 5:00 AM	0.801	BA
23081-1-E-F01-001	East Modular- Inside Room 502, Fountain 1	5/26/16 5:00 AM	<0.120	ND
23081-1-E-F01-002	East Modular- Inside Room 502, Fountain 1	5/26/16 5:00 AM	<0.120	ND
23081-1-E-F01-003	East Modular- Inside Room 502, Fountain 1	5/26/16 5:00 AM	<0.120	ND
23081-1-E-F01-004	East Modular- Inside Room 502, Fountain 1	5/26/16 5:00 AM	<0.120	ND
23081-1-E-F01-005	East Modular- Inside Room 502, Fountain 1	5/26/16 5:00 AM	<0.120	ND
23081-1-E-F02-001	East Modular- Outside Room 502, Fountain 1	5/26/16 5:00 AM	<0.120	ND
23081-1-E-F02-002	East Modular- Outside Room 502, Fountain 1	5/26/16 5:00 AM	<0.120	ND
23081-1-E-F02-003	East Modular- Outside Room 502, Fountain 1	5/26/16 5:00 AM	<0.120	ND
23081-1-E-F02-004	East Modular- Outside Room 502, Fountain 1	5/26/16 5:00 AM	<0.120	ND
23081-1-E-F02-005	East Modular- Outside Room 502, Fountain 1	5/26/16 5:00 AM	<0.120	ND
23081-1-E-F01-001	Annex- Next to Mechanical room, Fountain 1	5/26/16 5:00 AM	<0.120	ND
23081-1-E-F01-002	Annex- Next to Mechanical room, Fountain 1	5/26/16 5:00 AM	<0.120	ND
23081-1-E-F01-003	Annex- Next to Mechanical room, Fountain 1	5/26/16 5:00 AM	<0.120	ND
23081-1-E-F01-004	Annex- Next to Mechanical room, Fountain 1	5/26/16 5:00 AM	<0.120	ND
23081-1-E-F01-005	Annex- Next to Mechanical room, Fountain 1	5/26/16 5:00 AM	<0.120	ND
23081-1-E-F02-001	Annex- Next to Mechanical room, Fountain 2	5/26/16 5:00 AM	<0.120	ND
23081-1-E-F02-002	Annex- Next to Mechanical room, Fountain 2	5/26/16 5:00 AM	<0.120	ND
23081-1-E-F02-003	Annex- Next to Mechanical room, Fountain 2	5/26/16 5:00 AM	<0.120	ND
23081-1-E-F02-004	Annex- Next to Mechanical room, Fountain 2	5/26/16 5:00 AM	0.12	BA
23081-1-E-F02-005	Annex- Next to Mechanical room, Fountain 2	5/26/16 5:00 AM	<0.120	ND

23081-1-E-F01-001	West Modular- Outside Room 404, Fountain 1	5/26/16 5:00 AM	<0.120	ND
23081-1-E-F01-002	West Modular- Outside Room 404, Fountain 1	5/26/16 5:00 AM	<0.120	ND
23081-1-E-F01-003	West Modular- Outside Room 404, Fountain 1	5/26/16 5:00 AM	<0.120	ND
23081-1-E-F01-004	West Modular- Outside Room 404, Fountain 1	5/26/16 5:00 AM	<0.120	ND
23081-1-E-F01-005	West Modular- Outside Room 404, Fountain 1	5/26/16 5:00 AM	<0.120	ND
23081-1-E-F02-001	West Modular- Outside Room 404, Fountain 2	5/26/16 5:00 AM	<0.120	ND
23081-1-E-F02-002	West Modular- Outside Room 404, Fountain 2	5/26/16 5:00 AM	<0.120	ND
23081-1-E-F02-003	West Modular- Outside Room 404, Fountain 2	5/26/16 5:00 AM	<0.120	ND
23081-1-E-F02-004	West Modular- Outside Room 404, Fountain 2	5/26/16 5:00 AM	<0.120	ND
23081-1-E-F02-005	West Modular- Outside Room 404, Fountain 2	5/26/16 5:00 AM	<0.120	ND
1-W-CS01-01	Food Storage	6/21/16 6:10 AM	None Detected	ND
1-W-CS01-02	Food Storage	6/21/16 6:10 AM	None Detected	ND
1-W-CS01-03	Food Storage	6/21/16 6:10 AM	None Detected	ND
1-W-CS01-04	Food Storage	6/21/16 6:10 AM	None Detected	ND
1-W-CS01-05	Food Storage	6/21/16 6:10 AM	None Detected	ND
1-N-CS01-06	Room 601	6/21/16 6:18 AM	5.93	BA
1-N-CS01-07	Room 601	6/21/16 6:18 AM	None Detected	ND
1-N-CS01-08	Room 601	6/21/16 6:18 AM	None Detected	ND
1-N-CS01-09	Room 601	6/21/16 6:18 AM	None Detected	ND
1-N-CS01-10	Room 601	6/21/16 6:18 AM	None Detected	ND
1-S-F01-11	Corridor Outside Teachers Lounge	6/21/16 6:23 AM	None Detected	ND
1-S-F01-12	Corridor Outside Teachers Lounge	6/21/16 6:23 AM	None Detected	ND
1-S-F01-13	Corridor Outside Teachers Lounge	6/21/16 6:23 AM	None Detected	ND
1-S-F01-14	Corridor Outside Teachers Lounge	6/21/16 6:23 AM	None Detected	ND
1-S-F01-15	Corridor Outside Teachers Lounge	6/21/16 6:23 AM	None Detected	ND
1-S-F02-16	Corridor Outside Teachers Lounge	6/21/16 6:28 AM	None Detected	ND
1-S-F02-17	Corridor Outside Teachers Lounge	6/21/16 6:28 AM	None Detected	ND
1-S-F02-18	Corridor Outside Teachers Lounge	6/21/16 6:28 AM	None Detected	ND
1-S-F02-19	Corridor Outside Teachers Lounge	6/21/16 6:28 AM	None Detected	ND
1-S-F02-20	Corridor Outside Teachers Lounge	6/21/16 6:28 AM	None Detected	ND
1-N-CS01-21	Room 603	6/21/16 6:35 AM	None Detected	ND
1-N-CS01-22	Room 603	6/21/16 6:35 AM	None Detected	ND
1-N-CS01-23	Room 603	6/21/16 6:35 AM	None Detected	ND
1-N-CS01-24	Room 603	6/21/16 6:35 AM	None Detected	ND
1-N-CS01-25	Room 603	6/21/16 6:35 AM	None Detected	ND
1-S-CS01-26	Room 604	6/21/16 6:40 AM	None Detected	ND
1-S-CS01-27	Room 604	6/21/16 6:40 AM	None Detected	ND
1-S-CS01-28	Room 604	6/21/16 6:40 AM	None Detected	ND
1-S-CS01-29	Room 604	6/21/16 6:40 AM	None Detected	ND
1-S-CS01-30	Room 604	6/21/16 6:40 AM	None Detected	ND
1-N-CS01-31	Room 605	6/21/16 6:45 AM	None Detected	ND
1-N-CS01-32	Room 605	6/21/16 6:45 AM	None Detected	ND
1-N-CS01-33	Room 605	6/21/16 6:45 AM	None Detected	ND
1-N-CS01-34	Room 605	6/21/16 6:45 AM	None Detected	ND
1-N-CS01-35	Room 605	6/21/16 6:45 AM	None Detected	ND
1-S-CS01-36	Room 606	6/21/16 6:50 AM	None Detected	ND
1-S-CS01-37	Room 606	6/21/16 6:50 AM	None Detected	ND
1-S-CS01-38	Room 606	6/21/16 6:50 AM	None Detected	ND
1-S-CS01-39	Room 606	6/21/16 6:50 AM	None Detected	ND
1-S-CS01-40	Room 606	6/21/16 6:50 AM	None Detected	ND
1-N-CS01-41	Room 607	6/21/16 6:55 AM	None Detected	ND
1-N-CS01-42	Room 607	6/21/16 6:55 AM	None Detected	ND
1-N-CS01-43	Room 607	6/21/16 6:55 AM	None Detected	ND
1-N-CS01-44	Room 607	6/21/16 6:55 AM	None Detected	ND
1-N-CS01-45	Room 607	6/21/16 6:55 AM	None Detected	ND
1-S-CS01-46	Room 608	6/21/16 7:00 AM	None Detected	ND
1-S-CS01-47	Room 608	6/21/16 7:00 AM	None Detected	ND
1-S-CS01-48	Room 608	6/21/16 7:00 AM	None Detected	ND
1-S-CS01-49	Room 608	6/21/16 7:00 AM	None Detected	ND
1-S-CS01-50	Room 608	6/21/16 7:00 AM	None Detected	ND
1-N-CS01-51	Room 609	6/21/16 7:05 AM	None Detected	ND
1-N-CS01-52	Room 609	6/21/16 7:05 AM	None Detected	ND
1-N-CS01-53	Room 609	6/21/16 7:05 AM	None Detected	ND
1-N-CS01-54	Room 609	6/21/16 7:05 AM	None Detected	ND
1-N-CS01-55	Room 609	6/21/16 7:05 AM	None Detected	ND
1-S-F01-56	Corridor Outside Room 609	6/21/16 7:10 AM	None Detected	ND
1-S-F01-57	Corridor Outside Room 609	6/21/16 7:10 AM	None Detected	ND
1-S-F01-58	Corridor Outside Room 609	6/21/16 7:10 AM	None Detected	ND
1-S-F01-59	Corridor Outside Room 609	6/21/16 7:10 AM	None Detected	ND
1-S-F01-60	Corridor Outside Room 609	6/21/16 7:10 AM	None Detected	ND
1-S-F02-61	Corridor Outside Room 609	6/21/16 7:15 AM	None Detected	ND
1-S-F02-62	Corridor Outside Room 609	6/21/16 7:15 AM	None Detected	ND
1-S-F02-63	Corridor Outside Room 609	6/21/16 7:15 AM	None Detected	ND
1-S-F02-64	Corridor Outside Room 609	6/21/16 7:15 AM	None Detected	ND
1-S-F02-65	Corridor Outside Room 609	6/21/16 7:15 AM	None Detected	ND

EPA ACTION LEVEL FOR LEAD IS 15 ppb or 15 µg/L

SPREADSHEET LEGEND

ND-Not Detected at the Reporting Limit
BA-Below EPA Action Level of 15 ppb
AA-Above EPA Action Level

Chicago Public Schools - Department of Facility Operations