



School Lead Water Testing - Data Collection Form

School Short Name      **Ravenswood**

Length of time water remained in pipes before sampled (hours)      8+

Date of test      04/30/16

Water last used (Time and date)      4/29/16

Sample ID #	Sample Collection Time & Date	Length of time water remained in pipes before sampled (Hours)	Test Result (ppb)	Test Results
1-E-F-01	4/30/16 6:45 AM	8:45	ND	None Detected (ND)
1-N-F-02	4/30/16 6:50 AM	8:50	ND	None Detected (ND)
1-E-CS-03	4/30/16 6:53 AM	8:53	ND	None Detected (ND)
2-S-F-04	4/30/16 7:11 AM	9:11	ND	None Detected (ND)
3-W-F-05	4/30/16 7:18 AM	9:18	ND	None Detected (ND)

EPA ACTION LEVEL FOR LEAD IS 15 ppb or 15 µg/L

SPREADSHEET LEGEND

ND-Not Detected at the Reporting Limit

BA-Below EPA Action Level of 15 ppb

AA-Above EPA Action Level