

July 22, 2016

Dear CPS family,

In light of national events that have brought increased attention to the issue of water quality, the City of Chicago announced several additional precautionary measures that will be added to the City's water testing protocol, continuing the City's track record of complying with current state and federal regulations as well as exceeding industry standards.

As part of this announcement, Chicago Public Schools (CPS) began testing the water for levels of lead from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe. Schools are being tested based on a priority criteria that includes the age of the school, age of the students (with priority given to schools with pre-K programs), presence of a kitchen (where meals are prepared) and presence of pipes that could need repairs or replacement.

The results of all the schools are coming in on a rolling basis, and the majority have had levels under the EPA's action level of 15 parts per billion (ppb). We wanted to let you know that no lead was found above the action level in your child's school. The full results of your school's water samples can be found online at <a href="mailto:cps.edu/leadtesting">cps.edu/leadtesting</a>.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician for testing. Additionally, CDPH's lead hotline can address any health related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit <a href="https://www.cdc.gov/lead">www.cdc.gov/lead</a>.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

Forrest Claypool CEO, Chicago Public Schools Dr. Julie Morita

Commissioner, Chicago Department of Public Health



22 de julio de 2016

Estimadas familias de CPS,

Ante los eventos nacionales que han incrementado la atención en el tema de la calidad del agua, la Alcaldía de Chicago anunció varias medidas adicionales de precaución que serán agregadas al protocolo de prueba del agua de la ciudad, continuando con el cumplimiento de las regulaciones estatales y federales, que exceden los estándares industriales.

Como parte de este anuncio, las Escuelas Públicas de Chicago (CPS) comenzaron a medir los niveles de plomo en el agua de todas las escuelas del distrito. Nuestra principal prioridad es la salud y seguridad de todos nuestros estudiantes y personal, y estas pruebas fueron iniciadas solamente para extremar las precauciones y estar seguros de que el agua es segura. Las escuelas son examinadas con base a un criterio de prioridad que incluye la antigüedad del edificio, edad de los estudiantes (con prioridad para las escuelas con programas preescolares), presencia de una cocina (donde se preparan alimentos) y la presencia de cañerías que necesiten reparación o reemplazo.

Los resultados de todas las escuelas se están conociendo, y la mayoría ha registrado niveles por debajo del nivel de acción de la EPA, que es de 15 partículas por billón (ppb). Queremos hacerles saber que no se encontraron rastros de plomo por encima del nivel de acción en la escuela de su niño. Los resultados completos de las pruebas en su escuela se pueden ver en línea en cps.edu/leadtesting.

Los lineamientos federales indican que los niños menores de seis años son los que corren mayores riesgos con la exposición al plomo, algo que puede ocurrir de varias fuentes, incluyendo pintura, tierra y algunos productos de consumo. Si están preocupados por la posible exposición de su hijo al plomo, el Departamento de Salud Pública de la ciudad de Chicago (CDPH) recomienda visitar a su pediatra o a alguno de los centros de salud listados en el material adjunto, para una prueba. Además, la línea directa del CDPH puede responder cualquier pregunta que tengan, o ayudarlos a decidir si su niño debe ser examinado; por preguntas o más información, llame por favor al 312-747-5323. Por información adicional sobre el plomo y los niños, visite www.cdc.gov/lead.

La seguridad de sus hijos es nuestra principal prioridad, y hacemos todo lo que está en nuestro poder para resolver esta situación de una manera rápida y rigurosa. Continuaremos informándoles sobre este proceso.

Atentamente,

Forrest Claypool CEO, Escuelas Públicas de Chicago Dra. Julie Morita, Comisionada Departamento de Salud Pública de Chicago



Sample ID #	Sample Location	Sample Collection Time & Date	Test Result (ppb)	Test Reso
51581-1-E-F01-001 51581-1-E-F01-002	Main Bidg- Across Room 169 (Hallway), Fountain Main Bidg- Across Room 169 (Hallway), Fountain	6/17/16 5:00 AM 6/17/16 5:00 AM	137	BA BA
51581-1-E-F01-003 51581-1-E-F01-004	Main Bidg-Across Room 109 (Hallway), Fountain Main Bidg-Across Room 109 (Hallway), Fountain Main Bidg-Across Room 109 (Hallway), Fountain	6/17/16 5:00 AM 6/17/16 5:00 AM 6/17/16 5:00 AM	0.575 0.347 0.343	BA BA
51581-1-N-F02-001 51581-1-N-F02-002			1.32	BA BA
51581-1-N-F02-002 51581-1-N-F02-003 51581-1-N-F02-004 51581-1-N-F02-005	Main Bidg-Across Room 171 (Mallowy) East, Fourtain 1	6/17/16 5:00 AM 6/17/16 5:00 AM 6/17/16 5:00 AM 6/17/16 5:00 AM	0.455 0.206 0.173 0.143	BA BA
51581-1-N-F03-001		6/17/16 5:00 AM	0.143 10.8	BA BA
51581-1-N-F03-002 51581-1-N-F03-003	Main Bidg-Across Room 171 (Hallway) West, Fountain 2 Main Bidg-Across Room 171 (Hallway) West, Fountain 2	6/17/16 5:00 AM	3.63 1.35	BA BA
51581-1-NF03-005 51581-1-NF03-005	Main Bidg-Across Room 171 (Hallway) West, Fourbin 2 Main Bidg-Acr	6/17/16 5:00 AM 6/17/16 5:00 AM 6/17/16 5:00 AM	1.35 1.89 1.02 2.46	BA BA
51581-1-N-504-002 51581-1-N-504-003	Main Bidg- Inside of Room 175, Sink Main Bidg- Inside of Room 175, Sink	6/17/16 5:00 AM 6/17/16 5:00 AM	8.93 5.6	BA BA
51581-1-N-504-004 51581-1-N-504-005	Main Bidg- Inside of Room 175, Sink Main Bidg- Inside of Room 175, Sink	6/17/16 5:00 AM 6/17/16 5:00 AM	2.86 2.04	BA BA
51581-2-E-F01-001 51581-2-E-F01-002	Main Bidg-Across Room 255 (Hallway) North, Fountain 1 Main Bidg-Across Room 255 (Hallway) North, Fountain 1	6/17/16 5:00 AM 6/17/16 5:00 AM	1.53 0.632	BA BA
51581-2-E-F01-003 51581-2-E-F01-004	Main Bldg- Across Room 205 (Hallway) North, Fountain 1 Main Bldg- Across Room 205 (Hallway) North, Fountain 1 Main Bldg- Across Room 205 (Hallway) North, Fountain 1	6/17/16 5:00 AM 6/17/16 5:00 AM	0.553	BA BA
51581-2-6-F02-001 51581-2-6-F02-002	Main Bidg-Across Room 200 (Hallway) South, Fountain 1 Main Bidg-Across Room 205 (Hallway) South, Fountain 2 Main Bidg-Across Room 205 (Hallway) South, Fountain 2	617716 5:00 AM 6117716 5:00 AM 6117716 5:00 AM	0.555 0.67 1.42 0.521	BA BA
51581-2-E-F02-003 51581-2-E-F02-004	Main Bidg-Across Room 265 (Hallway) South, Fountain 2 Main Bidg-Across Room 265 (Hallway) South, Fountain 2 Main Bidg-Across Room 265 (Hallway) South, Fountain 2	6/17/16 5:00 AM 6/17/16 5:00 AM 6/17/16 5:00 AM	1.59	BA BA
51581-2-E-F02-005 51581-2-N-F03-001	Main Bidg-Across Room 255 (Hallway) South, Fountain 2 Main Bidg- Outside Room 2715 (Hallway) East, Fountain 1	6/17/16 5:00 AM 6/17/16 5:00 AM	0.485	BA BA
51581-2-N-F03-002 51581-2-N-F03-003	Main Bidg- Outside Room 271B (Hallway) East, Fountain 1 Main Bidg- Outside Room 271B (Hallway) East, Fountain 1 Main Bidg- Outside Room 271B (Hallway) East, Fountain 1	6/17/16 5:00 AM 6/17/16 5:00 AM 6/17/16 5:00 AM	0.268	BA BA
51581-2-N-F03-005 51581-2-N-F03-005	Main Bidg- Outside Room 271B (Hallway) East, Fountain 1	6/17/16 5:00 AM	0.189	BA BA
51581-2-N-F04-002 51581-2-N-F04-002	Main Bidg- Outside Room 2718 (Hallway) West, Fountain 2	6/17/16 5:00 AM	0.176	BA BA
51581-2-N-F04-003 51581-2-N-F04-004 51581-2-N-F04-005	Main Bidg- Outside Room 2718 (Hallway) West, Fountain 2 Main Bidg- Outside Room 2718 (Hallway) West, Fountain 2 Main Bidg- Outside Room 2718 (Hallway) West, Fountain 2	6/17/16 5:00 AM 6/17/16 5:00 AM 6/17/16 5:00 AM	+0.120 +0.120 +0.120	ND ND
51581-3-W-F01-001 51581-3-W-F01-002	Main Bidg-Across Room 355 (Hallway) North, Fountain 1 Main Bidg-Across Room 355 (Hallway) North, Fountain 1	6/17/16 5:00 AM 6/17/16 5:00 AM	1.37	BA BA
51581-3-W-F01-003 51581-3-W-F01-004	Main Bldg- Across Room 365 (Hallway) North, Fountain 1 Main Bldg- Across Room 365 (Hallway) North, Fountain 1	6/17/16 5:00 AM 6/17/16 5:00 AM	0.529	BA BA
51581-3-W-F01-005 51581-3-W-F02-001	Main Bidg- Across Room 365 (Hallway) North, Fountain 1 Main Bidg- Across Room 365 (Hallway) South, Fountain 2	6/17/16 5:00 AM 6/17/16 5:00 AM	0.336	BA BA
51581-3-W-F02-002 51581-3-W-F02-003	Main Bidg-Across Room 365 (Hallway) South, Fountain 2 Main Bidg-Across Room 366 (Hallway) South, Fountain 2 Main Bidg-Across Room 366 (Hallway) South, Fountain 2 Main Bidg-Across Room 365 (Hallway) South, Fountain 2	617/16 5:00 AM 617/16 5:00 AM 617/16 5:00 AM 617/16 5:00 AM	0.411	BA BA
51581-3-W-F02-005	Main Bidg-Across Room 355 (Hallway) South, Fountain 2 Main Bidg-Across Room 355 (Hallway) South, Fountain 2	6/17/16 5:00 AM 6/17/16 5:00 AM	0.402	BA BA
51581-3-N-F03-001 51581-3-N-F03-002 51581-3-N-F03-003	Main Bidg- Outside Room 374 (Hallway) West, Fountain 2  Main Bidg- Outside Room 374 (Hallway) West, Fountain 2	6/17/16 5:00 AM 6/17/16 5:00 AM	0.532	BA BA
51581-3-N-F03-003 51581-3-N-F03-004 51581-3-N-F03-005	Main Bidg- Outside Room 374 (Hallway) West, Fountain 2 Main Bidg- Outside Room 374 (Hallway) West, Fountain 2 Main Bidg- Outside Room 374 (Hallway) West, Fountain 2 Main Bidg- Outside Room 374 (Hallway) East, Fountain 1	6/17/16 5:00 AM 6/17/16 5:00 AM 6/17/16 5:00 AM 6/17/16 5:00 AM	0.166 0.137 0.166	BA BA
51581-3-N-F04-001 51581-3-N-F04-002	Main Bidg- Outside Room 374 (Hallway) East, Fountain 1	6/17/16 5:00 AM	0.160 0.453 +0.120	BA ND
51581-3-N-F04-003 51581-3-N-F04-004	Main Bldg- Outside Room 374 (Hallway) East, Fountain 1	6/17/16 5:00 AM 6/17/16 5:00 AM	0.127 0.126	BA BA
51581-3-N-F04-005 51581-4-W-F01-001	Main Bldg- Outside Room 374 (Hallway) East, Fountain 1 Main Bldg- Across Room 405 (Hallway) North, Fountain 1	6/17/16 5:00 AM 6/17/16 5:00 AM	0.129 2.63	BA BA
51581-4-W-F01-002 51581-4-W-F01-003 51581-4-W-F01-004	Main Bidg- Across Room 405 (Hallway) North, Fountain 1 Main Bidg- Across Room 405 (Hallway) North, Fountain 1 Main Bidg- Across Room 405 (Hallway) North, Fountain 1	6/17/16 5:00 AM 6/17/16 5:00 AM 6/17/16 5:00 AM	0.581 0.38 0.542	BA BA
51581-4-W-F01-005	Main Bldg- Across Room 405 (Hallway) North, Fountain 1 Main Bldg- Across Room 405 (Hallway) North, Fountain 1 Main Bldg- Outside Room 475 (Hallway) West, Fountain 2	6/17/16 5:00 AM 6/17/16 5:00 AM 6/17/16 5:00 AM	0.542 0.551 0.824	BA BA
51581-4-N-F03-002 51581-4-N-F03-002 51581-4-N-F03-003		6117/16 5:00 AM 6117/16 5:00 AM 6117/16 5:00 AM	0.892 0.492 0.395	BA BA
51581-4-N-F03-004 51581-4-N-F03-005	Main Bidg- Outside Room 475 (Hallway) Weal, Fountain 2 Main Bidg- Outside Room 475 (Hallway) Weal, Fountain 2 Main Bidg- Outside Room 475 (Hallway) Weal, Fountain 2	617/16 5:00 AM 617/16 5:00 AM 617/16 5:00 AM 617/16 5:00 AM	0.463	BA BA
51581-4-N-F04-001 51581-4-N-F04-002	Main Bidg- Outside Room 475 (Hallway) East, Fountain 1 Main Bidg- Outside Room 475 (Hallway) East, Fountain 1	6/17/16 5:00 AM 6/17/16 5:00 AM	0.919	BA BA
51581-4-N-F04-003 51581-4-N-F04-004	Main Bidg- Outside Room 475 (Hallway) East, Fountain 1 Main Bidg- Outside Room 475 (Hallway) East, Fountain 1	6/17/16 5:00 AM 6/17/16 5:00 AM	0.523 0.526	BA BA
51581-1-E-F01-001	Main Bidg- Outside Room 475 (Hallway) East, Fountain 1 Main Bidg- Outside Room 475 (Hallway) East, Fountain 1 Addition-Across Auditorium B (Hallway) North, Fountain 1	6/17/16 5:00 AM 6/17/16 5:00 AM	0.463 0.545	BA BA
51581-1-E-F01-002 51581-1-E-F01-003	Addition-Across Auditorium II (Hallway) North, Fountain 1 Addition-Across Auditorium II (Hallway) North, Fountain 1	6/17/16 5:00 AM 6/17/16 5:00 AM	0.492	BA BA
51581-1-E-F01-004 51581-1-E-F01-005	Addition-Across Auditorium B (Hallway) North, Fountain 1 Addition-Across Auditorium B (Hallway) North, Fountain 1	6/17/16 5:00 AM 6/17/16 5:00 AM	0.201 =0.120	ND ND
51581-1-E-F02-002 51581-1-E-F02-003	Addition-Across Auditorium B (Hallway) South, Fountain 2 Addition-Across Auditorium B (Hallway) South, Fountain 2 Addition-Across Auditorium B (Hallway) South, Fountain 2	6/17/16 5:00 AM 6/17/16 5:00 AM	<0.120 <0.120	ND ND
51581-1-E-F02-004 51581-1-E-F02-005	Addition-Across Auditorium B (Interway) South, Foundin 2	6/17/16 5:00 AM 6/17/16 5:00 AM 6/17/16 5:00 AM	<0.120	ND ND
51581-1-E-F03-001 51581-1-E-F03-002	Addition-Across Auditorium II (Hallway) South, Fountain 2 Addition-Across Auditorium A (Hallway) North, Fountain 1 Addition-Across Auditorium A (Hallway) North, Fountain 1	6/17/16 5:00 AM 6/17/16 5:00 AM 6/17/16 5:00 AM	-0.120 0.19 0.22	BA BA
51581-1-E-F03-003 51581-1-E-F03-004	Addition-Across Auditorium A (Hallway) North, Fountain 1 Addition-Across Auditorium A (Hallway) North, Fountain 1	6/17/16 5:00 AM 6/17/16 5:00 AM	0.253 0.253	BA BA
51581-1-0-F03-005 51581-1-0-F04-001	Addition-Across Auditorium A (Hallway) North, Fountain 1 Addition-Across Auditorium A (Hallway) South, Fountain 2 Addition-Across Auditorium A (Hallway) South, Fountain 2	6/17/16 5:00 AM 6/17/16 5:00 AM 6/17/16 5:00 AM	0.181 0.168 +0.120	BA BA
51581-1-E-F04-003 51581-1-E-F04-004	Addition-Across Auditorium A (Hallway) South, Fountain 2 Addition-Across Auditorium A (Hallway) South, Fountain 2 Addition-Across Auditorium A (Hallway) South, Fountain 2	6/17/16/5/00 AM 6/17/16/5/00 AM	+0.120	ND ND
51581-1-E-F04-005 51581-2-C-501-001	Addition-Across Additionum A (Hallway) South, Fountain 2 Addition-Kitchen Sink (East) 1	6/17/16 5:00 AM 6/17/16 5:00 AM	+0.120 +0.120 +0.75	ND ND
51581-2-C-501-002 51581-2-C-501-003	Addition-Kitchen Sink (East) 1 Addition-Kitchen Sink (East) 1	6/17/16 5:00 AM 6/17/16 5:00 AM	0.558	BA BA
51581-2-C-501-004 51581-2-C-501-005	Addition-Kitchen Sink (East) 1 Addition-Kitchen Sink (East) 1	6/17/16 5:00 AM 6/17/16 5:00 AM	0.653 0.409	BA BA
51581-2-C-502-001 51581-2-C-502-002	Addition Kitchen Sink (West) 2 Addition Kitchen Sink (West) 2	6/17/16 5:00 AM	0.333	BA BA
51581-2-C-502-004 51581-2-C-502-005	Addition Ritchen Sink (West) 2 Addition Ritchen Sink (West) 2 Addition Ritchen Sink (West) 2	617/16 5:00 AM 6/17/16 5:00 AM 6/17/16 5:00 AM 6/17/16 5:00 AM	0.668	BA BA
51581-2-N-F03-001 51581-2-N-F03-002	Addition Kitchen Sink (West) 2 Addition-Across Room 200 (Hallway) West, Fountain 3 Addition-Across Room 200 (Hallway) West, Fountain 3	6/17/16 5:00 AM	0.484 0.574 0.426	BA BA
51581-2-N-F03-003 51581-2-N-F03-004	Addition-Across Room 200 (Hallway) West, Fountain 3 Addition-Across Room 200 (Hallway) West, Fountain 3	6/17/16 5:00 AM 6/17/16 5:00 AM	0.395	BA BA
51581-2-N-F03-005 51581-2-N-F04-001	Addition-Across Room 200 (Hallway) West, Fountain 3 Addition-Across Room 200 (Hallway) Center, Fountain 2	6/17/16 5:00 AM 6/17/16 5:00 AM	0.365	BA BA
51581-2-N-F04-003 51581-2-N-F04-003	Addition-Across Room 200 (Hallway) Center, Fountain 2 Addition-Across Room 200 (Hallway) Center, Fountain 2 Addition-Across Room 200 (Hallway) Center, Fountain 2 Addition-Across Room 200 (Hallway) Center, Fountain 2	6/17/16 5:00 AM 6/17/16 5:00 AM 6/17/16 5:00 AM	0.401	BA BA
51581-2-N-F04-005 51581-2-N-F04-005 51581-2-N-F05-001	Addition-Across Room 200 (Hallway) Center, Fountain 2 Addition-Across Room 200 (Hallway) Center, Fountain 2 Addition-Across Room 200 (Hallway) East, Fountain 1	6/17/16 5:00 AM 6/17/16 5:00 AM 6/17/16 5:00 AM	0.376 0.376	BA BA
51581-2-N-F05-002 51581-2-N-F05-003	Addition-Across Room 200 (Hallway) East, Foundain 1 Addition-Across Room 200 (Hallway) East, Foundain 1 Addition-Across Room 200 (Hallway) East, Foundain 1	6/17/16 5:00 AM 6/17/16 5:00 AM	0.461 0.384	BA BA
51581-2-N-F05-004 51581-2-N-F05-005	Addition-Across Room 200 (Halfway) East, Fountain 1 Addition-Across Room 200 (Halfway) East, Fountain 1	6/17/16 5:00 AM 6/17/16 5:00 AM	0.407	BA BA
51561-3-W-F01-001 51561-3-W-F01-002	Addition-Across Room 322 (Hallway) North, Fountain 1 Addition-Across Room 322 (Hallway) North, Fountain 1	6/17/16 5:00 AM 6/17/16 5:00 AM	0.5	BA BA
51581-3-W-F01-003 51581-3-W-F01-004 51581-3-W-F01-005	Additon-Across Room 322 (Hallway) North, Fountain 1 Additon-Across Room 322 (Hallway) North, Fountain 1 Additon-Across Room 322 (Hallway) North, Fountain 1	6/17/16/5/00 AM 6/17/16/5/00 AM 6/17/16/5/00 AM 6/17/16/5/00 AM	0.299 0.3 0.262 0.345	BA BA
51581-3-W-F02-001 51581-3-W-F02-002	Addition-Across Room 322 (Hallway) North, Fountain 1 Addition-Across Room 322 (Hallway) South, Fountain 2 Addition-Across Room 322 (Hallway) South, Fountain 2	6/17/16 5:00 AM 6/17/16 5:00 AM	0.345	BA BA
51581-3-W-F02-003 51581-3-W-F02-004	Addition-Across Room 322 (HsRwsy) South, Fountain 2 Addition-Across Room 322 (HsRwsy) South, Fountain 2	6/17/16 5:00 AM 6/17/16 5:00 AM	0.228 0.233	BA BA
51581-3-W-F02-005 51581-3-E-F03-001	Addition-Across Room 322 (Hallway) South, Fountain 2 Addition-Across Room 334 (Hallway) North, Fountain 1	6/17/16 5:00 AM 6/17/16 5:00 AM	0.231	BA BA
51581-3-E-F03-002 51581-3-E-F03-003	Addition-Across Room 334 (Hallway) North, Fountain 1 Addition-Across Room 334 (Hallway) North, Fountain 1	6/17/16 5:00 AM 6/17/16 5:00 AM	0.443 0.428	BA BA
51581-3-E-F03-005 51581-3-E-F03-005 51581-3-E-F04-001	Addition-Across Room S34 (Hallway) North, Fountain 1 Addition-Across Room S34 (Hallway) North, Fountain 1 Addition-Across Room S34 (Hallway) South, Fountain 2	6/17/16 5:00 AM 6/17/16 5:00 AM 6/17/16 5:00 AM	0.405 0.417 0.43	BA BA
51581-3-E-F04-002 51581-3-E-F04-002	Addition-Across Room 334 (Hallway) South, Fountain 2 Addition-Across Room 334 (Hallway) South, Fountain 2	617/16 5:00 AM 6117/16 5:00 AM	0.435 0.435	BA BA
51581-3-E-F04-004 51581-3-E-F04-005	Addition-Across Room 334 (Hallway) South, Fountain 2 Addition-Across Room 334 (Hallway) South, Fountain 2	6/17/16 5:00 AM 6/17/16 5:00 AM	0.427 0.414 0.435	BA BA
51581-3-N-F05-001 51581-3-N-F05-002	Addition-Across Room 306 (Hallway) West, Fountain 2 Addition-Across Room 306 (Hallway) West, Fountain 2	6/17/16 5:00 AM 6/17/16 5:00 AM	0.435	BA BA
51581-3-N-F05-003 51581-3-N-F05-004	Addition-Across Room 308 (Hallway) West, Fountain 2 Addition-Across Room 308 (Hallway) West, Fountain 2 Addition-Across Room 308 (Hallway) West, Fountain 2 Addition-Across Room 308 (Hallway) West Fountain 2	6/17/16 5:00 AM 6/17/16 5:00 AM 6/17/16 5:00 AM	0.434 0.371 0.374	BA BA
51581-3-N-F05-001 51581-3-N-F05-001 51581-3-N-F05-002	Addition-Across Room 306 (Hallway) West, Fountain 2 Addition-Across Room 306 (Hallway) East, Fountain 1 Addition-Across Room 306 (Hallway) East, Fountain 1	6/17/16 5:00 AM 6/17/16 5:00 AM 6/17/16 5:00 AM	0.324 0.423 0.337	BA BA
51581-3-N-F05-003 51581-3-N-F05-004	Addition-Across Room 306 (Hallway) East, Fountain 1 Addition-Across Room 306 (Hallway) East, Fountain 1	6/17/16 5:00 AM 6/17/16 5:00 AM	0.291	BA BA
51581-3-N-F05-005 51581-4-W-F01-001	Addition-Across Room 305 (Hallway) East, Fountain 1 Addition-Across Room 434 (Hallway) South, Fountain 2	6/17/16 5:00 AM 6/17/16 5:00 AM	0.287 0.478	BA BA
51581-4-W-F01-002 51581-4-W-F01-003	Addition-Across Room 434 (Histway) South, Fountain 2 Addition-Across Room 434 (Histway) South, Fountain 2	6/17/16 5:00 AM 6/17/16 5:00 AM	0.429	BA BA
51581-4-W-F01-004 51581-4-W-F01-005	Addition-Across Room 434 (Hallway) South, Fountain 2 Addition-Across Room 434 (Hallway) South, Fountain 2 Addition-Across Room 434 (Hallway) North, Fountain 1	6/17/16 5:00 AM 6/17/16 5:00 AM	0.455 0.44 0.572	BA BA
51581-4-W-F02-001 51581-4-W-F02-002 51581-4-W-F02-003	Addition-Across Room 434 (Hallway) North, Fountain 1 Addition-Across Room 434 (Hallway) North, Fountain 1 Addition-Across Room 434 (Hallway) North, Fountain 1	6/17/16 5:00 AM 6/17/16 5:00 AM 6/17/16 5:00 AM	0.572 0.474 0.495	BA BA
51581+WF02-004	Additor-Across Room 434 (Hallway) North, Fountain 1 Additor-Across Room 434 (Hallway) North, Fountain 1 Additor-Across Room 434 (Hallway) North, Fountain 1	6/17/16 5:00 AM 6/17/16 5:00 AM 6/17/16 5:00 AM	0.485 0.46	BA BA
51581-4-W-F03-001 51581-4-W-F03-002	Addition-Across Room 434 (Hallway) North, Fountain 1 Addition-Across Room 422 (Hallway) South, Fountain 2 Addition-Across Room 422 (Hallway) South, Fountain 2	6/17/16 5:00 AM 6/17/16 5:00 AM 6/17/16 5:00 AM	0.462 0.404 0.394	BA BA
51581-4-W-F03-003 51581-4-W-F03-004	Addition-Across Room 422 (Halfway) South, Fountain 2 Addition-Across Room 422 (Halfway) South, Fountain 2 Addition-Across Room 422 (Halfway) South, Fountain 2	617716 5:00 AM 6117716 5:00 AM 6117716 5:00 AM	0.402 0.402	BA BA
51581+WF03-005 51581+WF04-001	Addition-Across Room 422 (Hallway) South, Fountain 2 Addition-Across Room 422 (Hallway) North, Fountain 1	6/17/16 5:00 AM 6/17/16 5:00 AM	0.4	BA BA
51581-4-W-F04-002 51581-4-W-F04-003	Addition-Across Room 422 (Hallway) North, Fountain 1	5/17/16 5:00 AM 5/17/16 5:00 AM	0.399	BA BA
51581-4-W-F04-004 51581-4-W-F04-005	Addition-Across Room 422 (Hallway) North, Fountain 1 Addition-Across Room 422 (Hallway) North, Fountain 1 Addition-Across Room 422 (Hallway) North, Fountain 1	6/17/16 5:00 AM 6/17/16 5:00 AM	2.35 0.367	BA BA
51581-4-N-F05-002 51581-4-N-F05-002	Addition-Across Room 405 (Hallway) East, Fountain 1 Addition-Across Room 405 (Hallway) East, Fountain 1 Addition-Across Room 405 (Hallway) East Fountain 1	6/17/16 5:00 AM 6/17/16 5:00 AM 6/17/16 5:00 AM	0.193	BA BA
51581-4-N-F05-034 51581-4-N-F05-035	Addition-Across Room 405 (Hallway) East, Fountain 1 Addition-Across Room 405 (Hallway) East, Fountain 1 Addition-Across Room 405 (Hallway) East, Fountain 1	6/17/16/5/00 AM 6/17/16/5/00 AM 6/17/16/5/00 AM	0.229 0.332 0.291	BA BA
21 22 1 1 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2	Addition-Across Room 405 (Hallway) West, Fountain 2	6/17/16 5:00 AM	0.273	BA
51581-4-N-F05-022	Addition-Across Room 405 (Hallway) West, Fountain 2 Addition-Across Room 405 (Hallway) West, Fountain 2	6/17/16 5:00 AM	0.257	BA

51581-4-N-F0G-036
51581-4-N-F0G-035
EPA ACTION LEVEL FOR LEAD IS 35 ppb or 35 pg/k
SPREAGSHET LIGGIND
ND-Not Detected at the Reporting Limit
BA-delow EPA Action Level of 15 ppb
AA-Above EPA Action Level