



School Lead Water Testing - Data Collection Form

School Short Name **Peirce**
Address 1423 Bryn Mawr Ave.

Length of time water remained in pipes before sampled (hours) ¹¹
Report based on lab results dated 5/28/16
Date of test 05/28/16
Water last used (Time and date)

Sample ID #	Sample Location	Sample Collection Time & Date	Test Result (ppb)	Test Results
1-S-F01-01	Original Building D.F. by 103	5/28/16	None Detected	ND
1-S-F01-02	Original Building D.F. by 103	5/28/16	None Detected	ND
1-S-F01-03	Original Building D.F. by 103	5/28/16	None Detected	ND
1-S-F01-04	Original Building D.F. by 103	5/28/16	None Detected	ND
1-S-F01-05	Original Building D.F. by 103	5/28/16	None Detected	ND
1-S-F02-06	Original Building D.F. by 103	5/28/16	None Detected	ND
1-S-F02-07	Original Building D.F. by 103	5/28/16	None Detected	ND
1-S-F02-08	Original Building D.F. by 103	5/28/16	None Detected	ND
1-S-F02-09	Original Building D.F. by 103	5/28/16	None Detected	ND
1-S-F02-10	Original Building D.F. by 103	5/28/16	None Detected	ND
1-W-F01-11	Original Building D.F. by 102	5/28/16	None Detected	ND
1-W-F01-12	Original Building D.F. by 102	5/28/16	None Detected	ND
1-W-F01-13	Original Building D.F. by 102	5/28/16	None Detected	ND
1-W-F01-14	Original Building D.F. by 102	5/28/16	None Detected	ND
1-W-F01-15	Original Building D.F. by 102	5/28/16	None Detected	ND
1-W-F02-16	Original Building D.F. by 102	5/28/16	None Detected	ND
1-W-F02-17	Original Building D.F. by 102	5/28/16	None Detected	ND
1-W-F02-18	Original Building D.F. by 102	5/28/16	None Detected	ND
1-W-F02-19	Original Building D.F. by 102	5/28/16	None Detected	ND
1-W-F02-20	Original Building D.F. by 102	5/28/16	None Detected	ND
1-W-F03-21	Original Building D.F. by 102	5/28/16	None Detected	ND
1-W-F03-22	Original Building D.F. by 102	5/28/16	None Detected	ND
1-W-F03-23	Original Building D.F. by 102	5/28/16	None Detected	ND
1-W-F03-24	Original Building D.F. by 102	5/28/16	None Detected	ND
1-W-F03-25	Original Building D.F. by 102	5/28/16	None Detected	ND
1-S-F01-26	Original Building - Outside Main Office	5/28/16	None Detected	ND
1-S-F01-27	Original Building - Outside Main Office	5/28/16	None Detected	ND
1-S-F01-28	Original Building - Outside Main Office	5/28/16	None Detected	ND
1-S-F01-29	Original Building - Outside Main Office	5/28/16	None Detected	ND
1-S-F01-30	Original Building - Outside Main Office	5/28/16	None Detected	ND
1-S-F02-31	Original Building - Outside Main Office	5/28/16	None Detected	ND

Sample ID #	Sample Location	Sample Collection Time & Date	Test Result (ppb)	Test Results
1-S-F02-32	Original Building - Outside Main Office	5/28/16	None Detected	ND
1-S-F02-33	Original Building - Outside Main Office	5/28/16	None Detected	ND
1-S-F02-34	Original Building - Outside Main Office	5/28/16	None Detected	ND
1-S-F02-35	Original Building - Outside Main Office	5/28/16	None Detected	ND
1-W-CS01-36	Original Building - Classroom 121	5/28/16	None Detected	ND
1-W-CS01-37	Original Building - Classroom 121	5/28/16	None Detected	ND
1-W-CS01-38	Original Building - Classroom 121	5/28/16	None Detected	ND
1-W-CS01-39	Original Building - Classroom 121	5/28/16	None Detected	ND
1-W-CS01-40	Original Building - Classroom 121	5/28/16	None Detected	ND
1-W-CS02-41	Original Building - Classroom 121	5/28/16	None Detected	ND
1-W-CS02-42	Original Building - Classroom 121	5/28/16	None Detected	ND
1-W-CS02-43	Original Building - Classroom 121	5/28/16	None Detected	ND
1-W-CS02-44	Original Building - Classroom 121	5/28/16	None Detected	ND
1-W-CS02-45	Original Building - Classroom 121	5/28/16	None Detected	ND
1-W-F01-46	Original Building - Classroom 121	5/28/16	None Detected	ND
1-W-F01-47	Original Building - Classroom 121	5/28/16	None Detected	ND
1-W-F01-48	Original Building - Classroom 121	5/28/16	None Detected	ND
1-W-F01-49	Original Building - Classroom 121	5/28/16	None Detected	ND
1-W-F01-50	Original Building - Classroom 121	5/28/16	None Detected	ND
1-W-CS01-51	Original Building - Classroom 128	5/28/16	None Detected	ND
1-W-CS01-52	Original Building - Classroom 128	5/28/16	None Detected	ND
1-W-CS01-53	Original Building - Classroom 128	5/28/16	None Detected	ND
1-W-CS01-54	Original Building - Classroom 128	5/28/16	None Detected	ND
1-W-CS01-55	Original Building - Classroom 128	5/28/16	None Detected	ND
1-W-CS02-56	Original Building - Classroom 128	5/28/16	None Detected	ND
1-W-CS01-57	Original Building - Classroom 128	5/28/16	None Detected	ND
1-W-CS01-58	Original Building - Classroom 128	5/28/16	None Detected	ND
1-W-CS01-59	Original Building - Classroom 128	5/28/16	None Detected	ND
1-W-CS01-60	Original Building - Classroom 128	5/28/16	None Detected	ND
1-W-CS01-61	Original Building - Classroom 122	5/28/16	None Detected	ND
1-W-CS01-62	Original Building - Classroom 122	5/28/16	None Detected	ND
1-W-CS01-63	Original Building - Classroom 122	5/28/16	None Detected	ND
1-W-CS01-64	Original Building - Classroom 122	5/28/16	None Detected	ND
1-W-CS01-65	Original Building - Classroom 122	5/28/16	None Detected	ND
1-W-CS02-66	Original Building - Classroom 122	5/28/16	None Detected	ND
1-W-CS02-67	Original Building - Classroom 122	5/28/16	None Detected	ND
1-W-CS02-68	Original Building - Classroom 122	5/28/16	None Detected	ND

Sample ID #	Sample Location	Sample Collection Time & Date	Test Result (ppb)	Test Results
1-W-CS02-69	Original Building - Classroom 122	5/28/16	None Detected	ND
1-W-CS02-70	Original Building - Classroom 122	5/28/16	None Detected	ND
1-W-F01-71	Original Building - Classroom 122	5/28/16	None Detected	ND
1-W-F01-72	Original Building - Classroom 122	5/28/16	None Detected	ND
1-W-F01-73	Original Building - Classroom 122	5/28/16	None Detected	ND
1-W-F01-74	Original Building - Classroom 122	5/28/16	None Detected	ND
1-W-F01-75	Original Building - Classroom 122	5/28/16	None Detected	ND
1-W-CS01-76	Original Building - Classroom 126	5/28/16	None Detected	ND
1-W-CS01-77	Original Building - Classroom 126	5/28/16	None Detected	ND
1-W-CS01-78	Original Building - Classroom 126	5/28/16	None Detected	ND
1-W-CS01-79	Original Building - Classroom 126	5/28/16	None Detected	ND
1-W-CS01-80	Original Building - Classroom 126	5/28/16	None Detected	ND
1-W-CS02-81	Original Building - Classroom 126	5/28/16	None Detected	ND
1-W-CS02-82	Original Building - Classroom 126	5/28/16	None Detected	ND
1-W-CS02-83	Original Building - Classroom 126	5/28/16	None Detected	ND
1-W-CS02-84	Original Building - Classroom 126	5/28/16	None Detected	ND
1-W-CS02-85	Original Building - Classroom 126	5/28/16	None Detected	ND
1-W-CS01-86	Original Building - Classroom 123	5/28/16	None Detected	ND
1-W-CS01-87	Original Building - Classroom 123	5/28/16	None Detected	ND
1-W-CS01-88	Original Building - Classroom 123	5/28/16	None Detected	ND
1-W-CS01-89	Original Building - Classroom 123	5/28/16	None Detected	ND
1-W-CS01-90	Original Building - Classroom 123	5/28/16	None Detected	ND
1-W-CS02-91	Original Building - Classroom 123	5/28/16	None Detected	ND
1-W-CS02-92	Original Building - Classroom 123	5/28/16	None Detected	ND
1-W-CS02-93	Original Building - Classroom 123	5/28/16	None Detected	ND
1-W-CS02-94	Original Building - Classroom 123	5/28/16	None Detected	ND
1-W-CS02-95	Original Building - Classroom 123	5/28/16	None Detected	ND
3-W-F01-96	Original Building - 3rd Floor	5/28/16	None Detected	ND
3-W-F01-97	Original Building - 3rd Floor	5/28/16	None Detected	ND
3-W-F01-98	Original Building - 3rd Floor	5/28/16	None Detected	ND
3-W-F01-99	Original Building - 3rd Floor	5/28/16	None Detected	ND
3-W-F01-100	Original Building - 3rd Floor	5/28/16	None Detected	ND
3-W-F02-101	Original Building - 3rd Floor	5/28/16	None Detected	ND
3-W-F02-102	Original Building - 3rd Floor	5/28/16	None Detected	ND
3-W-F02-103	Original Building - 3rd Floor	5/28/16	None Detected	ND
3-W-F02-104	Original Building - 3rd Floor	5/28/16	None Detected	ND
3-W-F02-105	Original Building - 3rd Floor	5/28/16	None Detected	ND

Sample ID #	Sample Location	Sample Collection Time & Date	Test Result (ppb)	Test Results
3-W-F03-106	Original Building - 3rd Floor Southwest Corridor by 209	5/28/16	None Detected	ND
3-W-F03-107	Original Building - 3rd Floor Southwest Corridor by 209	5/28/16	None Detected	ND
3-W-F03-108	Original Building - 3rd Floor Southwest Corridor by 209	5/28/16	None Detected	ND
3-W-F03-109	Original Building - 3rd Floor Southwest Corridor by 209	5/28/16	None Detected	ND
3-W-F03-110	Original Building - 3rd Floor Southwest Corridor by 209	5/28/16	None Detected	ND
3-W-F01-111	Original Building - 3rd Floor Northwest Hallway	5/28/16	None Detected	ND
3-W-F01-112	Original Building - 3rd Floor Northwest Hallway	5/28/16	None Detected	ND
3-W-F01-113	Original Building - 3rd Floor Northwest Hallway	5/28/16	None Detected	ND
3-W-F01-114	Original Building - 3rd Floor Northwest Hallway	5/28/16	None Detected	ND
3-W-F01-115	Original Building - 3rd Floor Northwest Hallway	5/28/16	None Detected	ND
3-W-F02-116	Original Building - 3rd Floor Northeast Hallway	5/28/16	None Detected	ND
3-W-F02-117	Original Building - 3rd Floor Northeast Hallway	5/28/16	None Detected	ND
3-W-F02-118	Original Building - 3rd Floor Northeast Hallway	5/28/16	None Detected	ND
3-W-F02-119	Original Building - 3rd Floor Northeast Hallway	5/28/16	None Detected	ND
3-W-F02-120	Original Building - 3rd Floor Northeast Hallway	5/28/16	None Detected	ND
3-E-CS-121	Original Building - 3rd Floor Northeast Hallway	5/28/16	None Detected	ND
3-E-CS-122	Original Building - 3rd Floor Northeast Hallway	5/28/16	None Detected	ND
3-E-CS-123	Original Building - 3rd Floor Northeast Hallway	5/28/16	None Detected	ND
3-E-CS-124	Original Building - 3rd Floor Northeast Hallway	5/28/16	None Detected	ND
3-E-CS-125	Original Building - 3rd Floor Northeast Hallway	5/28/16	None Detected	ND
3-S-F01-126	New Building - 3rd Floor by 331	5/28/16	None Detected	ND
3-S-F01-127	New Building - 3rd Floor by 331	5/28/16	None Detected	ND
3-S-F01-128	New Building - 3rd Floor by 331	5/28/16	None Detected	ND
3-S-F01-129	New Building - 3rd Floor by 331	5/28/16	None Detected	ND
3-S-F01-130	New Building - 3rd Floor by 331	5/28/16	None Detected	ND
2-S-F01-131	New Building - 2nd Floor by 231	5/28/16	None Detected	ND
2-S-F01-132	New Building - 2nd Floor by 231	5/28/16	None Detected	ND
2-S-F01-133	New Building - 2nd Floor by 231	5/28/16	None Detected	ND
2-S-F01-134	New Building - 2nd Floor by 231	5/28/16	None Detected	ND
2-S-F01-135	New Building - 2nd Floor by 231	5/28/16	None Detected	ND
2-S-F02-136	New Building - 2nd Floor by 231	5/28/16	None Detected	ND
2-S-F02-137	New Building - 2nd Floor by 231	5/28/16	None Detected	ND
2-S-F02-138	New Building - 2nd Floor by 231	5/28/16	None Detected	ND
2-S-F02-139	New Building - 2nd Floor by 231	5/28/16	None Detected	ND
2-S-F02-140	New Building - 2nd Floor by 231	5/28/16	None Detected	ND
2-W-F01-141	Original Building - 2nd Floor Southwest Corridor by 209	5/28/16	None Detected	ND

Sample ID #	Sample Location	Sample Collection Time & Date	Test Result (ppb)	Test Results
2-W-F01-142	Original Building - 2nd Floor Southwest Corridor by 209	5/28/16	None Detected	ND
2-W-F01-143	Original Building - 2nd Floor Southwest Corridor by 209	5/28/16	None Detected	ND
2-W-F01-144	Original Building - 2nd Floor Southwest Corridor by 209	5/28/16	None Detected	ND
2-W-F01-145	Original Building - 2nd Floor Southwest Corridor by 209	5/28/16	None Detected	ND
2-W-F02-146	Original Building - 2nd Floor Southwest Corridor by 209	5/28/16	None Detected	ND
2-W-F02-147	Original Building - 2nd Floor Southwest Corridor by 209	5/28/16	None Detected	ND
2-W-F02-148	Original Building - 2nd Floor Southwest Corridor by 209	5/28/16	None Detected	ND
2-W-F02-149	Original Building - 2nd Floor Southwest Corridor by 209	5/28/16	None Detected	ND
2-W-F02-150	Original Building - 2nd Floor Southwest Corridor by 209	5/28/16	None Detected	ND
2-W-F03-151	Original Building - 2nd Floor Southwest Corridor by 209	5/28/16	None Detected	ND
2-W-F03-152	Original Building - 2nd Floor Southwest Corridor by 209	5/28/16	None Detected	ND
2-W-F03-153	Original Building - 2nd Floor Southwest Corridor by 209	5/28/16	None Detected	ND
2-W-F03-154	Original Building - 2nd Floor Southwest Corridor by 209	5/28/16	None Detected	ND
2-W-F03-155	Original Building - 2nd Floor Southwest Corridor by 209	5/28/16	17.7	AA
2-W-F01-156	Original Building - 2nd Floor Northwest Corridor by 207	5/28/16	None Detected	ND
2-W-F01-157	Original Building - 2nd Floor Northwest Corridor by 207	5/28/16	None Detected	ND
2-W-F01-158	Original Building - 2nd Floor Northwest Corridor by 207	5/28/16	None Detected	ND
2-W-F01-159	Original Building - 2nd Floor Northwest Corridor by 207	5/28/16	None Detected	ND
2-W-F01-160	Original Building - 2nd Floor Northwest Corridor by 207	5/28/16	None Detected	ND
1-S-CS01-161	New Building - Kitchen	5/28/16	None Detected	ND
1-S-CS01-162	New Building - Kitchen	5/28/16	None Detected	ND

Sample ID #	Sample Location	Sample Collection Time & Date	Test Result (ppb)	Test Results
1-S-CS01-163	New Building - Kitchen	5/28/16	None Detected	ND
1-S-CS01-164	New Building - Kitchen	5/28/16	None Detected	ND
1-S-CS01-165	New Building - Kitchen	5/28/16	None Detected	ND
1-W-CS01-166	New Building - Kitchen	5/28/16	None Detected	ND
1-W-CS01-167	New Building - Kitchen	5/28/16	None Detected	ND
1-W-CS01-168	New Building - Kitchen	5/28/16	None Detected	ND
1-W-CS01-169	New Building - Kitchen	5/28/16	None Detected	ND
1-W-CS01-170	New Building - Kitchen	5/28/16	None Detected	ND
1-N-CS01-171	New Building - Kitchen	5/28/16	None Detected	ND
1-N-CS01-172	New Building - Kitchen	5/28/16	None Detected	ND
1-N-CS01-173	New Building - Kitchen	5/28/16	None Detected	ND
1-N-CS01-174	New Building - Kitchen	5/28/16	None Detected	ND
1-N-CS01-175	New Building - Kitchen	5/28/16	None Detected	ND

EPA ACTION LEVEL FOR LEAD IS 15 ppb or 15 µg/L

SPREADSHEET LEGEND

ND-Not Detected at CCA Reporting Limit

BA-Below EPA Action Level of 15 ppb

AA-Above EPA Action Level

Chicago Public Schools - Department of Facility Operations