



| Sample ID #        | Sample Location                                    | Sample Collection Time & Date | Test Result (ppb) | Test Results |
|--------------------|--|-------------------------------|-------------------|--------------|
| 21311-E-01-F-001   | Main- 1st flr corridor, Fountain 1                 | 5/24/16 5:00 AM               | 0.704             | BA           |
| 21311-E-01-F-002   | Main-1st flr corridor, Fountain 1                  | 5/24/16 5:00 AM               | 0.314             | BA           |
| 21311-E-01-F-003   | Main- 1st flr corridor, Fountain 1                 | 5/24/16 5:00 AM               | <12               | NO           |
| 21311-E-01-F-004   | Main- 1st flr corridor, Fountain 1                 | 5/24/16 5:00 AM               | <12               | NO           |
| 21311-E-01-F-005   | Main- 1st flr corridor, Fountain 1                 | 5/24/16 5:00 AM               | <12               | NO           |
| 21311-E-3-F-001    | Main- 1st flr corridor, Fountain 2                 | 5/24/16 5:00 AM               | 0.248             | BA           |
| 21311-E-3-F-002    | Main- 1st flr corridor, Fountain 2                 | 5/24/16 5:00 AM               | 0.145             | BA           |
| 21311-E-3-F-003    | Main- 1st flr corridor, Fountain 2                 | 5/24/16 5:00 AM               | 0.167             | BA           |
| 21311-E-3-F-004    | Main- 1st flr corridor, Fountain 2                 | 5/24/16 5:00 AM               | 0.199             | BA           |
| 21311-E-3-F-005    | Main- 1st flr corridor, Fountain 2                 | 5/24/16 5:00 AM               | 0.232             | BA           |
| 21311-1-K-0-S-001  | Inside Kindergarten Room 114, Sink                 | 5/24/16 5:00 AM               | 12.1              | BA           |
| 21311-1-K-0-S-002  | Inside Kindergarten Room 114, Sink                 | 5/24/16 5:00 AM               | 2.64              | BA           |
| 21311-1-K-0-S-003  | Inside Kindergarten Room 114, Sink                 | 5/24/16 5:00 AM               | 3.47              | BA           |
| 21311-1-K-0-S-004  | Inside Kindergarten Room 114, Sink                 | 5/24/16 5:00 AM               | 4.16              | BA           |
| 21311-1-K-0-S-005  | Inside Kindergarten Room 114, Sink                 | 5/24/16 5:00 AM               | 3.24              | BA           |
| 21311-1-K-P-001    | Annex 1st Floor Kindergarten, Pot Sink             | 5/24/16 5:00 AM               | 0.277             | BA           |
| 21311-1-K-P-002    | Annex 1st Floor Kindergarten, Pot Sink             | 5/24/16 5:00 AM               | 0.248             | BA           |
| 21311-1-K-P-003    | Annex 1st Floor Kindergarten, Pot Sink             | 5/24/16 5:00 AM               | 0.231             | BA           |
| 21311-1-K-P-004    | Annex 1st Floor Kindergarten, Pot Sink             | 5/24/16 5:00 AM               | 0.219             | BA           |
| 21311-1-K-P-005    | Annex 1st Floor Kindergarten, Pot Sink             | 5/24/16 5:00 AM               | 0.85              | BA           |
| 21311-1-K-S-001    | Annex 1st Floor Kindergarten, Sink                 | 5/24/16 5:00 AM               | 0.316             | BA           |
| 21311-1-K-S-002    | Annex 1st Floor Kindergarten, Sink                 | 5/24/16 5:00 AM               | 0.417             | BA           |
| 21311-1-K-S-003    | Annex 1st Floor Kindergarten, Sink                 | 5/24/16 5:00 AM               | 0.747             | BA           |
| 21311-1-K-S-004    | Annex 1st Floor Kindergarten, Sink                 | 5/24/16 5:00 AM               | 0.872             | BA           |
| 21311-1-K-S-005    | Annex 1st Floor Kindergarten, Sink                 | 5/24/16 5:00 AM               | 0.404             | BA           |
| 21311-1-N-0-S-001  | Outside Kindergarten Room, Fountain                | 5/24/16 5:00 AM               | 0.576             | BA           |
| 21311-1-N-01-F-002 | Outside Kindergarten Room, Fountain                | 5/24/16 5:00 AM               | 1.148             | BA           |
| 21311-1-N-01-F-003 | Outside Kindergarten Room, Fountain                | 5/24/16 5:00 AM               | 0.405             | BA           |
| 21311-1-N-01-F-004 | Outside Kindergarten Room, Fountain                | 5/24/16 5:00 AM               | 0.412             | BA           |
| 21311-1-N-01-F-005 | Outside Kindergarten Room, Fountain                | 5/24/16 5:00 AM               | 0.413             | BA           |
| 21311-1-N-01-F-006 | Annex Outside LB, Fountain                         | 5/24/16 5:00 AM               | 0.801             | BA           |
| 21311-1-N-01-F-007 | Annex Outside LB, Fountain                         | 5/24/16 5:00 AM               | 0.679             | BA           |
| 21311-1-N-01-F-008 | Annex Outside LB, Fountain                         | 5/24/16 5:00 AM               | 0.509             | BA           |
| 21311-1-N-01-F-009 | Annex Outside LB, Fountain                         | 5/24/16 5:00 AM               | 0.536             | BA           |
| 21311-1-N-01-F-010 | Annex Outside LB, Fountain                         | 5/24/16 5:00 AM               | 0.514             | BA           |
| 21311-1-P-K-SF-001 | Annex 1st Floor Pre-K, Sink/Fountain               | 5/24/16 5:00 AM               | 1.11              | BA           |
| 21311-1-P-K-SF-002 | Annex 1st Floor Pre-K, Sink/Fountain               | 5/24/16 5:00 AM               | 0.639             | BA           |
| 21311-1-P-K-SF-003 | Annex 1st Floor Pre-K, Sink/Fountain               | 5/24/16 5:00 AM               | 0.466             | BA           |
| 21311-1-P-K-SF-004 | Annex 1st Floor Pre-K, Sink/Fountain               | 5/24/16 5:00 AM               | 0.469             | BA           |
| 21311-1-P-K-SF-005 | Annex 1st Floor Pre-K, Sink/Fountain               | 5/24/16 5:00 AM               | 0.566             | BA           |
| 21311-2-E-2-F-001  | Main- 2nd flr corridor, Outside Room 201, Fountain | 5/24/16 5:00 AM               | 4.1               | AA           |
| 21311-2-E-2-F-002  | Main- 2nd flr corridor, Outside Room 201, Fountain | 5/24/16 5:00 AM               | 1.64              | BA           |
| 21311-2-E-2-F-003  | Main- 2nd flr corridor, Outside Room 201, Fountain | 5/24/16 5:00 AM               | 0.541             | BA           |
| 21311-2-E-2-F-004  | Main- 2nd flr corridor, Outside Room 201, Fountain | 5/24/16 5:00 AM               | 0.416             | BA           |
| 21311-2-E-2-F-005  | Main- 2nd flr corridor, Outside Room 201, Fountain | 5/24/16 5:00 AM               | 0.446             | BA           |
| 21311-2-E-4-F-001  | Main- Outside Room 208, Fountain                   | 5/24/16 5:00 AM               | 2.75              | BA           |
| 21311-2-E-4-F-002  | Main- Outside Room 208, Fountain                   | 5/24/16 5:00 AM               | 2.16              | BA           |
| 21311-2-E-4-F-003  | Main- Outside Room 208, Fountain                   | 5/24/16 5:00 AM               | 2.18              | BA           |
| 21311-2-E-4-F-004  | Main- Outside Room 208, Fountain                   | 5/24/16 5:00 AM               | 2.15              | BA           |
| 21311-2-E-4-F-005  | Main- Outside Room 208, Fountain                   | 5/24/16 5:00 AM               | 2.31              | BA           |
| 21311-2-N-02-F-001 | Annex Outside Toilets, Fountain 1                  | 5/24/16 5:00 AM               | 0.776             | BA           |
| 21311-2-N-02-F-002 | Annex Outside Toilets, Fountain 1                  | 5/24/16 5:00 AM               | 0.753             | BA           |
| 21311-2-N-02-F-003 | Annex Outside Toilets, Fountain 1                  | 5/24/16 5:00 AM               | 0.849             | BA           |
| 21311-2-N-02-F-004 | Annex Outside Toilets, Fountain 1                  | 5/24/16 5:00 AM               | 0.945             | BA           |
| 21311-2-N-02-F-005 | Annex Outside Toilets, Fountain 1                  | 5/24/16 5:00 AM               | 0.975             | BA           |
| 21311-3-N-01-F-001 | Annex Outside Toilets, Fountain 2                  | 5/24/16 5:00 AM               | 1.11              | BA           |
| 2131               |  |                               |                   |              |

|                    |  |                 |       |    |
|--------------------|--|-----------------|-------|----|
| 609908-2-E-F03-001 | Main, 2nd floor, Outside Room 206, Fountain              | 6/21/16 5:00 AM | 0.975 | BA |
| 609908-2-E-F03-002 | Main, 2nd floor, Outside Room 206, Fountain              | 6/21/16 5:00 AM | 0.879 | BA |
| 609908-2-E-F03-003 | Main, 2nd floor, Outside Room 206, Fountain              | 6/21/16 5:00 AM | 0.84  | BA |
| 609908-2-E-F03-004 | Main, 2nd floor, Outside Room 206, Fountain              | 6/21/16 5:00 AM | 1.33  | BA |
| 609908-2-E-F03-005 | Main, 2nd floor, Outside Room 206, Fountain              | 6/21/16 5:00 AM | 2.04  | BA |
| 609908-3-C-F01-001 | Annex, 3rd floor, Across from Room 318 North, Fountain 1 | 6/21/16 5:00 AM | 0.927 | BA |
| 609908-3-C-F01-002 | Annex, 3rd floor, Across from Room 318 North, Fountain 1 | 6/21/16 5:00 AM | 0.918 | BA |
| 609908-3-C-F01-003 | Annex, 3rd floor, Across from Room 318 North, Fountain 1 | 6/21/16 5:00 AM | 0.911 | BA |
| 609908-3-C-F01-004 | Annex, 3rd floor, Across from Room 318 North, Fountain 1 | 6/21/16 5:00 AM | 0.959 | BA |
| 609908-3-C-F01-005 | Annex, 3rd floor, Across from Room 318 North, Fountain 1 | 6/21/16 5:00 AM | 1.24  | BA |
| 609908-3-C-F02-001 | Annex, 3rd floor, Across from Room 318 South, Fountain 2 | 6/21/16 5:00 AM | 1.08  | BA |
| 609908-3-C-F02-002 | Annex, 3rd floor, Across from Room 318 South, Fountain 2 | 6/21/16 5:00 AM | 1.13  | BA |
| 609908-3-C-F02-003 | Annex, 3rd floor, Across from Room 318 South, Fountain 2 | 6/21/16 5:00 AM | 1.14  | BA |
| 609908-3-C-F02-004 | Annex, 3rd floor, Across from Room 318 South, Fountain 2 | 6/21/16 5:00 AM | 1.41  | BA |
| 609908-3-C-F02-005 | Annex, 3rd floor, Across from Room 318 South, Fountain 2 | 6/21/16 5:00 AM | 1.34  | BA |
| 609908-B-W-F01-001 | Main, Basement, Lunchroom Fountain                       | 6/21/16 5:00 AM | 10.1  | BA |
| 609908-B-W-F01-002 | Main, Basement, Lunchroom Fountain                       | 6/21/16 5:00 AM | 16    | AA |
| 609908-B-W-F01-003 | Main, Basement, Lunchroom Fountain                       | 6/21/16 5:00 AM | 10.2  | BA |
| 609908-B-W-F01-004 | Main, Basement, Lunchroom Fountain                       | 6/21/16 5:00 AM | 6.74  | BA |
| 609908-B-W-F01-005 | Main, Basement, Lunchroom Fountain                       | 6/21/16 5:00 AM | 4.89  | BA |

EPA ACTION LEVEL FOR LEAD IS 15 ppb or 15 µg/L

**SREADSHEET LEGEND**  
 ND-Not Detected at the Reporting Limit  
 BA-Below EPA Action Level of 15 ppb  
 AA-Above EPA Action Level

Chicago Public Schools - Department of Facility Operations