



School Lead Water Testing Summary

School Short Name **Westcott / Annex**
Address 409 W. 80th St
Facility ID 51394
CPS Team Member Craig Edgerley
MEC Team Member Evan Christian

Length of time water remained in pipes before sampled [Approx 9 hours](#)
Water last used (Time and date) [Approx 10 PM 5/4/16](#)
Date of test [5/5/2016](#)
Report based on lab results dated [5/10/2016](#)

Sample ID #	Sample Location	Sample Collection Time & Date	Test Results (ppb)	ppb Level
51394-1-K-CS-01	Kitchen	6:37 AM 5/5/16	ND	-
51394-1-W-F-02	Gymnasium	6:42 AM 5/5/16	ND	-
51394-1-C-F-03	Hallway by Lunchroom	6:45 AM 5/5/16	ND	-
51394-2-C-F-04	Hallway by Room 206	6:48 AM 5/5/16	ND	-
51394-3-C-F-05	Hallway by Room 306	6:51 AM 5/5/16	ND	-
51394-1-S-WC-06A	Hallway by Room 111	6:44 AM 5/5/16	ND	-

EPA ACTION LEVEL FOR LEAD IS 15 ppb or 15 µg/L

SPREADSHEET LEGEND

ND-Not Detected at the Reporting Limit
BA-Below EPA Action Level of 15 ppb
AA-Above EPA Action Level

Chicago Public Schools - Department of Facility Operations