



School Lead Water Testing - Data Collection Form

School Short Name **Von Linne**
Address 3221 N Sacramento Ave

Length of time water remained in pipes before sampled (hours) 13.00
Report based on lab results dated 6/3/16
Date of test 05/24/16
Water last used (Time and date) Approx 5 AM 5/23/16

Sample ID #	Sample Location	Sample Collection Time & Date	Test Result (ppb)	Test Results
24201-B-E01-F-001	N. Basement dance studio, Fountain	5/24/16 5:00 AM	10.3	BA
24201-B-E01-F-002	N. Basement dance studio, Fountain	5/24/16 5:00 AM	ND	ND
24201-B-E01-F-003	N. Basement dance studio, Fountain	5/24/16 5:00 AM	7.82	BA
24201-B-E01-F-004	N. Basement dance studio, Fountain	5/24/16 5:00 AM	5.4	BA
24201-B-E01-F-005	N. Basement dance studio, Fountain	5/24/16 5:00 AM	ND	ND
24201-B-E02-F-001	2nd Floor across from 209A, Fountain	5/24/16 5:00 AM	ND	ND
24201-B-E02-F-002	2nd Floor across from 209A, Fountain	5/24/16 5:00 AM	ND	ND
24201-B-E02-F-003	2nd Floor across from 209A, Fountain	5/24/16 5:00 AM	ND	ND
24201-B-E02-F-004	2nd Floor across from 209A, Fountain	5/24/16 5:00 AM	ND	ND
24201-B-E02-F-005	2nd Floor across from 209A, Fountain	5/24/16 5:00 AM	ND	ND
24201-2-E01-F-001	2nd floor across from 201, Fountain	5/24/16 5:00 AM	ND	ND
24201-2-E01-F-002	2nd floor across from 201, Fountain	5/24/16 5:00 AM	ND	ND
24201-2-E01-F-003	2nd floor across from 201, Fountain	5/24/16 5:00 AM	ND	ND
24201-2-E01-F-004	2nd floor across from 201, Fountain	5/24/16 5:00 AM	ND	ND
24201-2-E01-F-005	2nd floor across from 201, Fountain	5/24/16 5:00 AM	ND	ND
24201-2-N01-F-001	2nd floor annex, across from 224, Fountain	5/24/16 5:00 AM	ND	ND
24201-2-N01-F-002	2nd floor annex, across from 224, Fountain	5/24/16 5:00 AM	ND	ND
24201-2-N01-F-003	2nd floor annex, across from 224, Fountain	5/24/16 5:00 AM	ND	ND
24201-2-N01-F-004	2nd floor annex, across from 224, Fountain	5/24/16 5:00 AM	ND	ND
24201-2-N01-F-005	2nd floor annex, across from 224, Fountain	5/24/16 5:00 AM	ND	ND
24201-3-E01-F-001	3rd Floor across from 315, Fountain	5/24/16 5:00 AM	ND	ND
24201-3-E01-F-002	3rd Floor across from 315, Fountain	5/24/16 5:00 AM	ND	ND
24201-3-E01-F-003	3rd Floor across from 315, Fountain	5/24/16 5:00 AM	ND	ND
24201-3-E01-F-004	3rd Floor across from 315, Fountain	5/24/16 5:00 AM	ND	ND
24201-3-E01-F-005	3rd Floor across from 315, Fountain	5/24/16 5:00 AM	ND	ND
24201-3-E02-F-001	3rd Floor across from 301, Fountain	5/24/16 5:00 AM	ND	ND
24201-3-E02-F-002	3rd Floor across from 301, Fountain	5/24/16 5:00 AM	ND	ND
24201-3-E02-F-003	3rd Floor across from 301, Fountain	5/24/16 5:00 AM	ND	ND
24201-3-E02-F-004	3rd Floor across from 301, Fountain	5/24/16 5:00 AM	ND	ND
24201-3-E02-F-005	3rd Floor across from 301, Fountain	5/24/16 5:00 AM	ND	ND
24201-1-N01-S-001	Annex, 1st floor kitchen, Sink	5/24/16 5:00 AM	ND	ND
24201-1-N01-S-002	Annex, 1st floor kitchen, Sink	5/24/16 5:00 AM	ND	ND
24201-1-N01-S-003	Annex, 1st floor kitchen, Sink	5/24/16 5:00 AM	ND	ND
24201-1-N01-S-004	Annex, 1st floor kitchen, Sink	5/24/16 5:00 AM	ND	ND
24201-1-N01-S-005	Annex, 1st floor kitchen, Sink	5/24/16 5:00 AM	ND	ND

24201-1-N02-S-001	Annex, 1st floor room 120, Sink	5/24/16 5:00 AM	ND	ND
24201-1-N02-S-002	Annex, 1st floor room 120, Sink	5/24/16 5:00 AM	ND	ND
24201-1-N02-S-003	Annex, 1st floor room 120, Sink	5/24/16 5:00 AM	ND	ND
24201-1-N02-S-004	Annex, 1st floor room 120, Sink	5/24/16 5:00 AM	ND	ND
24201-1-N02-S-005	Annex, 1st floor room 120, Sink	5/24/16 5:00 AM	ND	ND
24201-1-N03-S-001	Annex, 1st floor room 122, Sink	5/24/16 5:00 AM	ND	ND
24201-1-N03-S-002	Annex, 1st floor room 122, Sink	5/24/16 5:00 AM	ND	ND
24201-1-N03-S-003	Annex, 1st floor room 122, Sink	5/24/16 5:00 AM	ND	ND
24201-1-N03-S-004	Annex, 1st floor room 122, Sink	5/24/16 5:00 AM	ND	ND
24201-1-N03-S-005	Annex, 1st floor room 122, Sink	5/24/16 5:00 AM	ND	ND
24201-1-N04-F-001	Annex, 1st floor room 122, Fountain	5/24/16 5:00 AM	ND	ND
24201-1-N04-F-002	Annex, 1st floor room 122, Fountain	5/24/16 5:00 AM	ND	ND
24201-1-N04-F-003	Annex, 1st floor room 122, Fountain	5/24/16 5:00 AM	ND	ND
24201-1-N04-F-004	Annex, 1st floor room 122, Fountain	5/24/16 5:00 AM	ND	ND
24201-1-N04-F-005	Annex, 1st floor room 122, Fountain	5/24/16 5:00 AM	ND	ND
24201-1-N05-S-001	Annex, 1st floor room 124, Sink	5/24/16 5:00 AM	ND	ND
24201-1-N05-S-002	Annex, 1st floor room 124, Sink	5/24/16 5:00 AM	ND	ND
24201-1-N05-S-003	Annex, 1st floor room 124, Sink	5/24/16 5:00 AM	ND	ND
24201-1-N05-S-004	Annex, 1st floor room 124, Sink	5/24/16 5:00 AM	ND	ND
24201-1-N05-S-005	Annex, 1st floor room 124, Sink	5/24/16 5:00 AM	ND	ND
24201-1-E01-S-001	Annex, 1st floor room 128, Sink	5/24/16 5:00 AM	ND	ND
24201-1-E01-S-002	Annex, 1st floor room 128, Sink	5/24/16 5:00 AM	ND	ND
24201-1-E01-S-003	Annex, 1st floor room 128, Sink	5/24/16 5:00 AM	ND	ND
24201-1-E01-S-004	Annex, 1st floor room 128, Sink	5/24/16 5:00 AM	ND	ND
24201-1-E01-S-005	Annex, 1st floor room 128, Sink	5/24/16 5:00 AM	ND	ND
24201-1-E02-S-001	Annex, 1st floor room 130, Sink	5/24/16 5:00 AM	ND	ND
24201-1-E02-S-002	Annex, 1st floor room 130, Sink	5/24/16 5:00 AM	ND	ND
24201-1-E02-S-003	Annex, 1st floor room 130, Sink	5/24/16 5:00 AM	ND	ND
24201-1-E02-S-004	Annex, 1st floor room 130, Sink	5/24/16 5:00 AM	ND	ND
24201-1-E02-S-005	Annex, 1st floor room 130, Sink	5/24/16 5:00 AM	ND	ND
24201-1-E03-S-001	Annex, 1st floor culinary, Sink	5/24/16 5:00 AM	ND	ND
24201-1-E03-S-002	Annex, 1st floor culinary, Sink	5/24/16 5:00 AM	ND	ND
24201-1-E03-S-003	Annex, 1st floor culinary, Sink	5/24/16 5:00 AM	ND	ND
24201-1-E03-S-004	Annex, 1st floor culinary, Sink	5/24/16 5:00 AM	ND	ND
24201-1-E03-S-005	Annex, 1st floor culinary, Sink	5/24/16 5:00 AM	ND	ND

EPA ACTION LEVEL FOR LEAD IS 15 ppb or 15 µg/L

SPREADSHEET LEGEND

ND-Not Detected at the Reporting Limit

BA-Below EPA Action Level of 15 ppb

AA-Above EPA Action Level