



School Lead Water Testing - Data Collection Form

School Short Name **Blair**

Length of time water remained in pipes before sampled (hours)  
Report based on lab results dated  
Date of test  
Water last used (Time and date)

13.00  
6/9/16  
05/28/16  
Approx 4 PM 5/27/16

Sample ID #	Sample Location	Sample Collection Time & Date	Test Result (ppb)	Test Results
51304-1-W-S01-001	Kitchen Sink West	5/28/16 5:00 AM	3.03	BA
51304-1-W-S01-002	Kitchen Sink West	5/28/16 5:00 AM	0.523	BA
51304-1-W-S01-003	Kitchen Sink West	5/28/16 5:00 AM	0.466	BA
51304-1-W-S01-004	Kitchen Sink West	5/28/16 5:00 AM	0.548	BA
51304-1-W-S01-005	Kitchen Sink West	5/28/16 5:00 AM	0.664	BA
51304-1-W-S02-001	Kitchen Sink East	5/28/16 5:00 AM	2.3	BA
51304-1-W-S02-002	Kitchen Sink East	5/28/16 5:00 AM	0.262	BA
51304-1-W-S02-003	Kitchen Sink East	5/28/16 5:00 AM	0.231	BA
51304-1-W-S02-004	Kitchen Sink East	5/28/16 5:00 AM	0.285	BA
51304-1-W-S02-005	Kitchen Sink East	5/28/16 5:00 AM	0.221	BA
51304-1-S-S03-001	Rem 113, Sink	5/28/16 5:00 AM	<0.120	ND
51304-1-S-S03-002	Rem 113, Sink	5/28/16 5:00 AM	<0.120	ND
51304-1-S-S03-003	Rem 113, Sink	5/28/16 5:00 AM	<0.120	ND
51304-1-S-S03-004	Rem 113, Sink	5/28/16 5:00 AM	<0.120	ND
51304-1-S-S03-005	Rem 113, Sink	5/28/16 5:00 AM	0.936	BA
51304-1-S-S04-001	Rem 114, Sink	5/28/16 5:00 AM	<0.120	ND
51304-1-S-S04-002	Rem 114, Sink	5/28/16 5:00 AM	<0.120	ND
51304-1-S-S04-003	Rem 114, Sink	5/28/16 5:00 AM	0.147	BA
51304-1-S-S04-004	Rem 114, Sink	5/28/16 5:00 AM	<0.120	ND
51304-1-S-S04-005	Rem 114, Sink	5/28/16 5:00 AM	<0.120	ND
51304-1-S-S05-001	Rem 112, Sink	5/28/16 5:00 AM	<0.120	ND
51304-1-S-S05-002	Rem 112, Sink	5/28/16 5:00 AM	<0.120	ND
51304-1-S-S05-003	Rem 112, Sink	5/28/16 5:00 AM	<0.120	ND
51304-1-S-S05-004	Rem 112, Sink	5/28/16 5:00 AM	1.45	BA
51304-1-S-S05-005	Rem 112, Sink	5/28/16 5:00 AM	1.31	BA
51304-1-S-S06-001	Rem 117, Sink	5/28/16 5:00 AM	0.215	BA
51304-1-S-S06-002	Rem 117, Sink	5/28/16 5:00 AM	1.45	BA
51304-1-S-S06-003	Rem 117, Sink	5/28/16 5:00 AM	1.47	BA
51304-1-S-S06-004	Rem 117, Sink	5/28/16 5:00 AM	2.78	BA
51304-1-S-S06-005	Rem 117, Sink	5/28/16 5:00 AM	2.46	BA
51304-1-S-S07-001	Rem 115, Sink	5/28/16 5:00 AM	1.11	BA
51304-1-S-S07-002	Rem 115, Sink	5/28/16 5:00 AM	1.05	BA
51304-1-S-S07-003	Rem 115, Sink	5/28/16 5:00 AM	0.275	BA
51304-1-S-S07-004	Rem 115, Sink	5/28/16 5:00 AM	0.546	BA
51304-1-S-S07-005	Rem 115, Sink	5/28/16 5:00 AM	1.06	BA
51304-1-S-S08-001	Rem 115, Sink	5/28/16 5:00 AM	1.86	BA
51304-1-S-S08-002	Rem 115, Sink	5/28/16 5:00 AM	2.3	BA
51304-1-S-S08-003	Rem 115, Sink	5/28/16 5:00 AM	1.40	BA
51304-1-S-S08-004	Rem 115, Sink	5/28/16 5:00 AM	1.05	BA
51304-1-S-S08-005	Rem 115, Sink	5/28/16 5:00 AM	1.07	BA
51304-1-S-S09-001	Rem 113, Sink	5/28/16 5:00 AM	0.46	BA
51304-1-S-S09-002	Rem 113, Sink	5/28/16 5:00 AM	1.13	BA
51304-1-S-S09-003	Rem 113, Sink	5/28/16 5:00 AM	0.386	BA
51304-1-S-S09-004	Rem 113, Sink	5/28/16 5:00 AM	0.413	BA
51304-1-S-S09-005	Rem 113, Sink	5/28/16 5:00 AM	3.8	BA
51304-1-S-F10-001	East Fountain 1, across from Rem 113	5/28/16 5:00 AM	<0.120	ND
51304-1-S-F10-002	East Fountain 1, across from Rem 113	5/28/16 5:00 AM	0.155	BA
51304-1-S-F10-003	East Fountain 1, across from Rem 113	5/28/16 5:00 AM	0.121	BA
51304-1-S-F10-004	East Fountain 1, across from Rem 113	5/28/16 5:00 AM	<0.120	ND
51304-1-S-F10-005	East Fountain 1, across from Rem 113	5/28/16 5:00 AM	<0.120	ND
51304-1-S-F11-001	West Fountain 2, across from Rem 113	5/28/16 5:00 AM	<0.120	ND
51304-1-S-F11-002	West Fountain 2, across from Rem 113	5/28/16 5:00 AM	0.241	BA
51304-1-S-F11-003	West Fountain 2, across from Rem 113	5/28/16 5:00 AM	0.44	BA
51304-1-S-F11-004	West Fountain 2, across from Rem 113	5/28/16 5:00 AM	0.194	BA
51304-1-S-F11-005	West Fountain 2, across from Rem 113	5/28/16 5:00 AM	0.214	BA
51304-1-N-F16-001	Outside Rem 108, Fountain	5/28/16 5:00 AM	937	AA
51304-1-N-F16-002	Outside Rem 108, Fountain	5/28/16 5:00 AM	29.4	AA
51304-1-N-F16-003	Outside Rem 108, Fountain	5/28/16 5:00 AM	14.4	AA
51304-1-N-F16-004	Outside Rem 108, Fountain	5/28/16 5:00 AM	19.3	AA
51304-1-N-F16-005	Outside Rem 108, Fountain	5/28/16 5:00 AM	11.9	AA
51304-1-N-S13-001	Rem 108, Sink	5/28/16 5:00 AM	0.99	BA
51304-1-N-S13-002	Rem 108, Sink	5/28/16 5:00 AM	0.17	BA
51304-1-N-S13-003	Rem 108, Sink	5/28/16 5:00 AM	<0.120	ND
51304-1-N-S13-004	Rem 108, Sink	5/28/16 5:00 AM	<0.120	ND
51304-1-N-S13-005	Rem 108, Sink	5/28/16 5:00 AM	<0.120	ND
51304-1-N-F14-001	Fountain across from Lunch Room, Courtyard	5/28/16 5:00 AM	<0.120	ND
51304-1-N-F14-002	Fountain across from Lunch Room, Courtyard	5/28/16 5:00 AM	<0.120	ND
51304-1-N-F14-003	Fountain across from Lunch Room, Courtyard	5/28/16 5:00 AM	<0.120	ND
51304-1-N-F14-004	Fountain across from Lunch Room, Courtyard	5/28/16 5:00 AM	<0.120	ND
51304-1-N-F14-005	Fountain across from Lunch Room, Courtyard	5/28/16 5:00 AM	<0.120	ND
51304-1-N-S15-001	Teachers Lunch Rm, Sink	5/28/16 5:00 AM	0.19	BA
51304-1-N-S15-002	Teachers Lunch Rm, Sink	5/28/16 5:00 AM	0.405	BA
51304-1-N-S15-003	Teachers Lunch Rm, Sink	5/28/16 5:00 AM	<0.120	ND
51304-1-N-S15-004	Teachers Lunch Rm, Sink	5/28/16 5:00 AM	<0.120	ND
51304-1-N-S15-005	Teachers Lunch Rm, Sink	5/28/16 5:00 AM	<0.120	ND
51304-1-N-S12-001	Rem 111, Sink	5/28/16 5:00 AM	49	AA
51304-1-N-S12-002	Rem 111, Sink	5/28/16 5:00 AM	16.8	AA
51304-1-N-S12-003	Rem 111, Sink	5/28/16 5:00 AM	59	AA
51304-1-N-S12-004	Rem 111, Sink	5/28/16 5:00 AM	21.3	AA
51304-1-N-S12-005	Rem 111, Sink	5/28/16 5:00 AM	31.7	AA
51304-1-N-S17-001	Rem 108, Sink	5/28/16 5:00 AM	85.4	AA
51304-1-N-S17-002	Rem 108, Sink	5/28/16 5:00 AM	23.3	AA
51304-1-N-S17-003	Rem 108, Sink	5/28/16 5:00 AM	24.8	AA
51304-1-N-S17-004	Rem 108, Sink	5/28/16 5:00 AM	35.4	AA
51304-1-N-S17-005	Rem 108, Sink	5/28/16 5:00 AM	1.69	BA
51304-1-S-B18-001	Rem 107, Sink	5/28/16 5:00 AM	3.88	BA
51304-1-S-B18-002	Rem 107, Sink	5/28/16 5:00 AM	7.1	BA
51304-1-S-B18-003	Rem 107, Sink	5/28/16 5:00 AM	1.35	BA
51304-1-S-B18-004	Rem 107, Sink	5/28/16 5:00 AM	4.72	BA
51304-1-S-B18-005	Rem 107, Sink	5/28/16 5:00 AM	6.41	BA
51304-1-N-S19-001	Rem 106, Sink	5/28/16 5:00 AM	1100	AA
51304-1-N-S19-002	Rem 106, Sink	5/28/16 5:00 AM	806	AA
51304-1-N-S19-003	Rem 106, Sink	5/28/16 5:00 AM	432	AA
51304-1-N-S19-004	Rem 106, Sink	5/28/16 5:00 AM	36.7	AA
51304-1-N-S19-005	Rem 106, Sink	5/28/16 5:00 AM	8.37	BA
51304-1-S-S20-001	Rem 105, Sink	5/28/16 5:00 AM	6.13	BA
51304-1-S-S20-002	Rem 105, Sink	5/28/16 5:00 AM	4.94	BA
51304-1-S-S20-003	Rem 105, Sink	5/28/16 5:00 AM	5.12	BA
51304-1-S-S20-004	Rem 105, Sink	5/28/16 5:00 AM	4.47	BA
51304-1-S-S20-005	Rem 105, Sink	5/28/16 5:00 AM	5.08	BA
51304-1-N-S21-001	Rem 204, Sink	5/28/16 5:00 AM	6.95	BA
51304-1-N-S21-002	Rem 204, Sink	5/28/16 5:00 AM	6.01	BA
51304-1-N-S21-003	Rem 204, Sink	5/28/16 5:00 AM	4.4	BA
51304-1-N-S21-004	Rem 204, Sink	5/28/16 5:00 AM	6.66	BA
51304-1-N-S21-005	Rem 204, Sink	5/28/16 5:00 AM	6.46	BA
51304-1-S-S22-001	Rem 103, Sink	5/28/16 5:00 AM	2.49	BA
51304-1-S-S22-002	Rem 103, Sink	5/28/16 5:00 AM	2.87	BA
51304-1-S-S22-003	Rem 103, Sink	5/28/16 5:00 AM	2.8	BA
51304-1-S-S22-004	Rem 103, Sink	5/28/16 5:00 AM	2.87	BA
51304-1-S-S22-005	Rem 103, Sink	5/28/16 5:00 AM	1.71	BA
51304-1-N-S23-001	Rem 1020, Sink	5/28/16 5:00 AM	10.1	BA
51304-1-N-S23-002	Rem 1020, Sink	5/28/16 5:00 AM	9.59	BA
51304-1-N-S23-003	Rem 1020, Sink	5/28/16 5:00 AM	1.61	BA
51304-1-N-S23-004	Rem 1020, Sink	5/28/16 5:00 AM	2.34	BA
51304-1-N-S23-005	Rem 1020, Sink	5/28/16 5:00 AM	2.11	BA
51304-1-N-F24-001	Fountain across from Boiler Rm	5/28/16 5:00 AM	2.73	BA
51304-1-N-F24-002	Fountain across from Boiler Rm	5/28/16 5:00 AM	2.22	BA
51304-1-N-F24-003	Fountain across from Boiler Rm	5/28/16 5:00 AM	1.72	BA
51304-1-N-F24-004	Fountain across from Boiler Rm	5/28/16 5:00 AM	1.89	BA
51304-1-N-F24-005	Fountain across from Boiler Rm	5/28/16 5:00 AM	1.87	BA
51304-1-N-S25-001	Rem 100, Sink	5/28/16 5:00 AM	1.4	BA
51304-1-N-S25-002	Rem 100, Sink	5/28/16 5:00 AM	1.71	BA
51304-1-N-S25-003	Rem 100, Sink	5/28/16 5:00 AM	2.13	BA
51304-1-N-S25-004	Rem 100, Sink	5/28/16 5:00 AM	1.98	BA
51304-1-N-S25-005	Rem 100, Sink	5/28/16 5:00 AM	0.964	BA

EPA ACTION LEVEL FOR LEAD IS 15 ppb or 15 µg/L

SPREADSHEET LEGEND  
ND-Not Detected at the Reporting Limit  
BA-Below EPA Action Level of 15 ppb  
AA-Above EPA Action Level