



School Lead Water Testing - Data Collection Form

School Name

Marquette

Sample ID #	Sample Location	Sample Collection Time & Date	Test Result (ppb)	Test Results
51300-1-N-F01-001	Main- Outside Room 117, Fountain	5/28/16 5:00 AM	0.9	BA
51300-1-N-F01-002	Main- Outside Room 117, Fountain	5/28/16 5:00 AM	0.881	BA
51300-1-N-F01-003	Main- Outside Room 117, Fountain	5/28/16 5:00 AM	0.659	BA
51300-1-N-F01-004	Main- Outside Room 117, Fountain	5/28/16 5:00 AM	0.691	BA
51300-1-N-F01-005	Main- Outside Room 117, Fountain	5/28/16 5:00 AM	0.996	BA
51300-1-N-F02-001	Main- Outside Room 115, Fountain 1	5/28/16 5:00 AM	0.321	BA
51300-1-N-F02-002	Main- Outside Room 115, Fountain 1	5/28/16 5:00 AM	0.367	BA
51300-1-N-F02-003	Main- Outside Room 115, Fountain 1	5/28/16 5:00 AM	0.366	BA
51300-1-N-F02-004	Main- Outside Room 115, Fountain 1	5/28/16 5:00 AM	0.422	BA
51300-1-N-F02-005	Main- Outside Room 115, Fountain 1	5/28/16 5:00 AM	0.384	BA
51300-1-N-F03-001	Main- Outside Room 115, Fountain 2	5/28/16 5:00 AM	0.429	BA
51300-1-N-F03-002	Main- Outside Room 115, Fountain 2	5/28/16 5:00 AM	0.324	BA
51300-1-N-F03-003	Main- Outside Room 115, Fountain 2	5/28/16 5:00 AM	0.32	BA
51300-1-N-F03-004	Main- Outside Room 115, Fountain 2	5/28/16 5:00 AM	0.319	BA
51300-1-N-F03-005	Main- Outside Room 115, Fountain 2	5/28/16 5:00 AM	0.304	BA
51300-1-N-F04-001	Main- Outside Room 115, Fountain 3	5/28/16 5:00 AM	1.75	BA
51300-1-N-F04-002	Main- Outside Room 115, Fountain 3	5/28/16 5:00 AM	1.02	BA
51300-1-N-F04-003	Main- Outside Room 115, Fountain 3	5/28/16 5:00 AM	0.603	BA
51300-1-N-F04-004	Main- Outside Room 115, Fountain 3	5/28/16 5:00 AM	0.558	BA
51300-1-N-F04-005	Main- Outside Room 115, Fountain 3	5/28/16 5:00 AM	0.538	BA
51300-1-S-F05-001	Main- Outside Room 107, Fountain	5/28/16 5:00 AM	1.15	BA
51300-1-S-F05-002	Main- Outside Room 107, Fountain	5/28/16 5:00 AM	0.787	BA
51300-1-S-F05-003	Main- Outside Room 107, Fountain	5/28/16 5:00 AM	0.447	BA
51300-1-S-F05-004	Main- Outside Room 107, Fountain	5/28/16 5:00 AM	0.444	BA
51300-1-S-F05-005	Main- Outside Room 107, Fountain	5/28/16 5:00 AM	0.378	BA
51300-1-S-F07-001	Main- Outside Room 103, Fountain 1	5/28/16 5:00 AM	0.711	BA
51300-1-S-F07-002	Main- Outside Room 103, Fountain 1	5/28/16 5:00 AM	0.997	BA
51300-1-S-F07-003	Main- Outside Room 103, Fountain 1	5/28/16 5:00 AM	0.944	BA
51300-1-S-F07-004	Main- Outside Room 103, Fountain 1	5/28/16 5:00 AM	1.13	BA
51300-1-S-F07-005	Main- Outside Room 103, Fountain 1	5/28/16 5:00 AM	0.753	BA
51300-1-S-F08-001	Main- Outside Room 103, Fountain 2	5/28/16 5:00 AM	1.07	BA
51300-1-S-F08-002	Main- Outside Room 103, Fountain 2	5/28/16 5:00 AM	1.19	BA
51300-1-S-F08-003	Main- Outside Room 103, Fountain 2	5/28/16 5:00 AM	1.18	BA
51300-1-S-F08-004	Main- Outside Room 103, Fountain 2	5/28/16 5:00 AM	1.18	BA
51300-1-S-F08-005	Main- Outside Room 103, Fountain 2	5/28/16 5:00 AM	1.15	BA
51300-2-N-F01-001	Main- Outside Room 217, Fountain	5/28/16 5:00 AM	0.866	BA
51300-2-N-F01-002	Main- Outside Room 217, Fountain	5/28/16 5:00 AM	0.655	BA
51300-2-N-F01-003	Main- Outside Room 217, Fountain	5/28/16 5:00 AM	0.614	BA
51300-2-N-F01-004	Main- Outside Room 217, Fountain	5/28/16 5:00 AM	0.607	BA
51300-2-N-F01-005	Main- Outside Room 217, Fountain	5/28/16 5:00 AM	0.654	BA
51300-2-N-F02-001	Main- Outside Room 215, Fountain 1	5/28/16 5:00 AM	0.946	BA
51300-2-N-F02-002	Main- Outside Room 215, Fountain 1	5/28/16 5:00 AM	0.972	BA
51300-2-N-F02-003	Main- Outside Room 215, Fountain 1	5/28/16 5:00 AM	0.867	BA
51300-2-N-F02-004	Main- Outside Room 215, Fountain 1	5/28/16 5:00 AM	0.751	BA
51300-2-N-F02-005	Main- Outside Room 215, Fountain 1	5/28/16 5:00 AM	0.702	BA
51300-2-N-F03-001	Main- Outside Room 215, Fountain 2	5/28/16 5:00 AM	0.639	BA
51300-2-N-F03-002	Main- Outside Room 215, Fountain 2	5/28/16 5:00 AM	0.524	BA
51300-2-N-F03-003	Main- Outside Room 215, Fountain 2	5/28/16 5:00 AM	0.413	BA
51300-2-N-F03-004	Main- Outside Room 215, Fountain 2	5/28/16 5:00 AM	0.393	BA
51300-2-N-F03-005	Main- Outside Room 215, Fountain 2	5/28/16 5:00 AM	0.392	BA
51300-2-N-F04-001	Main- Outside Room 215, Fountain 3	5/28/16 5:00 AM	0.204	BA
51300-2-N-F04-002	Main- Outside Room 215, Fountain 3	5/28/16 5:00 AM	0.329	BA
51300-2-N-F04-003	Main- Outside Room 215, Fountain 3	5/28/16 5:00 AM	0.301	BA
51300-2-N-F04-004	Main- Outside Room 215, Fountain 3	5/28/16 5:00 AM	0.304	BA
51300-2-N-F04-005	Main- Outside Room 215, Fountain 3	5/28/16 5:00 AM	0.287	BA
51300-2-S-F05-001	Main- Outside room 205, Fountain	5/28/16 5:00 AM	1.43	BA
51300-2-S-F05-002	Main- Outside room 205, Fountain	5/28/16 5:00 AM	1.14	BA
51300-2-S-F05-003	Main- Outside room 205, Fountain	5/28/16 5:00 AM	1.35	BA
51300-2-S-F05-004	Main- Outside room 205, Fountain	5/28/16 5:00 AM	0.975	BA
51300-2-S-F05-005	Main- Outside room 205, Fountain	5/28/16 5:00 AM	1.15	BA
51300-2-S-F06-001	Main- Outside Boys Room, Fountain 1	5/28/16 5:00 AM	0.929	BA
51300-2-S-F06-002	Main- Outside Boys Room, Fountain 1	5/28/16 5:00 AM	1.47	BA
51300-2-S-F06-003	Main- Outside Boys Room, Fountain 1	5/28/16 5:00 AM	1.33	BA
51300-2-S-F06-004	Main- Outside Boys Room, Fountain 1	5/28/16 5:00 AM	1.27	BA
51300-2-S-F06-005	Main- Outside Boys Room, Fountain 1	5/28/16 5:00 AM	1.09	BA
51300-2-S-F07-001	Main- Outside Boys Room, Fountain 2	5/28/16 5:00 AM	0.97	BA
51300-2-S-F07-002	Main- Outside Boys Room, Fountain 2	5/28/16 5:00 AM	0.91	BA
51300-2-S-F07-003	Main- Outside Boys Room, Fountain 2	5/28/16 5:00 AM	0.954	BA
51300-2-S-F07-004	Main- Outside Boys Room, Fountain 2	5/28/16 5:00 AM	0.605	BA
51300-2-S-F07-005	Main- Outside Boys Room, Fountain 2	5/28/16 5:00 AM	0.798	BA
51300-2-S-F08-001	Main- Outside Boys Room, Fountain 3	5/28/16 5:00 AM	1.05	BA
51300-2-S-F08-002	Main- Outside Boys Room, Fountain 3	5/28/16 5:00 AM	0.997	BA
51300-2-S-F08-003	Main- Outside Boys Room, Fountain 3	5/28/16 5:00 AM	0.966	BA
51300-2-S-F08-004	Main- Outside Boys Room, Fountain 3	5/28/16 5:00 AM	0.944	BA
51300-2-S-F08-005	Main- Outside Boys Room, Fountain 3	5/28/16 5:00 AM	0.916	BA
51300-1-E-F01-001	Annex- Outside Boys Restroom, Fountain	5/28/16 5:00 AM	<0.120	ND
51300-1-E-F01-002	Annex- Outside Boys Restroom, Fountain	5/28/16 5:00 AM	<0.120	ND
51300-1-E-F01-003	Annex- Outside Boys Restroom, Fountain	5/28/16 5:00 AM	<0.120	ND
51300-1-E-F01-004	Annex- Outside Boys Restroom, Fountain	5/28/16 5:00 AM	<0.120	ND
51300-1-E-F01-005	Annex- Outside Boys Restroom, Fountain	5/28/16 5:00 AM	<0.120	ND
51300-1-E-F02-001	Annex- Inside Main Entrance, Fountain	5/28/16 5:00 AM	<0.120	ND
51300-1-E-F02-002	Annex- Inside Main Entrance, Fountain	5/28/16 5:00 AM	0.271	BA
51300-1-E-F02-003	Annex- Inside Main Entrance, Fountain	5/28/16 5:00 AM	0.181	BA
51300-1-E-F02-004	Annex- Inside Main Entrance, Fountain	5/28/16 5:00 AM	<0.120	ND
51300-1-E-F02-005	Annex- Inside Main Entrance, Fountain	5/28/16 5:00 AM	<0.120	ND
51300-1-N-F04-001	Annex- North Lunchroom, Fountain	5/28/16 5:00 AM	<0.120	ND
51300-1-N-F04-002	Annex- North Lunchroom, Fountain	5/28/16 5:00 AM	<0.120	ND
51300-1-N-F04-003	Annex- North Lunchroom, Fountain	5/28/16 5:00 AM	<0.120	ND
51300-1-N-F04-004	Annex- North Lunchroom, Fountain	5/28/16 5:00 AM	<0.120	ND
51300-1-N-F04-005	Annex- North Lunchroom, Fountain	5/28/16 5:00 AM	<0.120	ND
51300-1-S-F05-001	Annex- South Lunchroom, Fountain	5/28/16 5:00 AM	<0.120	ND
51300-1-S-F05-002	Annex- South Lunchroom, Fountain	5/28/16 5:00 AM	<0.120	ND
51300-1-S-F05-003	Annex- South Lunchroom, Fountain	5/28/16 5:00 AM	<0.120	ND
51300-1-S-F05-004	Annex- South Lunchroom, Fountain	5/28/16 5:00 AM	<0.120	ND
51300-1-S-F05-005	Annex- South Lunchroom, Fountain	5/28/16 5:00 AM	<0.120	ND
51300-2-E-F01-001	Annex- Outside Boys Restroom, Fountain	5/28/16 5:00 AM	<0.120	ND
51300-2-E-F01-002	Annex- Outside Boys Restroom, Fountain	5/28/16 5:00 AM	<0.120	ND
51300-2-E-F01-003	Annex- Outside Boys Restroom, Fountain	5/28/16 5:00 AM	<0.120	ND
51300-2-E-F01-004	Annex- Outside Boys Restroom, Fountain	5/28/16 5:00 AM	<0.120	ND
51300-2-E-F01-005	Annex- Outside Boys Restroom, Fountain	5/28/16 5:00 AM	<0.120	ND
51300-2-E-F02-001	Annex- Outside Boys Restroom, Fountain 2	5/28/16 5:00 AM	<0.120	ND
51300-2-E-F02-002	Annex- Outside Boys Restroom, Fountain 3	5/28/16 5:00 AM	<0.120	ND
51300-2-E-F02-003	Annex- Outside Boys Restroom, Fountain 4	5/28/16 5:00 AM	<0.120	ND
51300-2-E-F02-004	Annex- Outside Boys Restroom, Fountain 5	5/28/16 5:00 AM	<0.120	ND
51300-2-E-F02-005	Annex- Outside Boys Restroom, Fountain 6	5/28/16 5:00 AM	<0.120	ND
51300-1-S-S01-001	Main- Inside Room 110, East Sink 1	6/22/16 5:00 AM	2.63	BA
51300-1-S-S01-002	Main- Inside Room 110, East Sink 1	6/22/16 5:00 AM	1.23	BA
51300-1-S-S01-003	Main- Inside Room 110, East Sink 1	6/22/16 5:00 AM	1	BA
51300-1-S-S01-004	Main- Inside Room 110, East Sink 1	6/22/16 5:00 AM	0.98	BA
51300-1-S-S01-005	Main- Inside Room 110, East Sink 1	6/22/16 5:00 AM	0.818	BA
51300-1-S-S02-001	Main- Inside Room 110, West Sink 2	6/22/16 5:00 AM	3	BA
51300-1-S-S02-002	Main- Inside Room 110, West Sink 2	6/22/16 5:00 AM	1.34	BA
51300-1-S-S02-003	Main- Inside Room 110, West Sink 2	6/22/16 5:00 AM	0.989	BA
51300-1-S-S02-004	Main- Inside Room 110, West Sink 2	6/22/16 5:00 AM	1.04	BA
51300-1-S-S02-005	Main- Inside Room 110, West Sink 2	6/22/16 5:00 AM	0.874	BA
51300-1-W-S03-001	Main- Inside Room 110, Work Room Sink 3	6/22/16 5:00 AM	2.91	BA
51300-1-W-S03-002	Main- Inside Room 110, Work Room Sink 3	6/22/16 5:00 AM	2.73	BA
51300-1-W-S03-003	Main- Inside Room 110, Work Room Sink 3	6/22/16 5:00 AM	1.11	BA
51300-1-W-S03-004	Main- Inside Room 110, Work Room Sink 3	6/22/16 5:00 AM	0.43	BA
51300-1-W-S03-005	Main- Inside Room 110, Work Room Sink 3	6/22/16 5:00 AM	0.609	BA

EPA ACTION LEVEL FOR LEAD IS 15 ppb or 15 µg/L

SPREADSHEET LEGEND

ND-Not Detected at the Reporting Limit
BA-Below EPA Action Level of 15 ppb
AA-Above EPA Action Level