



November 9, 2016

Dear Al Raby families,

In light of national events that have brought increased attention to the issue of water quality, the City of Chicago announced several additional precautionary measures that will be added to the City's water testing protocol, continuing the City's track record of complying with current state and federal regulations as well as exceeding industry standards.

As part of this announcement, Chicago Public Schools (CPS) began testing the water for levels of lead from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe. Schools are being tested based on a priority criteria that includes the age of the school, age of the students (with priority given to schools with pre-K programs), presence of a kitchen (where meals are prepared) and presence of pipes that could need repairs or replacement.

The results of all the schools are coming in on a rolling basis, and the majority have had levels under the EPA's action level of 15 parts per billion (ppb). At Raby samples were tested from 28 sites and the water sampled from a sink on the fourth floor in Room 420, the Culinary Arts Room, was above the action level of 15 ppb. The water from the sink has been turned off and remediation plans are being created.

Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why only one of the samples at Raby returned with elevated results – the issue is not system-wide, but is specific to the fixtures or pipes for that sink and will be addressed through the remediation plan. The full results of every school's water samples can be found online at cps.edu/leadtesting.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

Forrest Claypool
CEO, Chicago Public Schools

Dr. Julie Morita
Commissioner, Chicago Department of Public Health





9 de noviembre de 2016

Estimadas familias de la escuela Al Raby,

Ante recientes eventos nacionales que han aumentado la atención sobre el tema de la calidad del agua, la ciudad de Chicago anunció varias medidas de precaución adicionales que se sumarán al protocolo de la ciudad sobre control del agua, en cumplimiento de las regulaciones estatales y federales, así como de los estándares industriales

Como parte de este anuncio, las Escuelas Públicas de Chicago (CPS) comenzaron a examinar los niveles de plomo en el agua de las escuelas de todo el distrito. Nuestra prioridad máxima es la salud y seguridad de los estudiantes y del personal, y estas pruebas se iniciaron como precaución para estar seguros de la calidad del agua de las escuelas. Las pruebas se realizan según un criterio de prioridad que incluye la edad del edificio, edad de los estudiantes (con prioridad para las escuelas con programas de preescolares), la presencia de una cocina (donde se preparan alimentos) y de cañerías que puedan necesitar reparación o reemplazo.

Los resultados de todas las escuelas se han ido conociendo, y la mayoría registró niveles por debajo del nivel de acción de EPA que es de 15 partículas por billón (ppb). En Raby se tomaron muestras en 28 lugares y el agua de una pileta del cuarto piso, en el salón 420, de Artes Culinarias, tenía rastros de plomo por encima del nivel de acción de 15 ppb. El suministro de agua del dispositivo fue interrumpido y se están creando planes para remediar la situación.

El agua de Chicago no tiene plomo cuando sale de la planta de tratamiento. Sin embargo, se puede encontrar en algunas cañerías internas y materiales, y el plomo encontrado en el agua potable es provocado usualmente por la corrosión de las cañerías. Esto explica por qué solamente una de las muestras de Raby registró un nivel elevado. Este no es problema general sino específico de la cañería del dispositivo, y será solucionado. Los resultados completos de cada escuela se pueden ver en línea en cps.edu/leadtesting.

Los lineamientos federales indican que los niños menores de seis años son los que corren mayores riesgos con la exposición al plomo, algo que puede ocurrir de varias fuentes, incluyendo pintura, tierra y algunos productos de consumo. Si están preocupados por la posible exposición de su hijo al plomo, el Departamento de Salud Pública de la ciudad de Chicago (CDPH) recomienda visitar a su pediatra o a alguno de los centros de salud listados en el material adjunto, para una prueba. Además, la línea directa del CDPH puede responder cualquier pregunta que tengan, o ayudarlos a decidir si su niño debe ser examinado; por preguntas o más información, llame por favor al 312-747-5323. Por información adicional sobre el plomo y los niños, visite www.cdc.gov/lead.

La seguridad de sus hijos es nuestra principal prioridad, y hacemos todo lo que está en nuestro poder para resolver esta situación de una manera rápida y rigurosa. Continuaremos informándoles sobre este proceso.

Atentamente,

Forrest Claypool
CEO, Escuelas Públicas de Chicago

Dra. Julie Morita, Comisionada
Departamento de Salud Pública de Chicago





School Lead Water Testing - Data Collection Form

School Short Name **Raby HS**
 Date of test **10/28/16**

School Short Name	Facility ID	Sample ID #	Sample Location	Sample Collection Time & Date	Test Result (ppb)	Test Results
Raby HS	51574	51574-1-KIT-KS01-001	Main- Kitchen Triple Basin S. Wall Divider Left Faucet	10/28/16 6:00 AM	0.546	BA
Raby HS	51574	51574-1-KIT-KS01-002	Main- Kitchen Triple Basin S. Wall Divider Left Faucet	10/28/16 6:00 AM	1.21	BA
Raby HS	51574	51574-1-KIT-KS01-003	Main- Kitchen Triple Basin S. Wall Divider Left Faucet	10/28/16 6:00 AM	0.807	BA
Raby HS	51574	51574-1-KIT-KS01-004	Main- Kitchen Triple Basin S. Wall Divider Left Faucet	10/28/16 6:00 AM	0.634	BA
Raby HS	51574	51574-1-KIT-KS01-005	Main- Kitchen Triple Basin S. Wall Divider Left Faucet	10/28/16 6:00 AM	0.338	BA
Raby HS	51574	51574-1-KIT-KS02-001	Main- Kitchen Triple Basin S. Wall Divider Center Faucet	10/28/16 6:00 AM	0.433	BA
Raby HS	51574	51574-1-KIT-KS02-002	Main- Kitchen Triple Basin S. Wall Divider Center Faucet	10/28/16 6:00 AM	0.49	BA
Raby HS	51574	51574-1-KIT-KS02-003	Main- Kitchen Triple Basin S. Wall Divider Center Faucet	10/28/16 6:00 AM	<0.120	ND
Raby HS	51574	51574-1-KIT-KS02-004	Main- Kitchen Triple Basin S. Wall Divider Center Faucet	10/28/16 6:00 AM	<0.120	ND
Raby HS	51574	51574-1-KIT-KS02-005	Main- Kitchen Triple Basin S. Wall Divider Center Faucet	10/28/16 6:00 AM	<0.120	ND
Raby HS	51574	51574-1-KIT-KS03-001	Main- Kitchen Triple Basin S. Wall Divider Right Faucet	10/28/16 6:00 AM	1.04	BA
Raby HS	51574	51574-1-KIT-KS03-002	Main- Kitchen Triple Basin S. Wall Divider Right Faucet	10/28/16 6:00 AM	1.02	BA
Raby HS	51574	51574-1-KIT-KS03-003	Main- Kitchen Triple Basin S. Wall Divider Right Faucet	10/28/16 6:00 AM	0.679	BA
Raby HS	51574	51574-1-KIT-KS03-004	Main- Kitchen Triple Basin S. Wall Divider Right Faucet	10/28/16 6:00 AM	0.176	BA
Raby HS	51574	51574-1-KIT-KS03-005	Main- Kitchen Triple Basin S. Wall Divider Right Faucet	10/28/16 6:00 AM	0.163	BA
Raby HS	51574	51574-1-KIT-KS04-001	Main- Kitchen N. Triple Basin E. Wall Left Faucet	10/28/16 6:00 AM	2.44	BA
Raby HS	51574	51574-1-KIT-KS04-002	Main- Kitchen N. Triple Basin E. Wall Left Faucet	10/28/16 6:00 AM	1.31	BA
Raby HS	51574	51574-1-KIT-KS04-003	Main- Kitchen N. Triple Basin E. Wall Left Faucet	10/28/16 6:00 AM	2.13	BA
Raby HS	51574	51574-1-KIT-KS04-004	Main- Kitchen N. Triple Basin E. Wall Left Faucet	10/28/16 6:00 AM	2.27	BA
Raby HS	51574	51574-1-KIT-KS04-005	Main- Kitchen N. Triple Basin E. Wall Left Faucet	10/28/16 6:00 AM	1.06	BA
Raby HS	51574	51574-1-KIT-KS05-001	Main- Kitchen N. Triple Basin E. Wall Center Faucet	10/28/16 6:00 AM	0.46	BA
Raby HS	51574	51574-1-KIT-KS05-002	Main- Kitchen N. Triple Basin E. Wall Center Faucet	10/28/16 6:00 AM	<0.120	ND
Raby HS	51574	51574-1-KIT-KS05-003	Main- Kitchen N. Triple Basin E. Wall Center Faucet	10/28/16 6:00 AM	0.372	BA
Raby HS	51574	51574-1-KIT-KS05-004	Main- Kitchen N. Triple Basin E. Wall Center Faucet	10/28/16 6:00 AM	0.201	BA
Raby HS	51574	51574-1-KIT-KS05-005	Main- Kitchen N. Triple Basin E. Wall Center Faucet	10/28/16 6:00 AM	<0.120	ND
Raby HS	51574	51574-1-KIT-KS06-001	Main- Kitchen N. Triple Basin E. Wall Right Faucet	10/28/16 6:00 AM	1.7	BA
Raby HS	51574	51574-1-KIT-KS06-002	Main- Kitchen N. Triple Basin E. Wall Right Faucet	10/28/16 6:00 AM	0.2	BA
Raby HS	51574	51574-1-KIT-KS06-003	Main- Kitchen N. Triple Basin E. Wall Right Faucet	10/28/16 6:00 AM	<0.120	ND
Raby HS	51574	51574-1-KIT-KS06-004	Main- Kitchen N. Triple Basin E. Wall Right Faucet	10/28/16 6:00 AM	0.199	BA
Raby HS	51574	51574-1-KIT-KS06-005	Main- Kitchen N. Triple Basin E. Wall Right Faucet	10/28/16 6:00 AM	<0.120	ND
Raby HS	51574	51574-1-KIT-KS07-001	Main- Kitchen Island Sink	10/28/16 6:00 AM	1.57	BA
Raby HS	51574	51574-1-KIT-KS07-002	Main- Kitchen Island Sink	10/28/16 6:00 AM	1.67	BA
Raby HS	51574	51574-1-KIT-KS07-003	Main- Kitchen Island Sink	10/28/16 6:00 AM	5.02	BA
Raby HS	51574	51574-1-KIT-KS07-004	Main- Kitchen Island Sink	10/28/16 6:00 AM	1.5	BA
Raby HS	51574	51574-1-KIT-KS07-005	Main- Kitchen Island Sink	10/28/16 6:00 AM	0.738	BA
Raby HS	51574	51574-1-KIT-KS08-001	Main- Kitchen S. Triple Basin E. Wall Left Faucet	10/28/16 6:00 AM	0.504	BA
Raby HS	51574	51574-1-KIT-KS08-002	Main- Kitchen S. Triple Basin E. Wall Left Faucet	10/28/16 6:00 AM	0.65	BA
Raby HS	51574	51574-1-KIT-KS08-003	Main- Kitchen S. Triple Basin E. Wall Left Faucet	10/28/16 6:00 AM	0.18	BA
Raby HS	51574	51574-1-KIT-KS08-004	Main- Kitchen S. Triple Basin E. Wall Left Faucet	10/28/16 6:00 AM	<0.120	ND
Raby HS	51574	51574-1-KIT-KS08-005	Main- Kitchen S. Triple Basin E. Wall Left Faucet	10/28/16 6:00 AM	<0.120	ND
Raby HS	51574	51574-1-KIT-KS09-001	Main- Kitchen S. Triple Basin E. Wall Center Faucet	10/28/16 6:00 AM	0.635	BA
Raby HS	51574	51574-1-KIT-KS09-002	Main- Kitchen S. Triple Basin E. Wall Center Faucet	10/28/16 6:00 AM	0.209	BA

Raby HS	51574	51574-1-KIT-KS09-003	Main- Kitchen S. Triple Basin E. Wall Center Faucet	10/28/16 6:00 AM	<0.120	ND
Raby HS	51574	51574-1-KIT-KS09-004	Main- Kitchen S. Triple Basin E. Wall Center Faucet	10/28/16 6:00 AM	<0.120	ND
Raby HS	51574	51574-1-KIT-KS09-005	Main- Kitchen S. Triple Basin E. Wall Center Faucet	10/28/16 6:00 AM	0.146	BA
Raby HS	51574	51574-1-KIT-KS10-001	Main- Kitchen S. Triple Basin E. Wall Right Faucet	10/28/16 6:00 AM	3.36	BA
Raby HS	51574	51574-1-KIT-KS10-002	Main- Kitchen S. Triple Basin E. Wall Right Faucet	10/28/16 6:00 AM	0.758	BA
Raby HS	51574	51574-1-KIT-KS10-003	Main- Kitchen S. Triple Basin E. Wall Right Faucet	10/28/16 6:00 AM	0.384	BA
Raby HS	51574	51574-1-KIT-KS10-004	Main- Kitchen S. Triple Basin E. Wall Right Faucet	10/28/16 6:00 AM	0.342	BA
Raby HS	51574	51574-1-KIT-KS10-005	Main- Kitchen S. Triple Basin E. Wall Right Faucet	10/28/16 6:00 AM	0.336	BA
Raby HS	51574	51574-1-KIT-KS11-001	Main- Kitchen Triple Basin N. Wall Divider Left Faucet	10/28/16 6:00 AM	0.49	BA
Raby HS	51574	51574-1-KIT-KS11-002	Main- Kitchen Triple Basin N. Wall Divider Left Faucet	10/28/16 6:00 AM	0.499	BA
Raby HS	51574	51574-1-KIT-KS11-003	Main- Kitchen Triple Basin N. Wall Divider Left Faucet	10/28/16 6:00 AM	0.675	BA
Raby HS	51574	51574-1-KIT-KS11-004	Main- Kitchen Triple Basin N. Wall Divider Left Faucet	10/28/16 6:00 AM	0.575	BA
Raby HS	51574	51574-1-KIT-KS11-005	Main- Kitchen Triple Basin N. Wall Divider Left Faucet	10/28/16 6:00 AM	0.158	BA
Raby HS	51574	51574-1-KIT-KS12-001	Main- Kitchen Triple Basin N. Wall Divider Center Faucet	10/28/16 6:00 AM	0.592	BA
Raby HS	51574	51574-1-KIT-KS12-002	Main- Kitchen Triple Basin N. Wall Divider Center Faucet	10/28/16 6:00 AM	0.321	BA
Raby HS	51574	51574-1-KIT-KS12-003	Main- Kitchen Triple Basin N. Wall Divider Center Faucet	10/28/16 6:00 AM	<0.120	ND
Raby HS	51574	51574-1-KIT-KS12-004	Main- Kitchen Triple Basin N. Wall Divider Center Faucet	10/28/16 6:00 AM	0.713	BA
Raby HS	51574	51574-1-KIT-KS12-005	Main- Kitchen Triple Basin N. Wall Divider Center Faucet	10/28/16 6:00 AM	<0.120	ND
Raby HS	51574	51574-1-KIT-KS13-001	Main- Kitchen Triple Basin N. Wall Divider Right Faucet	10/28/16 6:00 AM	0.353	BA
Raby HS	51574	51574-1-KIT-KS13-002	Main- Kitchen Triple Basin N. Wall Divider Right Faucet	10/28/16 6:00 AM	0.128	BA
Raby HS	51574	51574-1-KIT-KS13-003	Main- Kitchen Triple Basin N. Wall Divider Right Faucet	10/28/16 6:00 AM	<0.120	ND
Raby HS	51574	51574-1-KIT-KS13-004	Main- Kitchen Triple Basin N. Wall Divider Right Faucet	10/28/16 6:00 AM	<0.120	ND
Raby HS	51574	51574-1-KIT-KS13-005	Main- Kitchen Triple Basin N. Wall Divider Right Faucet	10/28/16 6:00 AM	<0.120	ND
Raby HS	51574	51574-1-HAL-WC14-001	Main- Across Room 120, Water Cooler	10/28/16 6:00 AM	<0.120	ND
Raby HS	51574	51574-1-HAL-WC14-002	Main- Across Room 120, Water Cooler	10/28/16 6:00 AM	0.301	BA
Raby HS	51574	51574-1-HAL-WC14-003	Main- Across Room 120, Water Cooler	10/28/16 6:00 AM	0.368	BA
Raby HS	51574	51574-1-HAL-WC14-004	Main- Across Room 120, Water Cooler	10/28/16 6:00 AM	0.231	BA
Raby HS	51574	51574-1-HAL-WC14-005	Main- Across Room 120, Water Cooler	10/28/16 6:00 AM	<0.120	ND
Raby HS	51574	51574-1-HAL-WC15-001	Main- Across Room 114, Water Cooler	10/28/16 6:00 AM	0.15	BA
Raby HS	51574	51574-1-HAL-WC15-002	Main- Across Room 114, Water Cooler	10/28/16 6:00 AM	0.156	BA
Raby HS	51574	51574-1-HAL-WC15-003	Main- Across Room 114, Water Cooler	10/28/16 6:00 AM	0.254	BA
Raby HS	51574	51574-1-HAL-WC15-004	Main- Across Room 114, Water Cooler	10/28/16 6:00 AM	0.36	BA
Raby HS	51574	51574-1-HAL-WC15-005	Main- Across Room 114, Water Cooler	10/28/16 6:00 AM	0.377	BA
Raby HS	51574	51574-1-HAL-WC16-001	Main- Across Room 110, Water Cooler	10/28/16 6:00 AM	0.21	BA
Raby HS	51574	51574-1-HAL-WC16-002	Main- Across Room 110, Water Cooler	10/28/16 6:00 AM	0.295	BA
Raby HS	51574	51574-1-HAL-WC16-003	Main- Across Room 110, Water Cooler	10/28/16 6:00 AM	0.396	BA
Raby HS	51574	51574-1-HAL-WC16-004	Main- Across Room 110, Water Cooler	10/28/16 6:00 AM	0.547	BA
Raby HS	51574	51574-1-HAL-WC16-005	Main- Across Room 110, Water Cooler	10/28/16 6:00 AM	0.646	BA
Raby HS	51574	51574-1-HAL-WC17-001	Main- Across Womens Locker Room, Water Cooler	10/28/16 6:00 AM	<0.120	ND
Raby HS	51574	51574-1-HAL-WC17-002	Main- Across Womens Locker Room, Water Cooler	10/28/16 6:00 AM	<0.120	ND
Raby HS	51574	51574-1-HAL-WC17-003	Main- Across Womens Locker Room, Water Cooler	10/28/16 6:00 AM	0.154	BA
Raby HS	51574	51574-1-HAL-WC17-004	Main- Across Womens Locker Room, Water Cooler	10/28/16 6:00 AM	0.297	BA
Raby HS	51574	51574-1-HAL-WC17-005	Main- Across Womens Locker Room, Water Cooler	10/28/16 6:00 AM	0.372	BA
Raby HS	51574	51574-1-118-S18-001	Main- Inside Room 118, South Wall Sink	10/28/16 6:00 AM	4.36	BA
Raby HS	51574	51574-1-118-S18-002	Main- Inside Room 118, South Wall Sink	10/28/16 6:00 AM	4.03	BA
Raby HS	51574	51574-1-118-S18-003	Main- Inside Room 118, South Wall Sink	10/28/16 6:00 AM	2.3	BA
Raby HS	51574	51574-1-118-S18-004	Main- Inside Room 118, South Wall Sink	10/28/16 6:00 AM	0.942	BA
Raby HS	51574	51574-1-118-S18-005	Main- Inside Room 118, South Wall Sink	10/28/16 6:00 AM	1.19	BA
Raby HS	51574	51574-2-HAL-WC01-001	Main- Next to Room 209, Water Cooler	10/28/16 6:00 AM	6.82	BA
Raby HS	51574	51574-2-HAL-WC01-002	Main- Next to Room 209, Water Cooler	10/28/16 6:00 AM	7.07	BA
Raby HS	51574	51574-2-HAL-WC01-003	Main- Next to Room 209, Water Cooler	10/28/16 6:00 AM	7.26	BA
Raby HS	51574	51574-2-HAL-WC01-004	Main- Next to Room 209, Water Cooler	10/28/16 6:00 AM	7.01	BA
Raby HS	51574	51574-2-HAL-WC01-005	Main- Next to Room 209, Water Cooler	10/28/16 6:00 AM	6.11	BA
Raby HS	51574	51574-2-HAL-WC02-001	Main- Across From Room 216, Water Cooler	10/28/16 6:00 AM	0.471	BA
Raby HS	51574	51574-2-HAL-WC02-002	Main- Across From Room 216, Water Cooler	10/28/16 6:00 AM	0.479	BA
Raby HS	51574	51574-2-HAL-WC02-003	Main- Across From Room 216, Water Cooler	10/28/16 6:00 AM	0.605	BA

Raby HS	51574	51574-2-HAL-WC02-004	Main- Across From Room 216, Water Cooler	10/28/16 6:00 AM	0.682	BA
Raby HS	51574	51574-2-HAL-WC02-005	Main- Across From Room 216, Water Cooler	10/28/16 6:00 AM	0.701	BA
Raby HS	51574	51574-2-HAL-WC03-001	Main- Across From Room 222, Water Cooler	10/28/16 6:00 AM	0.14	BA
Raby HS	51574	51574-2-HAL-WC03-002	Main- Across From Room 222, Water Cooler	10/28/16 6:00 AM	0.412	BA
Raby HS	51574	51574-2-HAL-WC03-003	Main- Across From Room 222, Water Cooler	10/28/16 6:00 AM	0.228	BA
Raby HS	51574	51574-2-HAL-WC03-004	Main- Across From Room 222, Water Cooler	10/28/16 6:00 AM	0.126	BA
Raby HS	51574	51574-2-HAL-WC03-005	Main- Across From Room 222, Water Cooler	10/28/16 6:00 AM	<0.120	ND
Raby HS	51574	51574-3-HAL-WC01-001	Main- Across From Room 310, Water Cooler	10/28/16 6:00 AM	0.153	BA
Raby HS	51574	51574-3-HAL-WC01-002	Main- Across From Room 310, Water Cooler	10/28/16 6:00 AM	0.192	BA
Raby HS	51574	51574-3-HAL-WC01-003	Main- Across From Room 310, Water Cooler	10/28/16 6:00 AM	0.244	BA
Raby HS	51574	51574-3-HAL-WC01-004	Main- Across From Room 310, Water Cooler	10/28/16 6:00 AM	0.403	BA
Raby HS	51574	51574-3-HAL-WC01-005	Main- Across From Room 310, Water Cooler	10/28/16 6:00 AM	0.456	BA
Raby HS	51574	51574-3-HAL-WC02-001	Main- Across From Room 322, Water Cooler	10/28/16 6:00 AM	0.245	BA
Raby HS	51574	51574-3-HAL-WC02-002	Main- Across From Room 322, Water Cooler	10/28/16 6:00 AM	0.649	BA
Raby HS	51574	51574-3-HAL-WC02-003	Main- Across From Room 322, Water Cooler	10/28/16 6:00 AM	0.378	BA
Raby HS	51574	51574-3-HAL-WC02-004	Main- Across From Room 322, Water Cooler	10/28/16 6:00 AM	0.323	BA
Raby HS	51574	51574-3-HAL-WC02-005	Main- Across From Room 322, Water Cooler	10/28/16 6:00 AM	0.301	BA
Raby HS	51574	51574-4-HAL-WC01-001	Main- Across From Room 408, Water Cooler	10/28/16 6:00 AM	0.229	BA
Raby HS	51574	51574-4-HAL-WC01-002	Main- Across From Room 408, Water Cooler	10/28/16 6:00 AM	0.284	BA
Raby HS	51574	51574-4-HAL-WC01-003	Main- Across From Room 408, Water Cooler	10/28/16 6:00 AM	0.391	BA
Raby HS	51574	51574-4-HAL-WC01-004	Main- Across From Room 408, Water Cooler	10/28/16 6:00 AM	0.523	BA
Raby HS	51574	51574-4-HAL-WC01-005	Main- Across From Room 408, Water Cooler	10/28/16 6:00 AM	0.592	BA
Raby HS	51574	51574-4-420-S02-001	Main- Inside Culinary Room 420, NE Corner Wall, Sink	10/28/16 6:00 AM	1.64	BA
Raby HS	51574	51574-4-420-S02-002	Main- Inside Culinary Room 420, NE Corner Wall, Sink	10/28/16 6:00 AM	1.03	BA
Raby HS	51574	51574-4-420-S02-003	Main- Inside Culinary Room 420, NE Corner Wall, Sink	10/28/16 6:00 AM	0.952	BA
Raby HS	51574	51574-4-420-S02-004	Main- Inside Culinary Room 420, NE Corner Wall, Sink	10/28/16 6:00 AM	3.8	BA
Raby HS	51574	51574-4-420-S02-005	Main- Inside Culinary Room 420, NE Corner Wall, Sink	10/28/16 6:00 AM	1.43	BA
Raby HS	51574	51574-4-420-S03-001	Main- Inside Culinary Room 420, East Wall, Left Sink	10/28/16 6:00 AM	204	AA
Raby HS	51574	51574-4-420-S03-002	Main- Inside Culinary Room 420, East Wall, Left Sink	10/28/16 6:00 AM	11.2	BA
Raby HS	51574	51574-4-420-S03-003	Main- Inside Culinary Room 420, East Wall, Left Sink	10/28/16 6:00 AM	46.1	AA
Raby HS	51574	51574-4-420-S03-004	Main- Inside Culinary Room 420, East Wall, Left Sink	10/28/16 6:00 AM	11.3	BA
Raby HS	51574	51574-4-420-S03-005	Main- Inside Culinary Room 420, East Wall, Left Sink	10/28/16 6:00 AM	7.99	BA
Raby HS	51574	51574-4-420-S05-001	Main- Inside Culinary Room 420,SW Wall, Sink	10/28/16 6:00 AM	2.58	BA
Raby HS	51574	51574-4-420-S05-002	Main- Inside Culinary Room 420,SW Wall, Sink	10/28/16 6:00 AM	1.38	BA
Raby HS	51574	51574-4-420-S05-003	Main- Inside Culinary Room 420,SW Wall, Sink	10/28/16 6:00 AM	2.48	BA
Raby HS	51574	51574-4-420-S05-004	Main- Inside Culinary Room 420,SW Wall, Sink	10/28/16 6:00 AM	2.77	BA
Raby HS	51574	51574-4-420-S05-005	Main- Inside Culinary Room 420,SW Wall, Sink	10/28/16 6:00 AM	1.58	BA
Raby HS	51574	51574-4-HAL-WC06-001	Main- Across From Room 420, Water Cooler	10/28/16 6:00 AM	0.447	BA
Raby HS	51574	51574-4-HAL-WC06-002	Main- Across From Room 420, Water Cooler	10/28/16 6:00 AM	0.858	BA
Raby HS	51574	51574-4-HAL-WC06-003	Main- Across From Room 420, Water Cooler	10/28/16 6:00 AM	0.758	BA
Raby HS	51574	51574-4-HAL-WC06-004	Main- Across From Room 420, Water Cooler	10/28/16 6:00 AM	0.678	BA
Raby HS	51574	51574-4-HAL-WC06-005	Main- Across From Room 420, Water Cooler	10/28/16 6:00 AM	0.661	BA

EPA ACTION LEVEL FOR LEAD IS 15 ppb or 15 µg/L

SPREADSHEET LEGEND

ND-Not Detected at the Reporting Limit

BA-Below EPA Action Level of 15 ppb

AA-Above EPA Action Level

Chicago Public Schools - Department of Facility Operations