



School Lead Water Testing - Data Collection Form

School Short Name **Thomas**

Length of time water remained in pipes before sampled (hours) **13 hours**
Report based on lab results dated **6/8/16**
Date of test **05/26/16**
Water last used (Time and date) **Approx 4 PM 5/25/16**

Sample ID #	Sample Location	Sample Collection Time & Date	Test Result (ppb)	Test Results
26891-B-N-F01-001	Basement Faucet North, Sink	5/26/16 5:15 AM	2.09	BA
26891-B-N-F01-002	Basement Faucet North, Sink	5/26/16 5:16 AM	0.426	BA
26891-B-N-F01-003	Basement Faucet North, Sink	5/26/16 5:17 AM	0.332	BA
26891-B-N-F01-004	Basement Faucet North, Sink	5/26/16 5:18 AM	0.363	BA
26891-B-N-F01-004	Basement Faucet North, Sink	5/26/16 5:19 AM	0.34	BA
26891-B-S-S02-001	Basement Kitchen, Sink	5/26/16 5:25 AM	<0.120	ND
26891-B-S-S02-002	Basement Kitchen, Sink	5/26/16 5:26 AM	<0.120	ND
26891-B-S-S02-003	Basement Kitchen, Sink	5/26/16 5:27 AM	0.129	BA
26891-B-S-S02-004	Basement Kitchen, Sink	5/26/16 5:28 AM	<0.120	ND
26891-B-S-S02-005	Basement Kitchen, Sink	5/26/16 5:29 AM	<0.120	ND
26891-1-N-F01-001	First Floor Outside room 005, Fountain	5/26/16 5:36 AM	1.42	BA
26891-1-N-F01-002	First Floor Outside room 005, Fountain	5/26/16 5:37 AM	1.1	BA
26891-1-N-F01-003	First Floor Outside room 005, Fountain	5/26/16 5:38 AM	1.06	BA
26891-1-N-F01-004	First Floor Outside room 005, Fountain	5/26/16 5:39 AM	0.842	BA
26891-1-N-F01-005	First Floor Outside room 005, Fountain	5/26/16 5:40 AM	1.13	BA
26891-1-E-F02-001	First Floor Outside room 003, Fountain	5/26/16 5:45	1.33	BA
26891-1-E-F02-002	First Floor Outside room 003, Fountain	5/26/16 5:46 AM	0.904	BA
26891-1-E-F02-003	First Floor Outside room 003, Fountain	5/26/16 5:47 AM	0.592	BA
26891-1-E-F02-004	First Floor Outside room 003, Fountain	5/26/16 5:48 AM	0.389	BA
26891-1-E-F02-005	First Floor Outside room 003, Fountain	5/26/16 5:49 AM	0.462	BA
26891-1-S-F03-001	First Floor Outside room 001, Fountain	5/26/16 5:58 AM	1.55	BA
26891-1-S-F03-002	First Floor Outside room 001, Fountain	5/26/16 5:59 AM	1.26	BA
26891-1-S-F03-003	First Floor Outside room 001, Fountain	5/26/16 6:00 AM	1.23	BA
26891-1-S-F03-004	First Floor Outside room 001, Fountain	5/26/16 6:01 AM	1.13	BA
26891-1-S-F03-005	First Floor Outside room 001, Fountain	5/26/16 6:02 AM	0.852	BA

EPA ACTION LEVEL FOR LEAD IS 15 ppb or 15 µg/L

SPREADSHEET LEGEND

ND-Not Detected at the Reporting Limit
BA-Below EPA Action Level of 15 ppb
AA-Above EPA Action Level

Chicago Public Schools - Department of Facility Operations