



School Lead Water Testing - Data Collection Form

School Short Name
Address

Blaine
1420 W. Grace Street

Length of time water remained in pipes before sampled (hours)
Report based on lab results dated
Date of test
Water last used (Time and date)

13.00
6/8/16
05/27/16
Approx 4 PM 5/26/16

Sample ID #	Sample Location	Water Last Used (Time & Date)	Sample Collection Time & Date	Test Result (ppb)	Test Results
51048-B-N-S01-001	Sink 1 - Basement Kitchen, Main Bldg.	5/26/16 4:00 PM	5/27/2016 5:00AM	0.714	BA
51048-B-N-S01-002	Sink 1 - Basement Kitchen, Main Bldg.	5/26/16 4:00 PM	5/27/2016 5:00AM	0.43	BA
51048-B-N-S01-003	Sink 1 - Basement Kitchen, Main Bldg.	5/26/16 4:00 PM	5/27/2016 5:00AM	0.63	BA
51048-B-N-S01-004	Sink 1 - Basement Kitchen, Main Bldg.	5/26/16 4:00 PM	5/27/2016 5:00AM	0.814	BA
51048-B-N-S01-005	Sink 1 - Basement Kitchen, Main Bldg.	5/26/16 4:00 PM	5/27/2016 5:00AM	1.4	BA
51048-B-N-S02-001	Sink 2 - Basement Kitchen, Main Bldg.	5/26/16 4:00 PM	5/27/2016 5:00AM	0.336	BA
51048-B-N-S02-002	Sink 2 - Basement Kitchen, Main Bldg.	5/26/16 4:00 PM	5/27/2016 5:00AM	0.946	BA
51048-B-N-S02-003	Sink 2 - Basement Kitchen, Main Bldg.	5/26/16 4:00 PM	5/27/2016 5:00AM	1.51	BA
51048-B-N-S02-004	Sink 2 - Basement Kitchen, Main Bldg.	5/26/16 4:00 PM	5/27/2016 5:00AM	2.51	BA
51048-B-N-S02-005	Sink 2 - Basement Kitchen, Main Bldg.	5/26/16 4:00 PM	5/27/2016 5:00AM	1.83	BA
51048-B-S-F03-001	Fountain 1 - Basement Lunch Room, Main Bldg.	5/26/16 4:00 PM	5/27/2016 5:00AM	0.601	BA
51048-B-S-F03-002	Fountain 1 - Basement Lunch Room, Main Bldg.	5/26/16 4:00 PM	5/27/2016 5:00AM	0.401	BA
51048-B-S-F03-003	Fountain 1 - Basement Lunch Room, Main Bldg.	5/26/16 4:00 PM	5/27/2016 5:00AM	0.528	BA
51048-B-S-F03-004	Fountain 1 - Basement Lunch Room, Main Bldg.	5/26/16 4:00 PM	5/27/2016 5:00AM	0.439	BA
51048-B-S-F03-005	Fountain 1 - Basement Lunch Room, Main Bldg.	5/26/16 4:00 PM	5/27/2016 5:00AM	0.376	BA
51048-B-S-F04-001	Fountain 2 - Basement Lunch Room, Main Bldg.	5/26/16 4:00 PM	5/27/2016 5:00AM	0.566	BA
51048-B-S-F04-002	Fountain 2 - Basement Lunch Room, Main Bldg.	5/26/16 4:00 PM	5/27/2016 5:00AM	0.572	BA
51048-B-S-F04-003	Fountain 2 - Basement Lunch Room, Main Bldg.	5/26/16 4:00 PM	5/27/2016 5:00AM	0.348	BA
51048-B-S-F04-004	Fountain 2 - Basement Lunch Room, Main Bldg.	5/26/16 4:00 PM	5/27/2016 5:00AM	0.317	BA
51048-B-S-F04-005	Fountain 2 - Basement Lunch Room, Main Bldg.	5/26/16 4:00 PM	5/27/2016 5:00AM	0.314	BA
51048-B-W-F05-001	Fountain 1 - Inside Room B6, Bsmt. Main Bldg.	5/26/16 4:00 PM	5/27/2016 5:00AM	19.4	AA
51048-B-W-F05-002	Fountain 1 - Inside Room B6, Bsmt. Main Bldg.	5/26/16 4:00 PM	5/27/2016 5:00AM	7.56	BA
51048-B-W-F05-003	Fountain 1 - Inside Room B6, Bsmt. Main Bldg.	5/26/16 4:00 PM	5/27/2016 5:00AM	2.87	BA
51048-B-W-F05-004	Fountain 1 - Inside Room B6, Bsmt. Main Bldg.	5/26/16 4:00 PM	5/27/2016 5:00AM	2.78	BA
51048-B-W-F05-005	Fountain 1 - Inside Room B6, Bsmt. Main Bldg.	5/26/16 4:00 PM	5/27/2016 5:00AM	1.15	BA
51048-B-W-S06-001	Sink - Inside Room B6, Bsmt. Main Bldg.	5/26/16 4:00 PM	5/27/2016 5:00AM	0.873	BA
51048-B-W-S06-002	Sink - Inside Room B6, Bsmt. Main Bldg.	5/26/16 4:00 PM	5/27/2016 5:00AM	0.68	BA
51048-B-W-S06-003	Sink - Inside Room B6, Bsmt. Main Bldg.	5/26/16 4:00 PM	5/27/2016 5:00AM	0.514	BA
51048-B-W-S06-004	Sink - Inside Room B6, Bsmt. Main Bldg.	5/26/16 4:00 PM	5/27/2016 5:00AM	0.644	BA
51048-B-W-S06-005	Sink - Inside Room B6, Bsmt. Main Bldg.	5/26/16 4:00 PM	5/27/2016 5:00AM	0.758	BA
51048-B-W-S07-001	Sink - Outside Engineering Office, Bsmt. Main Bldg.	5/26/16 4:00 PM	5/27/2016 5:00AM	20.7	AA
51048-B-W-S07-002	Sink - Outside Engineering Office, Bsmt. Main Bldg.	5/26/16 4:00 PM	5/27/2016 5:00AM	4.42	BA
51048-B-W-S07-003	Sink - Outside Engineering Office, Bsmt. Main Bldg.	5/26/16 4:00 PM	5/27/2016 5:00AM	4.63	BA
51048-B-W-S07-004	Sink - Outside Engineering Office, Bsmt. Main Bldg.	5/26/16 4:00 PM	5/27/2016 5:00AM	5.28	BA
51048-B-W-S07-005	Sink - Outside Engineering Office, Bsmt. Main Bldg.	5/26/16 4:00 PM	5/27/2016 5:00AM	4.29	BA
51048-B-E-F08-001	Fountain 1 - Outside Room B11, Bsmt. Main Bldg.	5/26/16 4:00 PM	5/27/2016 5:00AM	1	BA
51048-B-E-F08-002	Fountain 1 - Outside Room B11, Bsmt. Main Bldg.	5/26/16 4:00 PM	5/27/2016 5:00AM	1.26	BA
51048-B-E-F08-003	Fountain 1 - Outside Room B11, Bsmt. Main Bldg.	5/26/16 4:00 PM	5/27/2016 5:00AM	1.1	BA
51048-B-E-F08-004	Fountain 1 - Outside Room B11, Bsmt. Main Bldg.	5/26/16 4:00 PM	5/27/2016 5:00AM	0.904	BA
51048-B-E-F08-005	Fountain 1 - Outside Room B11, Bsmt. Main Bldg.	5/26/16 4:00 PM	5/27/2016 5:00AM	0.95	BA
51048-B-W-F09-001	Fountain 2 - Outside Room B11, Bsmt. Main Bldg.	5/26/16 4:00 PM	5/27/2016 5:00AM	0.832	BA
51048-B-W-F09-002	Fountain 2 - Outside Room B11, Bsmt. Main Bldg.	5/26/16 4:00 PM	5/27/2016 5:00AM	0.48	BA
51048-B-W-F09-003	Fountain 2 - Outside Room B11, Bsmt. Main Bldg.	5/26/16 4:00 PM	5/27/2016 5:00AM	0.817	BA
51048-B-W-F09-004	Fountain 2 - Outside Room B11, Bsmt. Main Bldg.	5/26/16 4:00 PM	5/27/2016 5:00AM	0.253	BA
51048-B-W-F09-005	Fountain 2 - Outside Room B11, Bsmt. Main Bldg.	5/26/16 4:00 PM	5/27/2016 5:00AM	0.204	BA
51048-1-S-F01-001	Fountain 1 - Outside Room 106, 1st Fl. Main Bldg.	5/26/16 4:00 PM	5/27/2016 5:00AM	0.606	BA
51048-1-S-F01-002	Fountain 1 - Outside Room 106, 1st Fl. Main Bldg.	5/26/16 4:00 PM	5/27/2016 5:00AM	0.768	BA
51048-1-S-F01-003	Fountain 1 - Outside Room 106, 1st Fl. Main Bldg.	5/26/16 4:00 PM	5/27/2016 5:00AM	0.653	BA
51048-1-S-F01-004	Fountain 1 - Outside Room 106, 1st Fl. Main Bldg.	5/26/16 4:00 PM	5/27/2016 5:00AM	0.551	BA
51048-1-S-F01-005	Fountain 1 - Outside Room 106, 1st Fl. Main Bldg.	5/26/16 4:00 PM	5/27/2016 5:00AM	0.569	BA
51048-1-S-F02-001	Fountain 2 - Outside Room 106, 1st Fl. Main Bldg.	5/26/16 4:00 PM	5/27/2016 5:00AM	0.596	BA
51048-1-S-F02-002	Fountain 2 - Outside Room 106, 1st Fl. Main Bldg.	5/26/16 4:00 PM	5/27/2016 5:00AM	0.548	BA
51048-1-S-F02-003	Fountain 2 - Outside Room 106, 1st Fl. Main Bldg.	5/26/16 4:00 PM	5/27/2016 5:00AM	0.431	BA
51048-1-S-F02-004	Fountain 2 - Outside Room 106, 1st Fl. Main Bldg.	5/26/16 4:00 PM	5/27/2016 5:00AM	0.254	BA
51048-1-S-F02-005	Fountain 2 - Outside Room 106, 1st Fl. Main Bldg.	5/26/16 4:00 PM	5/27/2016 5:00AM	0.193	BA
51048-2-S-F01-001	Fountain - Outside Room 206, 2nd Fl. Main Bldg.	5/26/16 4:00 PM	5/27/2016 5:00AM	0.908	BA
51048-2-S-F01-002	Fountain - Outside Room 206, 2nd Fl. Main Bldg.	5/26/16 4:00 PM	5/27/2016 5:00AM	0.724	BA
51048-2-S-F01-003	Fountain - Outside Room 206, 2nd Fl. Main Bldg.	5/26/16 4:00 PM	5/27/2016 5:00AM	0.688	BA
51048-2-S-F01-004	Fountain - Outside Room 206, 2nd Fl. Main Bldg.	5/26/16 4:00 PM	5/27/2016 5:00AM	0.706	BA
51048-2-S-F01-005	Fountain - Outside Room 206, 2nd Fl. Main Bldg.	5/26/16 4:00 PM	5/27/2016 5:00AM	0.649	BA

51048-2-S-F02-001	Fountain 1 - Outside Room 202, 2nd Fl. Main Bldg.	5/26/16 4:00 PM	5/27/2016 5:00AM	0.329	BA
51048-2-S-F02-002	Fountain 1 - Outside Room 202, 2nd Fl. Main Bldg.	5/26/16 4:00 PM	5/27/2016 5:00AM	0.356	BA
51048-2-S-F02-003	Fountain 1 - Outside Room 202, 2nd Fl. Main Bldg.	5/26/16 4:00 PM	5/27/2016 5:00AM	0.362	BA
51048-2-S-F02-004	Fountain 1 - Outside Room 202, 2nd Fl. Main Bldg.	5/26/16 4:00 PM	5/27/2016 5:00AM	0.353	BA
51048-2-S-F02-005	Fountain 1 - Outside Room 202, 2nd Fl. Main Bldg.	5/26/16 4:00 PM	5/27/2016 5:00AM	0.337	BA
51048-2-S-F03-001	Fountain 2 - Outside Room 202, 2nd Fl. Main Bldg.	5/26/16 4:00 PM	5/27/2016 5:00AM	0.421	BA
51048-2-S-F03-002	Fountain 2 - Outside Room 202, 2nd Fl. Main Bldg.	5/26/16 4:00 PM	5/27/2016 5:00AM	0.421	BA
51048-2-S-F03-003	Fountain 2 - Outside Room 202, 2nd Fl. Main Bldg.	5/26/16 4:00 PM	5/27/2016 5:00AM	0.381	BA
51048-2-S-F03-004	Fountain 2 - Outside Room 202, 2nd Fl. Main Bldg.	5/26/16 4:00 PM	5/27/2016 5:00AM	0.371	BA
51048-2-S-F03-005	Fountain 2 - Outside Room 202, 2nd Fl. Main Bldg.	5/26/16 4:00 PM	5/27/2016 5:00AM	0.376	BA
51048-3-S-F01-001	Fountain - Outside Room 306, 2nd Fl. Main Bldg.	5/26/16 4:00 PM	5/27/2016 5:00AM	0.255	BA
51048-3-S-F01-002	Fountain - Outside Room 306, 2nd Fl. Main Bldg.	5/26/16 4:00 PM	5/27/2016 5:00AM	0.379	BA
51048-3-S-F01-003	Fountain - Outside Room 306, 2nd Fl. Main Bldg.	5/26/16 4:00 PM	5/27/2016 5:00AM	0.452	BA
51048-3-S-F01-004	Fountain - Outside Room 306, 2nd Fl. Main Bldg.	5/26/16 4:00 PM	5/27/2016 5:00AM	0.508	BA
51048-3-S-F01-005	Fountain - Outside Room 306, 2nd Fl. Main Bldg.	5/26/16 4:00 PM	5/27/2016 5:00AM	0.544	BA
51048-1-W-F01-001	Annex Bldg. Inside Room 122, Fountain	5/26/16 4:00 PM	5/27/2016 5:00AM	1.32	BA
51048-1-W-F01-002	Annex Bldg. Inside Room 122, Fountain	5/26/16 4:00 PM	5/27/2016 5:00AM	1.31	BA
51048-1-W-F01-003	Annex Bldg. Inside Room 122, Fountain	5/26/16 4:00 PM	5/27/2016 5:00AM	1.26	BA
51048-1-W-F01-004	Annex Bldg. Inside Room 122, Fountain	5/26/16 4:00 PM	5/27/2016 5:00AM	1.22	BA
51048-1-W-F01-005	Annex Bldg. Inside Room 122, Fountain	5/26/16 4:00 PM	5/27/2016 5:00AM	1.06	BA
51048-1-W-S02-001	Annex Bldg. Inside Room 122, Sink	5/26/16 4:00 PM	5/27/2016 5:00AM	3.89	BA
51048-1-W-S02-002	Annex Bldg. Inside Room 122, Sink	5/26/16 4:00 PM	5/27/2016 5:00AM	1.00	BA
51048-1-W-S02-003	Annex Bldg. Inside Room 122, Sink	5/26/16 4:00 PM	5/27/2016 5:00AM	1.04	BA
51048-1-W-S02-004	Annex Bldg. Inside Room 122, Sink	5/26/16 4:00 PM	5/27/2016 5:00AM	1.11	BA
51048-1-W-S02-005	Annex Bldg. Inside Room 122, Sink	5/26/16 4:00 PM	5/27/2016 5:00AM	1.26	BA
51048-1-C-S03-001	Annex Bldg. Outside Boys Bathroom, Sink	5/26/16 4:00 PM	5/27/2016 5:00AM	0.716	BA
51048-1-C-S03-002	Annex Bldg. Outside Boys Bathroom, Sink	5/26/16 4:00 PM	5/27/2016 5:00AM	0.608	BA
51048-1-C-S03-003	Annex Bldg. Outside Boys Bathroom, Sink	5/26/16 4:00 PM	5/27/2016 5:00AM	0.527	BA
51048-1-C-S03-004	Annex Bldg. Outside Boys Bathroom, Sink	5/26/16 4:00 PM	5/27/2016 5:00AM	0.501	BA
51048-1-C-S03-005	Annex Bldg. Outside Boys Bathroom, Sink	5/26/16 4:00 PM	5/27/2016 5:00AM	0.322	BA
51048-1-C-F04-001	Annex Bldg. Outside Girls Bathroom, Fountain 1	5/26/16 4:00 PM	5/27/2016 5:00AM	0.511	BA
51048-1-C-F04-002	Annex Bldg. Outside Girls Bathroom, Fountain 1	5/26/16 4:00 PM	5/27/2016 5:00AM	0.281	BA
51048-1-C-F04-003	Annex Bldg. Outside Girls Bathroom, Fountain 1	5/26/16 4:00 PM	5/27/2016 5:00AM	0.209	BA
51048-1-C-F04-004	Annex Bldg. Outside Girls Bathroom, Fountain 1	5/26/16 4:00 PM	5/27/2016 5:00AM	0.216	BA
51048-1-C-F04-005	Annex Bldg. Outside Girls Bathroom, Fountain 1	5/26/16 4:00 PM	5/27/2016 5:00AM	0.213	BA
51048-1-C-F05-001	Annex Bldg. Outside Girls Bathroom, Fountain 2	5/26/16 4:00 PM	5/27/2016 5:00AM	0.145	BA
51048-1-C-F05-002	Annex Bldg. Outside Girls Bathroom, Fountain 2	5/27/16 4:00 PM	5/27/2016 5:00AM	0.324	BA
51048-1-C-F05-003	Annex Bldg. Outside Girls Bathroom, Fountain 2	5/28/16 4:00 PM	5/27/2016 5:00AM	0.314	BA
51048-1-C-F05-004	Annex Bldg. Outside Girls Bathroom, Fountain 2	5/29/16 4:00 PM	5/27/2016 5:00AM	0.302	BA
51048-1-C-F05-005	Annex Bldg. Outside Girls Bathroom, Fountain 2	5/30/16 4:00 PM	5/27/2016 5:00AM	0.312	BA
51048-1-W-S06-001	Annex Bldg. Inside Room 128, Sink	5/31/16 4:00 PM	5/27/2016 5:00AM	4.65	BA
51048-1-W-S06-002	Annex Bldg. Inside Room 128, Sink	6/1/16 4:00 PM	5/27/2016 5:00AM	1.68	BA
51048-1-W-S06-003	Annex Bldg. Inside Room 128, Sink	6/2/16 4:00 PM	5/27/2016 5:00AM	1.49	BA
51048-1-W-S06-004	Annex Bldg. Inside Room 128, Sink	6/3/16 4:00 PM	5/27/2016 5:00AM	4.65	BA
51048-1-W-S06-005	Annex Bldg. Inside Room 128, Sink	6/4/16 4:00 PM	5/27/2016 5:00AM	1.92	BA
51048-1-W-F07-001	Annex Bldg. Inside Room 128, Fountain	5/26/16 4:00 PM	5/27/2016 5:00AM	0.939	BA
51048-1-W-F07-002	Annex Bldg. Inside Room 128, Fountain	5/27/16 4:00 PM	5/27/2016 5:00AM	0.973	BA
51048-1-W-F07-003	Annex Bldg. Inside Room 128, Fountain	5/26/16 4:00 PM	5/27/2016 5:00AM	0.963	BA
51048-1-W-F07-004	Annex Bldg. Inside Room 128, Fountain	5/26/16 4:00 PM	5/27/2016 5:00AM	0.97	BA
51048-1-W-F07-005	Annex Bldg. Inside Room 128, Fountain	5/26/16 4:00 PM	5/27/2016 5:00AM	1.03	BA

EPA ACTION LEVEL FOR LEAD IS 15 ppb or 15 µg/L

SPREADSHEET LEGEND

ND-Not Detected at the Reporting Limit

BA-Below EPA Action Level of 15 ppb

AA-Above EPA Action Level

Chicago Public Schools - Department of Facility Operations