



School Short Name  
Address

Camras

### School Lead Water Testing - Data Collection Form

Length of time water remained in pipes before sampled (hours) 8 hrs  
Report based on lab results dated  
Date of test 05/26/16  
Water last used (Time and date)

Sample ID #	Sample Location	Sample Collection Time & Date	Test Result (ppb)	Test Results
3-S-CS01-01	3rd Floor Kitchen	5/26/16 6:12 AM	None Detected	
3-S-CS01-02	3rd Floor Kitchen	5/26/16 6:12 AM	None Detected	
3-S-CS01-03	3rd Floor Kitchen	5/26/16 6:12 AM	None Detected	
3-S-CS01-04	3rd Floor Kitchen	5/26/16 6:12 AM	None Detected	
3-S-CS01-05	3rd Floor Kitchen	5/26/16 6:12 AM	None Detected	
3-S-F02-06	S. Corridor - Room 300 H	5/26/16 6:20 AM	None Detected	
3-S-F02-07	S. Corridor - Room 300 H	5/26/16 6:20 AM	None Detected	
3-S-F02-08	S. Corridor - Room 300 H	5/26/16 6:20 AM	None Detected	
3-S-F02-09	S. Corridor - Room 300 H	5/26/16 6:20 AM	None Detected	
3-S-F02-10	S. Corridor - Room 300 H	5/26/16 6:20 AM	None Detected	
3-S-F03-11	S. Corridor - Room 300 H	5/26/16 6:20 AM	None Detected	
3-S-F03-12	S. Corridor - Room 300 H	5/26/16 6:20 AM	None Detected	
3-S-F03-13	S. Corridor - Room 300 H	5/26/16 6:20 AM	None Detected	
3-S-F03-14	S. Corridor - Room 300 H	5/26/16 6:20 AM	None Detected	
3-S-F03-15	S. Corridor - Room 300 H	5/26/16 6:20 AM	None Detected	
3-N-F01-16	Corridor - Room 303	5/26/16 6:30 AM	None Detected	
3-N-F01-17	Corridor - Room 303	5/26/16 6:30 AM	None Detected	
3-N-F01-18	Corridor - Room 303	5/26/16 6:30 AM	None Detected	
3-N-F01-19	Corridor - Room 303	5/26/16 6:30 AM	None Detected	
3-N-F01-20	Corridor - Room 303	5/26/16 6:30 AM	None Detected	
3-N-F02-21	Corridor - Room 303	5/26/16 6:31 AM	None Detected	
3-N-F02-22	Corridor - Room 303	5/26/16 6:31 AM	None Detected	
3-N-F02-23	Corridor - Room 303	5/26/16 6:31 AM	None Detected	
3-N-F02-24	Corridor - Room 303	5/26/16 6:31 AM	None Detected	
3-N-F02-25	Corridor - Room 303	5/26/16 6:31 AM	None Detected	
3-N-F03-26	Corridor - Room 303	5/26/16 6:34 AM	None Detected	
3-N-F03-27	Corridor - Room 303	5/26/16 6:34 AM	None Detected	
3-N-F03-28	Corridor - Room 303	5/26/16 6:34 AM	None Detected	
3-N-F03-29	Corridor - Room 303	5/26/16 6:34 AM	None Detected	
3-N-F03-30	Corridor - Room 303	5/26/16 6:34 AM	None Detected	

EPA ACTION LEVEL FOR LEAD IS 15 ppb or 15 µg/L

#### SPREADSHEET LEGEND

ND-Not Detected at the Reporting Limit  
BA-Below EPA Action Level of 15 ppb