



School Lead Water Testing - Data Collection Form

School Short Name **Chopin**

Length of time water remained in pipes before sampled (hours) 8+
Date of test 05/24/16
Water last used (Time and date) 5/23/16

Sample ID #	Sample Collection Time & Date	Test Result (ppb)	Test Results
1-W-F-01	5/24/16 6:50 AM	ND	None Detected (ND)
1-E-F-02	5/24/16 6:52 AM	ND	None Detected (ND)
1-N-CS-03	5/24/16 6:54 AM	ND	None Detected (ND)
2-W-F-04	5/24/16 6:56 AM	ND	None Detected (ND)
2-W-F-05	5/24/16 6:58 AM	ND	None Detected (ND)
2-E-F-06	5/24/16 7:00 AM	ND	None Detected (ND)
2-E-F-07	5/24/16 7:02 AM	ND	None Detected (ND)
3-W-F-08	5/24/16 7:04 AM	ND	None Detected (ND)
3-W-F-09	5/24/16 7:06 AM	ND	None Detected (ND)
3-E-F-10	5/24/16 7:08 AM	ND	None Detected (ND)
3-E-F-11	5/24/16 7:10 AM	ND	None Detected (ND)

EPA ACTION LEVEL FOR LEAD IS 15 ppb or 15 µg/L

SPREADSHEET LEGEND

ND-Not Detected at the Reporting Limit
BA-Below EPA Action Level of 15 ppb
AA-Above EPA Action Level