



Chase

Sample ID	Sample Location	Sample Collection Time & Date	Test Result (ppb)	Test Results
51111-1-F01-001	Access from Room 106, Fountain 1	5/28/2016 5:00AM	<0.120	ND
51111-1-F01-002	Access from Room 106, Fountain 1	5/28/2016 5:00AM	0.121	BA
51111-1-F01-003	Access from Room 106, Fountain 1	5/28/2016 5:00AM	<0.120	ND
51111-1-F01-004	Access from Room 106, Fountain 1	5/28/2016 5:00AM	<0.120	ND
51111-1-F01-005	Access from Room 106, Fountain 1	5/28/2016 5:00AM	<0.120	ND
51111-1-F02-001	Access from Room 106, Fountain 2	5/28/2016 5:00AM	<0.120	ND
51111-1-F02-002	Access from Room 106, Fountain 2	5/28/2016 5:00AM	<0.120	ND
51111-1-F02-003	Access from Room 106, Fountain 2	5/28/2016 5:00AM	<0.120	ND
51111-1-F02-004	Access from Room 106, Fountain 2	5/28/2016 5:00AM	<0.120	ND
51111-1-F02-005	Access from Room 106, Fountain 2	5/28/2016 5:00AM	<0.120	ND
51111-1-F03-001	Access from Room 102, Fountain 1	5/28/2016 5:00AM	0.205	BA
51111-1-F03-002	Access from Room 102, Fountain 1	5/28/2016 5:00AM	0.678	BA
51111-1-F03-003	Access from Room 102, Fountain 1	5/28/2016 5:00AM	0.511	BA
51111-1-F03-004	Access from Room 102, Fountain 1	5/28/2016 5:00AM	0.163	BA
51111-1-F03-005	Access from Room 102, Fountain 1	5/28/2016 5:00AM	0.594	BA
51111-1-F04-001	Access from Room 102, Fountain 2	5/28/2016 5:00AM	0.618	BA
51111-1-F04-002	Access from Room 102, Fountain 2	5/28/2016 5:00AM	0.644	BA
51111-1-F04-003	Access from Room 102, Fountain 2	5/28/2016 5:00AM	0.644	BA
51111-1-F04-004	Access from Room 102, Fountain 2	5/28/2016 5:00AM	0.63	BA
51111-1-F04-005	Access from Room 102, Fountain 2	5/28/2016 5:00AM	0.697	BA
51111-1-S06-001	Annex, Inside Room A106, Sink 1	5/28/2016 5:00AM	0.986	BA
51111-1-S06-002	Annex, Inside Room A106, Sink 1	5/28/2016 5:00AM	0.39	BA
51111-1-S06-003	Annex, Inside Room A106, Sink 1	5/28/2016 5:00AM	0.471	BA
51111-1-S06-004	Annex, Inside Room A106, Sink 1	5/28/2016 5:00AM	0.658	BA
51111-1-S06-005	Annex, Inside Room A106, Sink 1	5/28/2016 5:00AM	0.138	BA
51111-1-S07-001	Annex, Inside Room A106, Sink 2	5/28/2016 5:00AM	0.459	BA
51111-1-S07-002	Annex, Inside Room A106, Sink 2	5/28/2016 5:00AM	0.763	BA
51111-1-S07-003	Annex, Inside Room A106, Sink 2	5/28/2016 5:00AM	0.376	BA
51111-1-S07-004	Annex, Inside Room A106, Sink 2	5/28/2016 5:00AM	0.13	BA
51111-1-S07-005	Annex, Inside Room A106, Sink 2	5/28/2016 5:00AM	0.597	BA
51111-1-S80-001	Main, Kitchen, Sink 1	6/1/2016 5:00AM	0.894	BA
51111-1-S80-002	Main, Kitchen, Sink 1	6/1/2016 5:00AM	0.175	BA
51111-1-S80-003	Main, Kitchen, Sink 1	6/1/2016 5:00AM	0.120	ND
51111-1-S80-004	Main, Kitchen, Sink 1	6/1/2016 5:00AM	<0.120	ND
51111-1-S80-005	Main, Kitchen, Sink 1	6/1/2016 5:00AM	<0.120	ND
51111-1-S81-001	Main, Kitchen Tray Left, Sink 2	6/1/2016 5:00AM	0.834	BA
51111-1-S81-002	Main, Kitchen Tray Left, Sink 2	6/1/2016 5:00AM	0.245	BA
51111-1-S81-003	Main, Kitchen Tray Left, Sink 2	6/1/2016 5:00AM	0.547	BA
51111-1-S81-004	Main, Kitchen Tray Left, Sink 2	6/1/2016 5:00AM	0.379	BA
51111-1-S82-001	Main, Kitchen Tray Center, Sink 3	6/1/2016 5:00AM	0.769	BA
51111-1-S82-002	Main, Kitchen Tray Center, Sink 3	6/1/2016 5:00AM	0.547	BA
51111-1-S82-003	Main, Kitchen Tray Center, Sink 3	6/1/2016 5:00AM	0.134	BA
51111-1-S82-004	Main, Kitchen Tray Center, Sink 3	6/1/2016 5:00AM	0.142	BA
51111-1-S83-001	Main, Kitchen Tray Right, Sink 4	6/1/2016 5:00AM	0.95	BA
51111-1-S83-002	Main, Kitchen Tray Right, Sink 4	6/1/2016 5:00AM	0.167	BA
51111-1-S83-003	Main, Kitchen Tray Right, Sink 4	6/1/2016 5:00AM	<0.120	ND
51111-1-S83-004	Main, Kitchen Tray Right, Sink 4	6/1/2016 5:00AM	0.13	BA
51111-1-S83-005	Main, Kitchen Tray Right, Sink 4	6/1/2016 5:00AM	0.157	BA
51111-1-S84-001	Main, Kitchen, Sink 5	6/1/2016 5:00AM	1.15	BA
51111-1-S84-002	Main, Kitchen, Sink 5	6/1/2016 5:00AM	0.12	BA
51111-1-S84-003	Main, Kitchen, Sink 5	6/1/2016 5:00AM	0.13	BA
51111-1-S84-004	Main, Kitchen, Sink 5	6/1/2016 5:00AM	0.154	BA
51111-1-S84-005	Main, Kitchen, Sink 5	6/1/2016 5:00AM	<0.120	ND
51111-1-S85-001	Main, Kitchen Above Slove, Faucet	6/1/2016 5:00AM	0.167	AA
51111-1-S85-002	Main, Kitchen Above Slove, Faucet	6/1/2016 5:00AM	0.12	AA
51111-1-S85-003	Main, Kitchen Above Slove, Faucet	6/1/2016 5:00AM	0.17	AA
51111-1-S85-004	Main, Kitchen Above Slove, Faucet	6/1/2016 5:00AM	131	AA
51111-1-S85-005	Main, Kitchen Above Slove, Faucet	6/1/2016 5:00AM	76.8	AA
51111-1-S86-001	Main, Kitchen Side Faucet	6/1/2016 5:00AM	2.33	BA
51111-1-S86-002	Main, Kitchen Side Faucet	6/1/2016 5:00AM	0.313	BA
51111-1-S86-003	Main, Kitchen Side Faucet	6/1/2016 5:00AM	0.287	BA
51111-1-S86-004	Main, Kitchen Side Faucet	6/1/2016 5:00AM	0.206	BA
51111-1-S86-005	Main, Kitchen Side Faucet	6/1/2016 5:00AM	0.378	BA
51111-1-S87-001	Main, Kitchen Serving Line, Sink	6/1/2016 5:00AM	0.247	BA
51111-1-S87-002	Main, Kitchen Serving Line, Sink	6/1/2016 5:00AM	<0.120	ND
51111-1-S87-003	Main, Kitchen Serving Line, Sink	6/1/2016 5:00AM	<0.120	ND
51111-1-S87-004	Main, Kitchen Serving Line, Sink	6/1/2016 5:00AM	<0.120	ND
51111-1-S87-005	Main, Kitchen Serving Line, Sink	6/1/2016 5:00AM	<0.120	ND
51111-1-SF03-001	Annex, Inside Room A106, Fountain	5/28/2016 5:00AM	<0.120	ND
51111-1-SF03-002	Annex, Inside Room A106, Fountain	5/28/2016 5:00AM	<0.120	ND
51111-1-SF03-003	Annex, Inside Room A106, Fountain	5/28/2016 5:00AM	<0.120	ND
51111-1-SF03-004	Annex, Inside Room A106, Fountain	5/28/2016 5:00AM	<0.120	ND
51111-1-SF03-005	Annex, Inside Room A106, Fountain	5/28/2016 5:00AM	<0.120	ND
51111-1-SF04-001	Annex, Next To Bathroom, Fountain 1	5/28/2016 5:00AM	<0.120	ND
51111-1-SF04-002	Annex, Next To Bathroom, Fountain 1	5/28/2016 5:00AM	<0.120	ND
51111-1-SF04-003	Annex, Next To Bathroom, Fountain 1	5/28/2016 5:00AM	<0.120	ND
51111-1-SF04-004	Annex, Next To Bathroom, Fountain 1	5/28/2016 5:00AM	<0.120	ND
51111-1-SF04-005	Annex, Next To Bathroom, Fountain 1	5/28/2016 5:00AM	<0.120	ND
51111-1-SF05-001	Annex, Next To Bathroom, Fountain 2	5/28/2016 5:00AM	<0.120	ND
51111-1-SF05-002	Annex, Next To Bathroom, Fountain 2	5/28/2016 5:00AM	<0.120	ND
51111-1-SF05-003	Annex, Next To Bathroom, Fountain 2	5/28/2016 5:00AM	<0.120	ND
51111-1-SF05-004	Annex, Next To Bathroom, Fountain 2	5/28/2016 5:00AM	<0.120	ND
51111-1-SF05-005	Annex, Next To Bathroom, Fountain 2	5/28/2016 5:00AM	<0.120	ND
51111-1-W501-001	Annex, Inside Room A108, Sink 1	5/28/2016 5:00AM	21.2	AA
51111-1-W501-002	Annex, Inside Room A108, Sink 1	5/28/2016 5:00AM	6.81	BA
51111-1-W501-003	Annex, Inside Room A108, Sink 1	5/28/2016 5:00AM	2.1	BA
51111-1-W501-004	Annex, Inside Room A108, Sink 1	5/28/2016 5:00AM	7.28	BA
51111-1-W501-005	Annex, Inside Room A108, Sink 1	5/28/2016 5:00AM	37.3	AA
51111-1-W502-001	Annex, Inside Room A108, Sink 2	5/28/2016 5:00AM	8.26	BA
51111-1-W502-002	Annex, Inside Room A108, Sink 2	5/28/2016 5:00AM	8.26	BA
51111-1-W502-003	Annex, Inside Room A108, Sink 2	5/28/2016 5:00AM	5.62	BA
51111-1-W502-004	Annex, Inside Room A108, Sink 2	5/28/2016 5:00AM	3.65	BA
51111-1-W502-005	Annex, Inside Room A108, Sink 2	5/28/2016 5:00AM	0.120	ND
51111-2-F01-001	Access from Room 206, Fountain 1	5/28/2016 5:00AM	<0.120	ND
51111-2-F01-002	Access from Room 206, Fountain 1	5/28/2016 5:00AM	0.13	BA
51111-2-F01-003	Access from Room 206, Fountain 1	5/28/2016 5:00AM	0.139	BA
51111-2-F01-004	Access from Room 206, Fountain 1	5/28/2016 5:00AM	0.173	BA
51111-2-F01-005	Access from Room 206, Fountain 1	5/28/2016 5:00AM	0.138	BA
51111-2-F02-001	Access from Room 206, Fountain 2	5/28/2016 5:00AM	0.189	BA
51111-2-F02-002	Access from Room 206, Fountain 2	5/28/2016 5:00AM	0.197	BA
51111-2-F02-003	Access from Room 206, Fountain 2	5/28/2016 5:00AM	0.206	BA
51111-2-F02-004	Access from Room 206, Fountain 2	5/28/2016 5:00AM	0.233	BA
51111-2-F02-005	Access from Room 202, Fountain 1	5/28/2016 5:00AM	0.663	BA
51111-2-F03-001	Access from Room 202, Fountain 1	5/28/2016 5:00AM	0.52	BA
51111-2-F03-002	Access from Room 202, Fountain 1	5/28/2016 5:00AM	0.78	BA
51111-2-F03-003	Access from Room 202, Fountain 1	5/28/2016 5:00AM	0.793	BA
51111-2-F03-004	Access from Room 202, Fountain 1	5/28/2016 5:00AM	0.769	BA
51111-2-F04-001	Access from Room 202, Fountain 2	5/28/2016 5:00AM	0.304	BA
51111-2-F04-002	Access from Room 202, Fountain 2	5/28/2016 5:00AM	0.22	BA
51111-2-F04-003	Access from Room 202, Fountain 2	5/28/2016 5:00AM	0.712	BA
51111-2-F04-004	Access from Room 202, Fountain 2	5/28/2016 5:00AM	0.683	BA
51111-2-F04-005	Access from Room 202, Fountain 2	5/28/2016 5:00AM	0.661	BA
51111-2-SF01-001	Annex, Across Room A208, Fountain	5/28/2016 5:00AM	0.120	ND
51111-2-SF01-002	Annex, Across Room A208, Fountain	5/28/2016 5:00AM	<0.120	ND
51111-2-SF01-003	Annex, Across Room A208, Fountain	5/28/2016 5:00AM	<0.120	ND
51111-2-SF01-004	Annex, Across Room A208, Fountain	5/28/2016 5:00AM	<0.120	ND
51111-2-SF01-005	Annex, Across Room A208, Fountain	5/28/2016 5:00AM	<0.120	ND
51111-2-SF02-001	Annex, Across Room A208, Fountain 1	5/28/2016 5:00AM	<0.120	ND
51111-2-SF02-002	Annex, Across Room A208, Fountain 1	5/28/2016 5:00AM	0.241	BA
51111-2-SF02-003	Annex, Across Room A208, Fountain 1	5/28/2016 5:00AM	0.209	BA
51111-2-SF02-004	Annex, Across Room A208, Fountain 1	5/28/2016 5:00AM	<0.120	ND
51111-2-SF02-005	Annex, Across Room A208, Fountain 1	5/28/2016 5:00AM	<0.120	ND
51111-2-SF03-001	Annex, Across Room A208, Fountain 2	5/28/2016 5:00AM	<0.120	ND
51111-2-SF03-002	Annex, Across Room A208, Fountain 2	5/28/2016 5:00AM	<0.120	ND
51111-2-SF03-003	Annex, Across Room A208, Fountain 2	5/28/2016 5:00AM	<0.120	ND
51111-2-SF03-004	Annex, Across Room A208, Fountain 2	5/28/2016 5:00AM	<0.120	ND
51111-2-SF03-005	Annex, Across Room A208, Fountain 2	5/28/2016 5:00AM	<0.120	ND
51111-3-F03-001	Access from Room 302, Fountain 1	5/28/2016 5:00AM	0.242	BA
51111-3-F03-002	Access from Room 302, Fountain 1	5/28/2016 5:00AM	1.09	BA
51111-3-F03-003	Access from Room 302, Fountain 1	5/28/2016 5:00AM	1.07	BA
51111-3-F03-004	Access from Room 302, Fountain 1	5/28/2016 5:00AM	0.899	BA
51111-3-F04-001	Access from Room 302, Fountain 2	5/28/2016 5:00AM	0.2	BA
51111-3-F04-002	Access from Room 302, Fountain 2	5/28/2016 5:00AM	0.26	BA
51111-3-F04-003	Access from Room 302, Fountain 2	5/28/2016 5:00AM	0.721	BA
51111-3-F04-004	Access from Room 302, Fountain 2	5/28/2016 5:00AM	0.868	BA
51111-3-F04-005	Access from Room 302, Fountain 2	5/28/2016 5:00AM	0.209	BA

51111-3-S-F01-001	Across from Room 307c, Fountain 1	5/28/2016 5:00AM	1.63	BA
51111-3-S-F01-001	Annex, Across Room A306, Fountain	5/28/2016 5:00AM	<0.120	ND
51111-3-S-F01-002	Across from Room 307c, Fountain 1	5/28/2016 5:00AM	1.82	BA
51111-3-S-F01-002	Annex, Across Room A308, Fountain	5/28/2016 5:00AM	<0.120	ND
51111-3-S-F01-003	Across from Room 307c, Fountain 1	5/28/2016 5:00AM	2.44	BA
51111-3-S-F01-003	Annex, Across Room A306, Fountain	5/28/2016 5:00AM	<0.120	ND
51111-3-S-F01-004	Across from Room 307c, Fountain 1	5/28/2016 5:00AM	2.69	BA
51111-3-S-F01-004	Annex, Across Room A308, Fountain	5/28/2016 5:00AM	<0.120	ND
51111-3-S-F01-005	Across from Room 307c, Fountain 1	5/28/2016 5:00AM	2.69	BA
51111-3-S-F01-005	Annex, Across Room A306, Fountain	5/28/2016 5:00AM	<0.120	ND
51111-3-S-F02-001	Across from Room 307c, Fountain 2	5/28/2016 5:00AM	2.73	BA
51111-3-S-F02-001	Annex, Across Room A306, Fountain 1	5/28/2016 5:00AM	<0.120	ND
51111-3-S-F02-002	Across from Room 307c, Fountain 2	5/28/2016 5:00AM	2.94	BA
51111-3-S-F02-002	Annex, Across Room A306, Fountain 1	5/28/2016 5:00AM	<0.120	ND
51111-3-S-F02-003	Across from Room 307c, Fountain 2	5/28/2016 5:00AM	2.82	BA
51111-3-S-F02-003	Annex, Across Room A306, Fountain 1	5/28/2016 5:00AM	<0.120	ND
51111-3-S-F02-004	Across from Room 307c, Fountain 2	5/28/2016 5:00AM	2.94	BA
51111-3-S-F02-004	Annex, Across Room A306, Fountain 1	5/28/2016 5:00AM	<0.120	ND
51111-3-S-F02-005	Across from Room 307c, Fountain 2	5/28/2016 5:00AM	2.88	BA
51111-3-S-F02-005	Annex, Across Room A306, Fountain 1	5/28/2016 5:00AM	<0.120	ND
51111-3-S-F03-001	Annex, Across Room A306, Fountain 2	5/28/2016 5:00AM	<0.120	ND
51111-3-S-F03-002	Annex, Across Room A306, Fountain 2	5/28/2016 5:00AM	<0.120	ND
51111-3-S-F03-003	Annex, Across Room A306, Fountain 2	5/28/2016 5:00AM	<0.120	ND
51111-3-S-F03-004	Annex, Across Room A306, Fountain 2	5/28/2016 5:00AM	<0.120	ND
51111-3-S-F03-005	Annex, Across Room A306, Fountain 2	6/21/2016 5:00AM	<0.120	ND
51111-B-E-F01-001	Across from Room 016, Fountain 1	5/28/2016 5:00AM	0.684	BA
51111-B-E-F01-002	Across from Room 016, Fountain 1	5/28/2016 5:00AM	1.26	BA
51111-B-E-F01-003	Across from Room 016, Fountain 1	5/28/2016 5:00AM	1.12	BA
51111-B-E-F01-004	Across from Room 016, Fountain 1	5/28/2016 5:00AM	1.19	BA
51111-B-E-F01-005	Across from Room 016, Fountain 1	5/28/2016 5:00AM	1.17	BA
51111-B-E-F02-001	Across from Room 016, Fountain 2	5/28/2016 5:00AM	1.09	BA
51111-B-E-F02-002	Across from Room 016, Fountain 2	5/28/2016 5:00AM	1.26	BA
51111-B-E-F02-003	Across from Room 016, Fountain 2	5/28/2016 5:00AM	1.22	BA
51111-B-E-F02-004	Across from Room 016, Fountain 2	5/28/2016 5:00AM	1.19	BA
51111-B-E-F02-005	Across from Room 016, Fountain 2	5/28/2016 5:00AM	1.17	BA
51111-B-E-F03-001	Across from Room 010, Fountain 1	5/28/2016 5:00AM	0.905	BA
51111-B-E-F03-002	Across from Room 010, Fountain 1	5/28/2016 5:00AM	1.42	BA
51111-B-E-F03-003	Across from Room 010, Fountain 1	5/28/2016 5:00AM	1.43	BA
51111-B-E-F03-004	Across from Room 010, Fountain 1	5/28/2016 5:00AM	0.893	BA
51111-B-E-F03-005	Across from Room 010, Fountain 1	5/28/2016 5:00AM	0.855	BA
51111-B-E-F04-001	Across from Room 010, Fountain 2	5/28/2016 5:00AM	0.774	BA
51111-B-E-F04-002	Across from Room 010, Fountain 2	5/28/2016 5:00AM	0.611	BA
51111-B-E-F04-003	Across from Room 010, Fountain 2	5/28/2016 5:00AM	0.763	BA
51111-B-E-F04-004	Across from Room 010, Fountain 2	5/28/2016 5:00AM	0.826	BA
51111-B-E-F04-005	Across from Room 010, Fountain 2	5/28/2016 5:00AM	0.856	BA
51111-B-N-S07-001	Inside Room 010, Sink	5/28/2016 5:00AM	1.02	BA
51111-B-N-S07-002	Inside Room 010, Sink	5/28/2016 5:00AM	1.37	BA
51111-B-N-S07-003	Inside Room 010, Sink	5/28/2016 5:00AM	1.32	BA
51111-B-N-S07-004	Inside Room 010, Sink	5/28/2016 5:00AM	2.1	BA
51111-B-N-S07-005	Inside Room 010, Sink	5/28/2016 5:00AM	2.15	BA
51111-B-S-F05-001	Inside Room 014, Fountain	5/28/2016 5:00AM	0.19	BA
51111-B-S-F05-002	Inside Room 014, Fountain	5/28/2016 5:00AM	0.455	BA
51111-B-S-F05-003	Inside Room 014, Fountain	5/28/2016 5:00AM	0.566	BA
51111-B-S-F05-004	Inside Room 014, Fountain	5/28/2016 5:00AM	0.479	BA
51111-B-S-F05-005	Inside Room 014, Fountain	5/28/2016 5:00AM	0.5	BA
51111-B-S-S06-001	Inside Room 014, Sink	5/28/2016 5:00AM	0.318	BA
51111-B-S-S06-002	Inside Room 014, Sink	5/28/2016 5:00AM	0.999	BA
51111-B-S-S06-003	Inside Room 014, Sink	5/28/2016 5:00AM	0.899	BA
51111-B-S-S06-004	Inside Room 014, Sink	5/28/2016 5:00AM	0.744	BA
51111-B-S-S06-005	Inside Room 014, Sink	5/28/2016 5:00AM	0.552	BA
51111-B-W-S08-001	Inside Room 013, Sink	5/28/2016 5:00AM	0.986	BA
51111-B-W-S08-002	Inside Room 013, Sink	5/28/2016 5:00AM	1.14	BA
51111-B-W-S08-003	Inside Room 013, Sink	5/28/2016 5:00AM	0.978	BA
51111-B-W-S08-004	Inside Room 013, Sink	5/28/2016 5:00AM	0.933	BA
51111-B-W-S08-005	Inside Room 013, Sink	5/28/2016 5:00AM	1.01	BA

EPA ACTION LEVEL FOR LEAD IS 15 ppb or 15 µg/L

**SPREADSHEET LEGEND**

ND-Not Detected at the Reporting Limit  
BA-Below EPA Action Level of 15 ppb  
AA-Above EPA Action Level

Chicago Public Schools - Department of Facility Operations