



# School Lead Water Testing - Data Collection Form

School Short Name

Chicago Academy ES

Length of time water remained in pipes before sampled (hours)

13.00

Report based on lab results dated

6/16/16

Date of test

06/02/16

Water last used (Time and date)

Approx 4 PM 6/01/16

Sample ID #	Sample Location	Sample Collection Time & Date	Test Result (ppb)	Test Results
51041-1-N-F01-001	Fountain 1 Outside Room 125A	6/2/16 5:00 AM	0.187	BA
51041-1-N-F01-002	Fountain 1 Outside Room 125A	6/2/16 5:00 AM	0.197	BA
51041-1-N-F01-003	Fountain 1 Outside Room 125A	6/2/16 5:00 AM	0.386	BA
51041-1-N-F01-004	Fountain 1 Outside Room 125A	6/2/16 5:00 AM	0.623	BA
51041-1-N-F01-005	Fountain 1 Outside Room 125A	6/2/16 5:00 AM	0.525	BA
51041-1-N-F02-001	Fountain 2 Outside Room 125A	6/2/16 5:00 AM	0.434	BA
51041-1-N-F02-002	Fountain 2 Outside Room 125A	6/2/16 5:00 AM	0.427	BA
51041-1-N-F02-003	Fountain 2 Outside Room 125A	6/2/16 5:00 AM	0.4	BA
51041-1-N-F02-004	Fountain 2 Outside Room 125A	6/2/16 5:00 AM	0.367	BA
51041-1-N-F02-005	Fountain 2 Outside Room 125A	6/2/16 5:00 AM	0.332	BA
51041-1-NW-S03-001	Sink Inside Pre-K Room 121	6/2/16 5:00 AM	<0.120	ND
51041-1-NW-S03-002	Sink Inside Pre-K Room 121	6/2/16 5:00 AM	<0.120	ND
51041-1-NW-S03-003	Sink Inside Pre-K Room 121	6/2/16 5:00 AM	<0.120	ND
51041-1-NW-S03-004	Sink Inside Pre-K Room 121	6/2/16 5:00 AM	<0.120	ND
51041-1-NW-S03-005	Sink Inside Pre-K Room 121	6/2/16 5:00 AM	0.273	BA
51041-1-NW-F04-001	Fountain Inside Pre-K Room 121	6/2/16 5:00 AM	<0.120	ND
51041-1-NW-F04-002	Fountain Inside Pre-K Room 121	6/2/16 5:00 AM	<0.120	ND
51041-1-NW-F04-003	Fountain Inside Pre-K Room 121	6/2/16 5:00 AM	<0.120	ND
51041-1-NW-F04-004	Fountain Inside Pre-K Room 121	6/2/16 5:00 AM	<0.120	ND
51041-1-NW-F04-005	Fountain Inside Pre-K Room 121	6/2/16 5:00 AM	<0.120	ND
51041-1-NE-S06-001	Sink Inside Room 115	6/2/16 5:00 AM	<0.120	ND
51041-1-NE-S06-002	Sink Inside Room 115	6/2/16 5:00 AM	0.127	BA
51041-1-NE-S06-003	Sink Inside Room 115	6/2/16 5:00 AM	<0.120	ND
51041-1-NE-S06-004	Sink Inside Room 115	6/2/16 5:00 AM	1.29	BA
51041-1-NE-S06-005	Sink Inside Room 115	6/2/16 5:00 AM	<0.120	ND
51041-1-NE-F07-001	Fountain Outside Room 116	6/2/16 5:00 AM	0.188	BA
51041-1-NE-F07-002	Fountain Outside Room 116	6/2/16 5:00 AM	0.286	BA
51041-1-NE-F07-003	Fountain Outside Room 116	6/2/16 5:00 AM	0.271	BA
51041-1-NE-F07-004	Fountain Outside Room 116	6/2/16 5:00 AM	0.282	BA
51041-1-NE-F07-005	Fountain Outside Room 116	6/2/16 5:00 AM	0.258	BA
51041-1-SW-F08-001	Fountain Inside Kindergarten Room 111	6/2/16 5:00 AM	<0.120	ND
51041-1-SW-F08-002	Fountain Inside Kindergarten Room 111	6/2/16 5:00 AM	<0.120	ND
51041-1-SW-F08-003	Fountain Inside Kindergarten Room 111	6/2/16 5:00 AM	<0.120	ND
51041-1-SW-F08-004	Fountain Inside Kindergarten Room 111	6/2/16 5:00 AM	<0.120	ND
51041-1-SW-F08-005	Fountain Inside Kindergarten Room 111	6/2/16 5:00 AM	<0.120	ND
51041-1-SW-S09-001	Sink Inside Kindergarten Room 111	6/2/16 5:00 AM	<0.120	ND
51041-1-SW-S09-002	Sink Inside Kindergarten Room 111	6/2/16 5:00 AM	<0.120	ND
51041-1-SW-S09-003	Sink Inside Kindergarten Room 111	6/2/16 5:00 AM	<0.120	ND
51041-1-SW-S09-004	Sink Inside Kindergarten Room 111	6/2/16 5:00 AM	<0.120	ND
51041-1-SW-S09-005	Sink Inside Kindergarten Room 111	6/2/16 5:00 AM	<0.120	ND
51041-1-SE-F10-001	Fountain 1 Outside Room 110	6/2/16 5:00 AM	<0.120	ND
51041-1-SE-F10-002	Fountain 1 Outside Room 110	6/2/16 5:00 AM	<0.120	ND
51041-1-SE-F10-003	Fountain 1 Outside Room 110	6/2/16 5:00 AM	<0.120	ND
51041-1-SE-F10-004	Fountain 1 Outside Room 110	6/2/16 5:00 AM	0.204	BA
51041-1-SE-F10-005	Fountain 1 Outside Room 110	6/2/16 5:00 AM	0.173	BA
51041-1-SE-F11-001	Fountain 2 Outside Room 110	6/2/16 5:00 AM	0.16	BA
51041-1-SE-F11-002	Fountain 2 Outside Room 110	6/2/16 5:00 AM	0.128	BA
51041-1-SE-F11-003	Fountain 2 Outside Room 110	6/2/16 5:00 AM	0.12	BA
51041-1-SE-F11-004	Fountain 2 Outside Room 110	6/2/16 5:00 AM	<0.120	ND
51041-1-SE-F11-005	Fountain 2 Outside Room 110	6/2/16 5:00 AM	<0.120	ND
51041-1-SE-F12-001	Fountain Inside Room 109	6/2/16 5:00 AM	<0.120	ND
51041-1-SE-F12-002	Fountain Inside Room 109	6/2/16 5:00 AM	<0.120	ND
51041-1-SE-F12-003	Fountain Inside Room 109	6/2/16 5:00 AM	<0.120	ND
51041-1-SE-F12-004	Fountain Inside Room 109	6/2/16 5:00 AM	<0.120	ND
51041-1-SE-F12-005	Fountain Inside Room 109	6/2/16 5:00 AM	<0.120	ND
51041-1-SE-S13-001	Sink Inside Room 109	6/2/16 5:00 AM	<0.120	ND
51041-1-SE-S13-002	Sink Inside Room 109	6/2/16 5:00 AM	<0.120	ND
51041-1-SE-S13-003	Sink Inside Room 109	6/2/16 5:00 AM	<0.120	ND
51041-1-SE-S13-004	Sink Inside Room 109	6/2/16 5:00 AM	<0.120	ND
51041-1-SE-S13-005	Sink Inside Room 109	6/2/16 5:00 AM	<0.120	ND
51041-1-SE-S14-001	Sink 1 In Elementary Teachers Lounge	6/2/16 5:00 AM	1.07	BA
51041-1-SE-S14-002	Sink 1 In Elementary Teachers Lounge	6/2/16 5:00 AM	1.24	BA
51041-1-SE-S14-003	Sink 1 In Elementary Teachers Lounge	6/2/16 5:00 AM	1.13	BA
51041-1-SE-S14-004	Sink 1 In Elementary Teachers Lounge	6/2/16 5:00 AM	0.827	BA
51041-1-SE-S14-005	Sink 1 In Elementary Teachers Lounge	6/2/16 5:00 AM	1.01	BA
51041-1-SE-S15-001	Sink 2 In Elementary Teachers Lounge	6/2/16 5:00 AM	0.363	BA
51041-1-SE-S15-002	Sink 2 In Elementary Teachers Lounge	6/2/16 5:00 AM	0.856	BA
51041-1-SE-S15-003	Sink 2 In Elementary Teachers Lounge	6/2/16 5:00 AM	0.718	BA
51041-1-SE-S15-004	Sink 2 In Elementary Teachers Lounge	6/2/16 5:00 AM	0.592	BA
51041-1-SE-S15-005	Sink 2 In Elementary Teachers Lounge	6/2/16 5:00 AM	0.389	BA
51041-1-SF-F16-001	Fountain Outside Room 107	6/2/16 5:00 AM	0.132	BA
51041-1-SF-F16-002	Fountain Outside Room 107	6/2/16 5:00 AM	0.153	BA
51041-1-SF-F16-003	Fountain Outside Room 107	6/2/16 5:00 AM	0.167	BA
51041-1-SF-F16-004	Fountain Outside Room 107	6/2/16 5:00 AM	0.237	BA
51041-1-SF-F16-005	Fountain Outside Room 107	6/2/16 5:00 AM	0.263	BA
51041-2-N-F01-001	Fountain Outside Room 225	6/2/16 5:00 AM	<0.120	ND
51041-2-N-F01-002	Fountain Outside Room 225	6/2/16 5:00 AM	<0.120	ND
51041-2-N-F01-003	Fountain Outside Room 225	6/2/16 5:00 AM	0.172	BA
51041-2-N-F01-004	Fountain Outside Room 225	6/2/16 5:00 AM	0.286	BA
51041-2-N-F01-005	Fountain Outside Room 225	6/2/16 5:00 AM	0.342	BA
51041-2-N-F02-001	Fountain Outside Room 225A	6/2/16 5:00 AM	0.659	BA
51041-2-N-F02-002	Fountain Outside Room 225A	6/2/16 5:00 AM	0.351	BA
51041-2-N-F02-003	Fountain Outside Room 225A	6/2/16 5:00 AM	0.134	BA
51041-2-N-F02-004	Fountain Outside Room 225A	6/2/16 5:00 AM	0.325	BA
51041-2-N-F02-005	Fountain Outside Room 225A	6/2/16 5:00 AM	0.308	BA
51041-2-E-F03-001	Fountain Outside Room 216	6/2/16 5:00 AM	0.141	BA
51041-2-E-F03-002	Fountain Outside Room 216	6/2/16 5:00 AM	0.235	BA
51041-2-E-F03-003	Fountain Outside Room 216	6/2/16 5:00 AM	0.257	BA
51041-2-E-F03-004	Fountain Outside Room 216	6/2/16 5:00 AM	0.257	BA
51041-2-E-F03-005	Fountain Outside Room 216	6/2/16 5:00 AM	0.291	BA
51041-2-S-F05-001	Fountain 1 Outside Room 207B	6/2/16 5:00 AM	<0.120	ND
51041-2-S-F05-002	Fountain 1 Outside Room 207B	6/2/16 5:00 AM	<0.120	ND
51041-2-S-F05-003	Fountain 1 Outside Room 207B	6/2/16 5:00 AM	0.164	BA
51041-2-S-F05-004	Fountain 1 Outside Room 207B	6/2/16 5:00 AM	0.21	BA
51041-2-S-F05-005	Fountain 1 Outside Room 207B	6/2/16 5:00 AM	0.21	BA
51041-2-S-F06-001	Fountain 2 Outside Room 207B	6/2/16 5:00 AM	0.193	BA
51041-2-S-F06-002	Fountain 2 Outside Room 207B	6/2/16 5:00 AM	0.171	BA
51041-2-S-F06-003	Fountain 2 Outside Room 207B	6/2/16 5:00 AM	0.159	BA
51041-2-S-F06-004	Fountain 2 Outside Room 207B	6/2/16 5:00 AM	0.164	BA
51041-2-S-F06-005	Fountain 2 Outside Room 207B	6/2/16 5:00 AM	0.177	BA
51041-2-SE-F07-001	Fountain 1 Inside Gym	6/2/16 5:00 AM	1.32	BA
51041-2-SE-F07-002	Fountain 1 Inside Gym	6/2/16 5:00 AM	1.31	BA
51041-2-SE-F07-003	Fountain 1 Inside Gym	6/2/16 5:00 AM	1.6	BA
51041-2-SE-F07-004	Fountain 1 Inside Gym	6/2/16 5:00 AM	1.93	BA
51041-2-SE-F07-005	Fountain 1 Inside Gym	6/2/16 5:00 AM	2.05	BA
51041-2-SE-F08-001	Fountain 2 Inside Gym	6/2/16 5:00 AM	0.892	BA
51041-2-SE-F08-002	Fountain 2 Inside Gym	6/2/16 5:00 AM	1.1	BA
51041-2-SE-F08-003	Fountain 2 Inside Gym	6/2/16 5:00 AM	1.32	BA
51041-2-SE-F08-004	Fountain 2 Inside Gym	6/2/16 5:00 AM	1.47	BA
51041-2-SE-F08-005	Fountain 2 Inside Gym	6/2/16 5:00 AM	1.56	BA
51041-3-N-S01-001	Kitchen Sink 1	6/2/16 5:00 AM	1.2	BA
51041-3-N-S01-002	Kitchen Sink 1	6/2/16 5:00 AM	<0.120	ND
51041-3-N-S01-003	Kitchen Sink 1	6/2/16 5:00 AM	<0.120	ND
51041-3-N-S01-004	Kitchen Sink 1	6/2/16 5:00 AM	<0.120	ND
51041-3-N-S01-005	Kitchen Sink 1	6/2/16 5:00 AM	<0.120	ND
51041-3-N-S02-001	Kitchen Sink 2	6/2/16 5:00 AM	<0.120	ND
51041-3-N-S02-002	Kitchen Sink 2	6/2/16 5:00 AM	<0.120	ND
51041-3-N-S02-003	Kitchen Sink 2	6/2/16 5:00 AM	2.83	BA
51041-3-N-S02-004	Kitchen Sink 2	6/2/16 5:00 AM	1.24	BA
51041-3-N-S02-005	Kitchen Sink 2	6/2/16 5:00 AM	<0.120	ND
51041-3-N-F03-001	Fountain 1 Across Lunchroom near Womens Toilets	6/2/16 5:00 AM	0.318	BA
51041-3-N-F03-002	Fountain 1 Across Lunchroom near Womens Toilets	6/2/16 5:00 AM	0.33	BA
51041-3-N-F03-003	Fountain 1 Across Lunchroom near Womens Toilets	6/2/16 5:00 AM	0.423	BA
51041-3-N-F03-004	Fountain 1 Across Lunchroom near Womens Toilets	6/2/16 5:00 AM	0.564	BA
51041-3-N-F03-005	Fountain 1 Across Lunchroom near Womens Toilets	6/2/16 5:00 AM	0.726	BA
51041-3-N-F04-001	Fountain 2 Across Lunchroom near Womens Toilets	6/2/16 5:00 AM	0.591	BA
51041-3-N-F04-002	Fountain 2 Across Lunchroom near Womens Toilets	6/2/16 5:00 AM	0.587	BA
51041-3-N-F04-003	Fountain 2 Across Lunchroom near Womens Toilets	6/2/16 5:00 AM	0.527	BA
51041-3-N-F04-004	Fountain 2 Across Lunchroom near Womens Toilets	6/2/16 5:00 AM	0.486	BA
51041-3-N-F04-005	Fountain 2 Across Lunchroom near Womens Toilets	6/2/16 5:00 AM	0.477	BA
51041-3-S-F05-001	Fountain 1 Outside Room 316	6/2/16 5:00 AM	0.668	BA
51041-3-S-F05-002	Fountain 1 Outside Room 316	6/2/16 5:00 AM	0.763	BA
51041-3-S-F05-003	Fountain 1 Outside Room 316	6/2/16 5:00 AM	0.838	BA
51041-3-S-F05-004	Fountain 1 Outside Room 316	6/2/16 5:00 AM	0.868	BA
51041-3-S-F05-005	Fountain 1 Outside Room 316	6/2/16 5:00 AM	0.858	BA
51041-3-S-F06-001	Fountain 2 Outside Room 316	6/2/16 5:00 AM	0.572	BA
51041-3-S-F06-002	Fountain 2 Outside Room 316	6/2/16 5:00 AM	0.577	BA
51041-3-S-F06-003	Fountain 2 Outside Room 316	6/2/16 5:00 AM	0.625	BA
51041-3-S-F06-004	Fountain 2 Outside Room 316	6/2/16 5:00 AM	0.742	BA
51041-3-S-F06-005	Fountain 2 Outside Room 316	6/2/16 5:00 AM	0.631	BA

51041-3-S-F07-001	Fountain 1 Outside Room 305A	6/2/16 5:00 AM	0.152	BA
51041-3-S-F07-002	Fountain 1 Outside Room 305A	6/2/16 5:00 AM	0.17	BA
51041-3-S-F07-003	Fountain 1 Outside Room 305A	6/2/16 5:00 AM	0.28	BA
51041-3-S-F07-004	Fountain 1 Outside Room 305A	6/2/16 5:00 AM	0.37	BA
51041-3-S-F07-005	Fountain 1 Outside Room 305A	6/2/16 5:00 AM	0.659	BA
51041-3-S-F08-001	Fountain 2 Outside Room 305A	6/2/16 5:00 AM	0.165	BA
51041-3-S-F08-002	Fountain 2 Outside Room 305A	6/2/16 5:00 AM	0.351	BA
51041-3-S-F08-003	Fountain 2 Outside Room 305A	6/2/16 5:00 AM	0.425	BA
51041-3-S-F08-004	Fountain 2 Outside Room 305A	6/2/16 5:00 AM	0.872	BA
51041-3-S-F08-005	Fountain 2 Outside Room 305A	6/2/16 5:00 AM	1.3	BA
51041-3-S-S09-001	Sink Inside High School Teachers Lounge	6/2/16 5:00 AM	0.248	BA
51041-3-S-S09-002	Sink Inside High School Teachers Lounge	6/2/16 5:00 AM	0.156	BA
51041-3-S-S09-003	Sink Inside High School Teachers Lounge	6/2/16 5:00 AM	0.157	BA
51041-3-S-S09-004	Sink Inside High School Teachers Lounge	6/2/16 5:00 AM	0.156	BA
51041-3-S-S09-005	Sink Inside High School Teachers Lounge	6/2/16 5:00 AM	0.181	BA

EPA ACTION LEVEL FOR LEAD IS 15 ppb or 15 µg/L

**SPREADSHEET LEGEND**

ND-Not Detected at the Reporting Limit  
BA-Below EPA Action Level of 15 ppb

AA-Above EPA Action Level

Chicago Public Schools - Department of Facility Operations