



July 22, 2016

Dear Nettelhorst families,

In light of national events that have brought increased attention to the issue of water quality, the City of Chicago announced several additional precautionary measures that will be added to the City's water testing protocol, continuing the City's track record of complying with current state and federal regulations as well as exceeding industry standards.

As part of this announcement, Chicago Public Schools (CPS) began testing the water for levels of lead from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe. Schools are being tested based on a priority criteria that includes the age of the school, age of the students (with priority given to schools with pre-K programs), presence of a kitchen (where meals are prepared) and presence of pipes that could need repairs or replacement.

The results of all the schools are coming in on a rolling basis, and the majority have had levels under the EPA's action level of 15 parts per billion (ppb). At Nettelhorst samples were tested from 28 sites and the water sampled from two fountains were above the action level of 15 ppb. The first fountain on the second floor read at 17.4 ppb. The second fountain on the first floor read at 22.9, 19.5, and 19.1 ppb. The water from the fountains have been turned off and remediation plans are being created.

Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why only two of the samples at Nettelhorst returned with elevated results – the issue is not system-wide, but is specific to the fixtures or pipes for those fountains and will be addressed through the remediation plan. The full results of every school's water samples can be found online at [cps.edu/leadtesting](http://cps.edu/leadtesting).

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit [www.cdc.gov/lead](http://www.cdc.gov/lead).

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

Forrest Claypool  
CEO, Chicago Public Schools

Dr. Julie Morita  
Commissioner, Chicago Department of Public Health





22 de julio de 2016

Estimadas familias de la escuela Nettelhorst,

Ante los eventos nacionales que han incrementado la atención en el tema de la calidad del agua, la Alcaldía de Chicago anunció varias medidas adicionales de precaución que serán agregadas al protocolo de prueba del agua de la ciudad, continuando con el cumplimiento de las regulaciones estatales y federales, que exceden los estándares industriales.

Como parte de este anuncio, las Escuelas Públicas de Chicago (CPS) comenzaron a medir los niveles de plomo en el agua de todas las escuelas del distrito. Nuestra principal prioridad es la salud y seguridad de todos nuestros estudiantes y personal, y estas pruebas fueron iniciadas solamente para extremar las precauciones y estar seguros de que el agua es segura. Las escuelas son examinadas con base a un criterio de prioridad que incluye la antigüedad del edificio, edad de los estudiantes (con prioridad para las escuelas con programas preescolares), presencia de una cocina (donde se preparan alimentos) y la presencia de cañerías que necesiten reparación o reemplazo.

Los resultados de todas las escuelas se están conociendo, y la mayoría ha registrado niveles por debajo del nivel de acción de la EPA, que es de 15 partículas por billón (ppb). En Nettelhorst se tomaron muestras de 28 lugares y el agua de dos bebederos tenía rastros de plomo por encima del nivel de acción de 15 ppb. Un bebedero del segundo piso registró 17.4 ppb. Un segundo bebedero del primer piso registró 22.9, 19.5 y 19.1 ppb. El suministro de agua de los bebederos fue interrumpido y se están creando planes para remediar la situación.

El agua de Chicago no tiene plomo cuando sale de la planta de tratamiento. Sin embargo, el plomo se puede encontrar en algunas cañerías internas y materiales, y el plomo encontrado en el agua potable es provocado usualmente por la corrosión de las cañerías. Esto explica por qué solamente dos de las muestras de Nettelhorst registraron niveles elevados, un tema que no es general sino específico de las cañerías de los bebederos, que será abordado en el plan de remediación. Los resultados completos del agua de cada escuela se pueden ver en línea en [cps.edu/leadtesting](https://cps.edu/leadtesting).

Los lineamientos federales indican que los niños menores de seis años son los que corren mayores riesgos con la exposición al plomo, algo que puede ocurrir de varias fuentes, incluyendo pintura, tierra y algunos productos de consumo. Si están preocupados por la posible exposición de su hijo al plomo, el Departamento de Salud Pública de la ciudad de Chicago (CDPH) recomienda visitar a su pediatra o a alguno de los centros de salud listados en el material adjunto, para una prueba. Además, la línea directa del CDPH puede responder cualquier pregunta que tengan, o ayudarlos a decidir si su niño debe ser examinado; por preguntas o más información, llame por favor al 312-747-5323. Por información adicional sobre el plomo y los niños, visite [www.cdc.gov/lead](https://www.cdc.gov/lead).

La seguridad de sus hijos es nuestra principal prioridad, y hacemos todo lo que está en nuestro poder para resolver esta situación de una manera rápida y rigurosa. Continuaremos informándoles sobre este proceso.

Atentamente,

Forrest Claypool  
CEO, Escuelas Públicas de Chicago

Dra. Julie Morita, Comisionada  
Departamento de Salud Pública de Chicago





## School Lead Water Testing - Data Collection Form

School Name

Nettelhorst

Sample ID #	Sample Location	Sample Collection Time & Date	Test Result (ppb)	Test Results
1-SE-CS01-01	Teachers Lounge	6/16/16 6:10 AM	None Detected	ND
1-SE-CS01-02	Teachers Lounge	6/16/16 6:10 AM	None Detected	ND
1-SE-CS01-03	Teachers Lounge	6/16/16 6:10 AM	None Detected	ND
1-SE-CS01-04	Teachers Lounge	6/16/16 6:10 AM	None Detected	ND
1-SE-CS01-05	Teachers Lounge	6/16/16 6:10 AM	None Detected	ND
1-N-CS01-06	Kitchen	6/16/16 6:20 AM	None Detected	ND
1-N-CS01-07	Kitchen	6/16/16 6:20 AM	None Detected	ND
1-N-CS01-08	Kitchen	6/16/16 6:20 AM	None Detected	ND
1-N-CS01-09	Kitchen	6/16/16 6:20 AM	None Detected	ND
1-N-CS01-10	Kitchen	6/16/16 6:20 AM	None Detected	ND
1-N-CS02-11	Kitchen	6/16/16 6:25 AM	None Detected	ND
1-N-CS02-12	Kitchen	6/16/16 6:25 AM	None Detected	ND
1-N-CS02-13	Kitchen	6/16/16 6:25 AM	None Detected	ND
1-N-CS02-14	Kitchen	6/16/16 6:25 AM	None Detected	ND
1-N-CS02-15	Kitchen	6/16/16 6:25 AM	None Detected	ND
4-NE-WC01-16	Gym	6/16/16 6:35 AM	None Detected	ND
4-NE-WC01-17	Gym	6/16/16 6:35 AM	None Detected	ND
4-NE-WC01-18	Gym	6/16/16 6:35 AM	None Detected	ND
4-NE-WC01-19	Gym	6/16/16 6:35 AM	None Detected	ND
4-NE-WC01-20	Gym	6/16/16 6:35 AM	None Detected	ND
4-NE-WC02-21	Gym	6/16/16 6:40 AM	None Detected	ND
4-NE-WC02-22	Gym	6/16/16 6:40 AM	None Detected	ND
4-NE-WC02-23	Gym	6/16/16 6:40 AM	None Detected	ND
4-NE-WC02-24	Gym	6/16/16 6:40 AM	None Detected	ND
4-NE-WC02-25	Gym	6/16/16 6:40 AM	None Detected	ND
3-N-F01-26	Outside 313	6/16/16 6:45 AM	None Detected	ND
3-N-F01-27	Outside 313	6/16/16 6:45 AM	None Detected	ND
3-N-F01-28	Outside 313	6/16/16 6:45 AM	None Detected	ND
3-N-F01-29	Outside 313	6/16/16 6:45 AM	None Detected	ND
3-N-F01-30	Outside 313	6/16/16 6:45 AM	None Detected	ND
3-N-F02-31	Outside 314	6/16/16 6:50 AM	None Detected	ND
3-N-F02-32	Outside 314	6/16/16 6:50 AM	None Detected	ND
3-N-F02-33	Outside 314	6/16/16 6:50 AM	None Detected	ND
3-N-F02-34	Outside 314	6/16/16 6:50 AM	None Detected	ND
3-N-F02-35	Outside 314	6/16/16 6:50 AM	None Detected	ND
3-W-F01-36	Inside Faculty Washroom	6/16/16 6:55 AM	None Detected	ND
3-W-F01-37	Inside Faculty Washroom	6/16/16 6:55 AM	None Detected	ND
3-W-F01-38	Inside Faculty Washroom	6/16/16 6:55 AM	None Detected	ND
3-W-F01-39	Inside Faculty Washroom	6/16/16 6:55 AM	None Detected	ND
3-W-F01-40	Inside Faculty Washroom	6/16/16 6:55 AM	None Detected	ND
3-S-F01-41	Outside 317	6/16/16 7:00 AM	None Detected	ND
3-S-F01-42	Outside 317	6/16/16 7:00 AM	None Detected	ND
3-S-F01-43	Outside 317	6/16/16 7:00 AM	None Detected	ND
3-S-F01-44	Outside 317	6/16/16 7:00 AM	None Detected	ND
3-S-F01-45	Outside 317	6/16/16 7:00 AM	None Detected	ND
3-S-F02-46	Outside 317	6/16/16 7:03 AM	None Detected	ND

Sample ID #	Sample Location	Sample Collection Time & Date	Test Result (ppb)	Test Results
3-S-F02-47	Outside 317	6/16/16 7:03 AM	None Detected	ND
3-S-F02-48	Outside 317	6/16/16 7:03 AM	None Detected	ND
3-S-F02-49	Outside 317	6/16/16 7:03 AM	None Detected	ND
3-S-F02-50	Outside 317	6/16/16 7:03 AM	None Detected	ND
2-SE-F01-51	Outside 202	6/16/16 7:08 AM	None Detected	ND
2-SE-F01-52	Outside 202	6/16/16 7:08 AM	None Detected	ND
2-SE-F01-53	Outside 202	6/16/16 7:08 AM	None Detected	ND
2-SE-F01-54	Outside 202	6/16/16 7:08 AM	None Detected	ND
2-SE-F01-55	Outside 202	6/16/16 7:08 AM	None Detected	ND
2-SE-F02-56	Outside 202	6/16/16 7:00 AM	None Detected	ND
2-SE-F02-57	Outside 202	6/16/16 7:00 AM	None Detected	ND
2-SE-F02-58	Outside 202	6/16/16 7:00 AM	None Detected	ND
2-SE-F02-59	Outside 202	6/16/16 7:00 AM	None Detected	ND
2-SE-F02-60	Outside 202	6/16/16 7:00 AM	None Detected	ND
2-SE-CS01-61	Pre-K 202	6/16/16 7:12 AM	None Detected	ND
2-SE-CS01-62	Pre-K 202	6/16/16 7:12 AM	None Detected	ND
2-SE-CS01-63	Pre-K 202	6/16/16 7:12 AM	None Detected	ND
2-SE-CS01-64	Pre-K 202	6/16/16 7:12 AM	None Detected	ND
2-SE-CS01-65	Pre-K 202	6/16/16 7:12 AM	None Detected	ND
2-SE-CS02-66	Pre-K 202	6/16/16 7:15 AM	None Detected	ND
2-SE-CS02-67	Pre-K 202	6/16/16 7:15 AM	None Detected	ND
2-SE-CS02-68	Pre-K 202	6/16/16 7:15 AM	None Detected	ND
2-SE-CS02-69	Pre-K 202	6/16/16 7:15 AM	None Detected	ND
2-SE-CS02-70	Pre-K 202	6/16/16 7:15 AM	None Detected	ND
2-SE-F01-71	Pre-K 201	6/16/16 7:20 AM	None Detected	ND
2-SE-F01-72	Pre-K 201	6/16/16 7:20 AM	None Detected	ND
2-SE-F01-73	Pre-K 201	6/16/16 7:20 AM	None Detected	ND
2-SE-F01-74	Pre-K 201	6/16/16 7:20 AM	None Detected	ND
2-SE-F01-75	Pre-K 201	6/16/16 7:20 AM	None Detected	ND
2-N-F01-76	Outside 213	6/16/16 7:25 AM	None Detected	ND
2-N-F01-77	Outside 213	6/16/16 7:25 AM	None Detected	ND
2-N-F01-78	Outside 213	6/16/16 7:25 AM	None Detected	ND
2-N-F01-79	Outside 213	6/16/16 7:25 AM	None Detected	ND
2-N-F01-80	Outside 213	6/16/16 7:25 AM	None Detected	ND
2-N-F02-81	Outside 213	6/16/16 7:30 AM	None Detected	ND
2-N-F02-82	Outside 213	6/16/16 7:30 AM	None Detected	ND
2-N-F02-83	Outside 213	6/16/16 7:30 AM	None Detected	ND
2-N-F02-84	Outside 213	6/16/16 7:30 AM	None Detected	ND
2-N-F02-85	Outside 213	6/16/16 7:30 AM	None Detected	ND
2-W-F01-86	Outside 214	6/16/16 7:32 AM	None Detected	ND
2-W-F01-87	Outside 214	6/16/16 7:32 AM	None Detected	ND
2-W-F01-88	Outside 214	6/16/16 7:32 AM	None Detected	ND
2-W-F01-89	Outside 214	6/16/16 7:32 AM	None Detected	ND
2-W-F01-90	Outside 214	6/16/16 7:32 AM	None Detected	ND
2-W-F02-91	Outside 214	6/16/16 7:35 AM	None Detected	ND
2-W-F02-92	Outside 214	6/16/16 7:35 AM	None Detected	ND
2-W-F02-93	Outside 214	6/16/16 7:35 AM	None Detected	ND
2-W-F02-94	Outside 214	6/16/16 7:35 AM	None Detected	ND
2-W-F02-95	Outside 214	6/16/16 7:35 AM	None Detected	ND
2-E-F02-96	Bathroom of Main Office	6/16/16 7:40 AM	8.5	BA

Sample ID #	Sample Location	Sample Collection Time & Date	Test Result (ppb)	Test Results
2-E-F02-97	Bathroom of Main Office	6/16/16 7:40 AM	17.4	AA
2-E-F02-98	Bathroom of Main Office	6/16/16 7:40 AM	None Detected	ND
2-E-F02-99	Bathroom of Main Office	6/16/16 7:40 AM	None Detected	ND
2-E-F02-100	Bathroom of Main Office	6/16/16 7:40 AM	None Detected	ND
1-SE-WC01-101	Pre-K 101	6/16/16 7:50 AM	None Detected	ND
1-SE-WC01-102	Pre-K 101	6/16/16 7:50 AM	None Detected	ND
1-SE-WC01-103	Pre-K 101	6/16/16 7:50 AM	None Detected	ND
1-SE-WC01-104	Pre-K 101	6/16/16 7:50 AM	None Detected	ND
1-SE-WC01-105	Pre-K 101	6/16/16 7:50 AM	None Detected	ND
1-SE-CS01-106	Pre-K 101 Bathroom	6/16/16 7:52 AM	None Detected	ND
1-SE-CS01-107	Pre-K 101 Bathroom	6/16/16 7:52 AM	None Detected	ND
1-SE-CS01-108	Pre-K 101 Bathroom	6/16/16 7:52 AM	None Detected	ND
1-SE-CS01-109	Pre-K 101 Bathroom	6/16/16 7:52 AM	None Detected	ND
1-SE-CS01-110	Pre-K 101 Bathroom	6/16/16 7:52 AM	None Detected	ND
1-SE-CS02-111	Pre-K 101	6/16/16 7:55 AM	None Detected	ND
1-SE-CS02-112	Pre-K 101	6/16/16 7:55 AM	None Detected	ND
1-SE-CS02-113	Pre-K 101	6/16/16 7:55 AM	None Detected	ND
1-SE-CS02-114	Pre-K 101	6/16/16 7:55 AM	None Detected	ND
1-SE-CS02-115	Pre-K 101	6/16/16 7:55 AM	None Detected	ND
1-C-F01-116	Outside Kitchen 113	6/16/16 8:00 AM	None Detected	ND
1-C-F01-117	Outside Kitchen 113	6/16/16 8:00 AM	None Detected	ND
1-C-F01-118	Outside Kitchen 113	6/16/16 8:00 AM	None Detected	ND
1-C-F01-119	Outside Kitchen 113	6/16/16 8:00 AM	None Detected	ND
1-C-F01-120	Outside Kitchen 113	6/16/16 8:00 AM	None Detected	ND
1-W-F01-121	Outside Room 114	6/16/16 8:03 AM	None Detected	ND
1-W-F01-122	Outside Room 114	6/16/16 8:03 AM	None Detected	ND
1-W-F01-123	Outside Room 114	6/16/16 8:03 AM	None Detected	ND
1-W-F01-124	Outside Room 114	6/16/16 8:03 AM	None Detected	ND
1-W-F01-125	Outside Room 114	6/16/16 8:03 AM	None Detected	ND
1-W-F02-126	Outside Room 114	6/16/16 8:06 AM	None Detected	ND
1-W-F02-127	Outside Room 114	6/16/16 8:06 AM	None Detected	ND
1-W-F02-128	Outside Room 114	6/16/16 8:06 AM	None Detected	ND
1-W-F02-129	Outside Room 114	6/16/16 8:06 AM	None Detected	ND
1-W-F02-130	Outside Room 114	6/16/16 8:06 AM	None Detected	ND
1-S-F01-131	Outside Room 117	6/16/16 8:10 AM	19.1	AA
1-S-F01-132	Outside Room 117	6/16/16 8:10 AM	22.9	AA
1-S-F01-133	Outside Room 117	6/16/16 8:10 AM	19.5	AA
1-S-F01-134	Outside Room 117	6/16/16 8:10 AM	14.8	BA
1-S-F01-135	Outside Room 117	6/16/16 8:10 AM	9.37	BA
1-S-F02-136	Outside Room 117	6/16/16 8:12 AM	12.8	BA
1-S-F02-137	Outside Room 117	6/16/16 8:12 AM	6.23	BA
1-S-F02-138	Outside Room 117	6/16/16 8:12 AM	None Detected	ND
1-S-F02-139	Outside Room 117	6/16/16 8:12 AM	None Detected	ND
1-S-F02-140	Outside Room 117	6/16/16 8:12 AM	None Detected	ND

EPA ACTION LEVEL FOR LEAD IS 15 ppb or 15 µg/L

**SPREADSHEET LEGEND**

ND-Not Detected at the Reporting Limit

BA-Below EPA Action Level of 15 ppb

AA-Above EPA Action Level