



School Lead Water Testing Summary

School Short Name **Saucedo**
Address 2850 W. 24th Blvd.
Facility ID 51275
CPS Team Member P. Sales, C. Edgerley
MEC Team Member Evan Christian

Length of time water remained in pipes before sampled [Approx 9 hours](#)
Water last used (Time and date) [Approx 10 PM 5/9/16](#)
Date of test [5/11/2016](#)
Report based on lab results dated [5/18/2016](#)

Sample ID #	Sample Location	Sample Collection Time & Date	Test Results (ppb)	ppb Level
51275-2-K-CS-01	Kitchen	6:04 AM 5/11/16	ND	-
51275-2-NE-F-02	Hallway by Room 228	6:08 AM 5/11/16	ND	-
51275-1-NE-1-03	Room 162	6:10 AM 5/11/16	ND	-
51275-1-NE-F-04	Room 130	6:12 AM 5/11/16	ND	-
51275-1-NE-F-05	Hallway by Room 130	6:14 AM 5/11/16	ND	-
51275-1-C-F-06	Gymnasium	6:16 AM 5/11/16	ND	-
51275-1-CW-F-07	Hallway by Auditorium	6:21 AM 5/11/16	ND	-
51275-1-C-F-08	Pool	6:23 AM 5/11/16	ND	-
51275-1-NW-F-09	Hallway by Room 129	6:25 AM 5/11/16	ND	-
51275-2-SE-F-10	Hallway by Room 201	6:28 AM 5/11/16	ND	-
51275-3-NW-F-11	Hallway by Room 329	6:31 AM 5/11/16	ND	-
51275-3-SW-F-12	Hallway by Room 317	6:33 AM 5/11/16	ND	-
51275-3-SE-F-13	Hallway by Room 316	6:35 AM 5/11/16	ND	-
51275-2-NW-F-14	Telpochcalli-Hallway by Room 252	6:39 AM 5/11/16	ND	-
51275-1-NW-F-15	Telpochcalli-Hallway by Room 164	6:41 AM 5/11/16	ND	-

EPA ACTION LEVEL FOR LEAD IS 15 ppb or 15 µg/L

SPREADSHEET LEGEND

ND-Not Detected at the Reporting Limit
 BA-Below EPA Action Level of 15 ppb
 AA-Above EPA Action Level

Chicago Public Schools - Department of Facility Operations