



School Lead Water Testing - Data Collection Form

School Short Name    McKay

Sample ID #	Sample Location	Sample Collection Time & Date	Test Result (ppb)	Test Results
52507-2-N-F01-001	Main- 2nd Fl North Outside Room 206, Fountain	6/2/16 5:00 AM	<0.120	ND
52507-2-N-F01-002	Main- 2nd Fl North Outside Room 206, Fountain	6/2/16 5:00 AM	<0.120	ND
52507-2-N-F01-003	Main- 2nd Fl North Outside Room 206, Fountain	6/2/16 5:00 AM	<0.120	ND
52507-2-N-F01-004	Main- 2nd Fl North Outside Room 206, Fountain	6/2/16 5:00 AM	<0.120	ND
52507-2-N-F01-005	Main- 2nd Fl North Outside Room 206, Fountain	6/2/16 5:00 AM	<0.120	ND
52507-1-N-F02-001	Main- 1st Fl North Outside Boiler Rm, Fountain	6/2/16 5:00 AM	0.544	BA
52507-1-N-F02-002	Main- 1st Fl North Outside Boiler Rm, Fountain	6/2/16 5:00 AM	0.559	BA
52507-1-N-F02-004	Main- 1st Fl North Outside Boiler Rm, Fountain	6/2/16 5:00 AM	0.749	BA
52507-1-N-F02-004	Main- 1st Fl North Outside Boiler Rm, Fountain	6/2/16 5:00 AM	0.695	BA
52507-1-N-F02-005	Main- 1st Fl North Outside Boiler Rm, Fountain	6/2/16 5:00 AM	1.63	BA
52507-1-S-F03-001	Main- 1st Fl South Outside Boy Bathroom, Fountain	6/2/16 5:00 AM	0.439	BA
52507-1-S-F03-002	Main- 1st Fl South Outside Boy Bathroom, Fountain	6/2/16 5:00 AM	0.415	BA
52507-1-S-F03-003	Main- 1st Fl South Outside Boy Bathroom, Fountain	6/2/16 5:00 AM	0.297	BA
52507-1-S-F03-004	Main- 1st Fl South Outside Boy Bathroom, Fountain	6/2/16 5:00 AM	0.459	BA
52507-1-S-F03-005	Main- 1st Fl South Outside Boy Bathroom, Fountain	6/2/16 5:00 AM	0.663	BA
52507-3-N-F02-001	Addition- 3rd floor Fountain Outside Room 320	6/2/16 5:00 AM	<0.120	ND
52507-3-N-F02-002	Addition- 3rd floor Fountain Outside Room 320	6/2/16 5:00 AM	<0.120	ND
52507-3-N-F02-003	Addition- 3rd floor Fountain Outside Room 320	6/2/16 5:00 AM	<0.120	ND
52507-3-N-F02-004	Addition- 3rd floor Fountain Outside Room 320	6/2/16 5:00 AM	<0.120	ND
52507-3-N-F02-005	Addition- 3rd floor Fountain Outside Room 320	6/2/16 5:00 AM	<0.120	ND
52507-2-N-F01-001	Addition- 2nd floor Fountain 1 Outside Girls Bathroom	6/2/16 5:00 AM	1.24	BA
52507-2-N-F01-002	Addition- 2nd floor Fountain 1 Outside Girls Bathroom	6/2/16 5:00 AM	0.67	BA
52507-2-N-F01-003	Addition- 2nd floor Fountain 1 Outside Girls Bathroom	6/2/16 5:00 AM	0.673	BA
52507-2-N-F01-004	Addition- 2nd floor Fountain 1 Outside Girls Bathroom	6/2/16 5:00 AM	1.07	BA
52507-2-N-F01-005	Addition- 2nd floor Fountain 1 Outside Girls Bathroom	6/2/16 5:00 AM	1.87	BA
52507-2-N-F02-001	Addition- 2nd floor Fountain 2 Outside Girls Bathroom	6/2/16 5:00 AM	<0.120	ND
52507-2-N-F02-002	Addition- 2nd floor Fountain 2 Outside Girls Bathroom	6/2/16 5:00 AM	<0.120	ND
52507-2-N-F02-003	Addition- 2nd floor Fountain 2 Outside Girls Bathroom	6/2/16 5:00 AM	0.131	BA
52507-2-N-F02-004	Addition- 2nd floor Fountain 2 Outside Girls Bathroom	6/2/16 5:00 AM	<0.120	ND
52507-2-N-F02-005	Addition- 2nd floor Fountain 2 Outside Girls Bathroom	6/2/16 5:00 AM	<0.120	ND
52507-1-N-S01-001	Addition- 1st floor Kitchen North Wall Sink	6/2/16 5:00 AM	<0.120	ND
52507-1-N-S01-002	Addition- 1st floor Kitchen North Wall Sink	6/2/16 5:00 AM	<0.120	ND
52507-1-N-S01-003	Addition- 1st floor Kitchen North Wall Sink	6/2/16 5:00 AM	<0.120	ND
52507-1-N-S01-004	Addition- 1st floor Kitchen North Wall Sink	6/2/16 5:00 AM	<0.120	ND
52507-1-N-S01-005	Addition- 1st floor Kitchen North Wall Sink	6/2/16 5:00 AM	0.219	BA
52507-1-N-S02-001	Addition- 1st floor Kitchen East Wall Sink 2	6/2/16 5:00 AM	0.305	BA
52507-1-N-S02-002	Addition- 1st floor Kitchen East Wall Sink 2	6/2/16 5:00 AM	0.301	BA
52507-1-N-S02-003	Addition- 1st floor Kitchen East Wall Sink 2	6/2/16 5:00 AM	<0.120	ND
52507-1-N-S02-004	Addition- 1st floor Kitchen East Wall Sink 2	6/2/16 5:00 AM	0.21	BA
52507-1-N-S02-005	Addition- 1st floor Kitchen East Wall Sink 2	6/2/16 5:00 AM	<0.120	ND
52507-1-N-S03-001	Addition- 1st floor Kitchen South Wall Sink 3	6/2/16 5:00 AM	<0.120	ND
52507-1-N-S03-002	Addition- 1st floor Kitchen South Wall Sink 3	6/2/16 5:00 AM	0.821	BA
52507-1-N-S03-003	Addition- 1st floor Kitchen South Wall Sink 3	6/2/16 5:00 AM	0.146	BA
52507-1-N-S03-004	Addition- 1st floor Kitchen South Wall Sink 3	6/2/16 5:00 AM	0.272	BA
52507-1-N-S03-005	Addition- 1st floor Kitchen South Wall Sink 3	6/2/16 5:00 AM	<0.120	ND
52507-1-N-F04-001	Addition- 1st floor N, Fountain 1 Outside Girls Bathroom	6/2/16 5:00 AM	<0.120	ND
52507-1-N-F04-002	Addition- 1st floor N, Fountain 1 Outside Girls Bathroom	6/2/16 5:00 AM	<0.120	ND
52507-1-N-F04-003	Addition- 1st floor N, Fountain 1 Outside Girls Bathroom	6/2/16 5:00 AM	<0.120	ND
52507-1-N-F04-004	Addition- 1st floor N, Fountain 1 Outside Girls Bathroom	6/2/16 5:00 AM	<0.120	ND
52507-1-N-F04-005	Addition- 1st floor N, Fountain 1 Outside Girls Bathroom	6/2/16 5:00 AM	<0.120	ND
52507-1-N-F05-001	Addition- 1st floor N, Fountain 2 Outside Girls Bathroom	6/2/16 5:00 AM	<0.120	ND
52507-1-N-F05-002	Addition- 1st floor N, Fountain 2 Outside Girls Bathroom	6/2/16 5:00 AM	<0.120	ND
52507-1-N-F05-003	Addition- 1st floor N, Fountain 2 Outside Girls Bathroom	6/2/16 5:00 AM	<0.120	ND
52507-1-N-F05-004	Addition- 1st floor N, Fountain 2 Outside Girls Bathroom	6/2/16 5:00 AM	0.133	BA
52507-1-N-F05-005	Addition- 1st floor N, Fountain 2 Outside Girls Bathroom	6/2/16 5:00 AM	<0.120	ND
52507-1-E-S07-001	Addition- Inside Room 128 Sink 1	6/2/16 5:00 AM	<0.120	ND
52507-1-E-S07-002	Addition- Inside Room 128 Sink 1	6/2/16 5:00 AM	<0.120	ND
52507-1-E-S07-003	Addition- Inside Room 128 Sink 1	6/2/16 5:00 AM	<0.120	ND
52507-1-E-S07-004	Addition- Inside Room 128 Sink 1	6/2/16 5:00 AM	<0.120	ND
52507-1-E-S07-005	Addition- Inside Room 128 Sink 1	6/2/16 5:00 AM	<0.120	ND
52507-1-E-S08-001	Addition- Inside Room 128 Sink 2	6/2/16 5:00 AM	<0.120	ND
52507-1-E-S08-002	Addition- Inside Room 128 Sink 2	6/2/16 5:00 AM	<0.120	ND
52507-1-E-S08-003	Addition- Inside Room 128 Sink 2	6/2/16 5:00 AM	<0.120	ND
52507-1-E-S08-004	Addition- Inside Room 128 Sink 2	6/2/16 5:00 AM	<0.120	ND
52507-1-E-S08-005	Addition- Inside Room 128 Sink 2	6/2/16 5:00 AM	<0.120	ND
52507-1-W-S10-001	Addition- Inside Room 129 Sink 1	6/2/16 5:00 AM	0.384	BA
52507-1-W-S10-002	Addition- Inside Room 129 Sink 1	6/2/16 5:00 AM	<0.120	ND
52507-1-W-S10-003	Addition- Inside Room 129 Sink 1	6/2/16 5:00 AM	<0.120	ND
52507-1-W-S10-004	Addition- Inside Room 129 Sink 1	6/2/16 5:00 AM	<0.120	ND
52507-1-W-S10-005	Addition- Inside Room 129 Sink 1	6/2/16 5:00 AM	<0.120	ND
52507-1-W-S11-001	Addition- Inside Room 129 Sink 2	6/2/16 5:00 AM	<0.120	ND
52507-1-W-S11-002	Addition- Inside Room 129 Sink 2	6/2/16 5:00 AM	<0.120	ND
52507-1-W-S11-003	Addition- Inside Room 129 Sink 2	6/2/16 5:00 AM	<0.120	ND
52507-1-W-S11-004	Addition- Inside Room 129 Sink 2	6/2/16 5:00 AM	<0.120	ND
52507-1-W-S11-005	Addition- Inside Room 129 Sink 2	6/2/16 5:00 AM	0.262	BA
52507-1-E-S13-001	Addition- Inside Room 130 Sink	6/2/16 5:00 AM	<0.120	ND
52507-1-E-S13-002	Addition- Inside Room 130 Sink	6/2/16 5:00 AM	<0.120	ND
52507-1-E-S13-003	Addition- Inside Room 130 Sink	6/2/16 5:00 AM	0.12	BA
52507-1-E-S13-004	Addition- Inside Room 130 Sink	6/2/16 5:00 AM	<0.120	ND
52507-1-E-S13-005	Addition- Inside Room 130 Sink	6/2/16 5:00 AM	<0.120	ND
52507-1-W-S17-001	Addition- Inside Room 131 Sink	6/2/16 5:00 AM	0.12	BA
52507-1-W-S17-002	Addition- Inside Room 131 Sink	6/2/16 5:00 AM	0.185	BA
52507-1-W-S17-003	Addition- Inside Room 131 Sink	6/2/16 5:00 AM	<0.120	ND
52507-1-W-S17-004	Addition- Inside Room 131 Sink	6/2/16 5:00 AM	<0.120	ND
52507-1-W-S17-005	Addition- Inside Room 131 Sink	6/2/16 5:00 AM	0.2	BA
52507-1-E-S19-001	Addition- Inside Room 132 Sink 1	6/2/16 5:00 AM	0.245	BA
52507-1-E-S19-002	Addition- Inside Room 132 Sink 1	6/2/16 5:00 AM	<0.120	ND
52507-1-E-S19-003	Addition- Inside Room 132 Sink 1	6/2/16 5:00 AM	<0.120	ND
52507-1-E-S19-004	Addition- Inside Room 132 Sink 1	6/2/16 5:00 AM	<0.120	ND
52507-1-E-S19-005	Addition- Inside Room 132 Sink 1	6/2/16 5:00 AM	<0.120	ND
52507-1-E-S20-001	Addition- Inside Room 132 Sink 2	6/2/16 5:00 AM	<0.120	ND
52507-1-E-S20-002	Addition- Inside Room 132 Sink 2	6/2/16 5:00 AM	<0.120	ND
52507-1-E-S20-003	Addition- Inside Room 132 Sink 2	6/2/16 5:00 AM	<0.120	ND
52507-1-E-S20-004	Addition- Inside Room 132 Sink 2	6/2/16 5:00 AM	<0.120	ND
52507-1-E-S20-005	Addition- Inside Room 132 Sink 2	6/2/16 5:00 AM	<0.120	ND
52507-1-W-F21-001	Addition- Inside Room 133 Fountain	6/2/16 5:00 AM	<0.120	ND
52507-1-W-F21-002	Addition- Inside Room 133 Fountain	6/2/16 5:00 AM	<0.120	ND
52507-1-W-F21-003	Addition- Inside Room 133 Fountain	6/2/16 5:00 AM	<0.120	ND
52507-1-W-F21-004	Addition- Inside Room 133 Fountain	6/2/16 5:00 AM	0.177	BA
52507-1-W-F21-005	Addition- Inside Room 133 Fountain	6/2/16 5:00 AM	<0.120	ND
52507-1-W-S22-001	Addition- Inside Room 133 Sink 1	6/2/16 5:00 AM	<0.120	ND
52507-1-W-S22-002	Addition- Inside Room 133 Sink 1	6/2/16 5:00 AM	<0.120	ND
52507-1-W-S22-003	Addition- Inside Room 133 Sink 1	6/2/16 5:00 AM	<0.120	ND
52507-1-W-S22-004	Addition- Inside Room 133 Sink 1	6/2/16 5:00 AM	<0.120	ND
52507-1-W-S22-005	Addition- Inside Room 133 Sink 1	6/2/16 5:00 AM	0.129	BA
52507-1-W-S23-001	Addition- Inside Room 133 Sink 2	6/2/16 5:00 AM	0.139	BA
52507-1-W-S23-002	Addition- Inside Room 133 Sink 2	6/2/16 5:00 AM	<0.120	ND
52507-1-W-S23-003	Addition- Inside Room 133 Sink 2	6/2/16 5:00 AM	0.132	BA
52507-1-W-S23-004	Addition- Inside Room 133 Sink 2	6/2/16 5:00 AM	0.151	BA
52507-1-W-S23-005	Addition- Inside Room 133 Sink 2	6/2/16 5:00 AM	<0.120	ND

EPA ACTION LEVEL FOR LEAD IS 15 ppb or 15 µg/L

SPREADSHEET LEGEND

ND-Not Detected at the Reporting Limit  
BA-Below EPA Action Level of 15 ppb  
AA-Above EPA Action Level