



November 10, 2016

Dear CPS family,

In light of national events that have brought increased attention to the issue of water quality, the City of Chicago announced several additional precautionary measures that will be added to the City's water testing protocol, continuing the City's track record of complying with current state and federal regulations as well as exceeding industry standards.

As part of this announcement, Chicago Public Schools (CPS) began testing the water for levels of lead from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe. Schools are being tested based on a priority criteria that includes the age of the school, age of the students (with priority given to schools with pre-K programs), presence of a kitchen (where meals are prepared) and presence of pipes that could need repairs or replacement.

The results of all the schools are coming in on a rolling basis, and the majority have had levels under the EPA's action level of 15 parts per billion (ppb). We wanted to let you know that no lead was found above the action level in your child's school. The full results of your school's water samples can be found online at cps.edu/leadtesting.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician for testing. Additionally, CDPH's lead hotline can address any health related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

Forrest Claypool
CEO, Chicago Public Schools

Dr. Julie Morita
Commissioner, Chicago Department of Public Health





Estimadas familias de CPS,

Ante los eventos nacionales que han incrementado la atención en el tema de la calidad del agua, la Alcaldía de Chicago anunció varias medidas adicionales de precaución que serán agregadas al protocolo de prueba del agua de la ciudad, continuando con el cumplimiento de las regulaciones estatales y federales, que exceden los estándares industriales.

Como parte de este anuncio, las Escuelas Públicas de Chicago (CPS) comenzaron a medir los niveles de plomo en el agua de todas las escuelas del distrito. Nuestra principal prioridad es la salud y seguridad de todos nuestros estudiantes y personal, y estas pruebas fueron iniciadas solamente para extremar las precauciones y estar seguros de que el agua es segura. Las escuelas son examinadas con base a un criterio de prioridad que incluye la antigüedad del edificio, edad de los estudiantes (con prioridad para las escuelas con programas preescolares), presencia de una cocina (donde se preparan alimentos) y la presencia de cañerías que necesiten reparación o reemplazo.

Los resultados de todas las escuelas se están conociendo, y la mayoría ha registrado niveles por debajo del nivel de acción de la EPA, que es de 15 partículas por billón (ppb). Queremos hacerles saber que no se encontraron rastros de plomo por encima del nivel de acción en la escuela de su niño. Los resultados completos de las pruebas en su escuela se pueden ver en línea en cps.edu/leadtesting.

Los lineamientos federales indican que los niños menores de seis años son los que corren mayores riesgos con la exposición al plomo, algo que puede ocurrir de varias fuentes, incluyendo pintura, tierra y algunos productos de consumo. Si están preocupados por la posible exposición de su hijo al plomo, el Departamento de Salud Pública de la ciudad de Chicago (CDPH) recomienda visitar a su pediatra o a alguno de los centros de salud listados en el material adjunto, para una prueba. Además, la línea directa del CDPH puede responder cualquier pregunta que tengan, o ayudarlos a decidir si su niño debe ser examinado; por preguntas o más información, llame por favor al 312-747-5323. Por información adicional sobre el plomo y los niños, visite www.cdc.gov/lead.

La seguridad de sus hijos es nuestra principal prioridad, y hacemos todo lo que está en nuestro poder para resolver esta situación de una manera rápida y rigurosa. Continuaremos informándoles sobre este proceso.

Atentamente,

Forrest Claypool
CEO, Escuelas Públicas de Chicago

Dra. Julie Morita, Comisionada
Departamento de Salud Pública de Chicago





School Lead Water Testing - Data Collection Form

School Short Name **Kenwood HS**

Date of test 10/25/16

School Short Name	Facility ID	Sample ID #	Sample Location	Sample Collection Time & Date	Test Result (ppb)	Test Results
Kenwood HS	51586	51586-2-KIT-KS01-01	Kitchen right sink on NE Wall	6:30AM	0.82	BA
Kenwood HS	51586	51586-2-KIT-KS01-02	Kitchen right sink on NE Wall	6:30AM	0.4	BA
Kenwood HS	51586	51586-2-KIT-KS01-03	Kitchen right sink on NE Wall	6:30AM	<0.50	BA
Kenwood HS	51586	51586-2-KIT-KS01-04	Kitchen right sink on NE Wall	6:30AM	<0.50	BA
Kenwood HS	51586	51586-2-KIT-KS01-05	Kitchen right sink on NE Wall	6:30AM	0.27	BA
Kenwood HS	51586	51586-2-KIT-KS02-01	Kitchen Middle Sink on NE Wall	6:35AM	3.5	BA
Kenwood HS	51586	51586-2-KIT-KS02-02	Kitchen Middle Sink on NE Wall	6:35AM	1.4	BA
Kenwood HS	51586	51586-2-KIT-KS02-03	Kitchen Middle Sink on NE Wall	6:35AM	0.81	BA
Kenwood HS	51586	51586-2-KIT-KS02-04	Kitchen Middle Sink on NE Wall	6:35AM	0.59	BA
Kenwood HS	51586	51586-2-KIT-KS02-05	Kitchen Middle Sink on NE Wall	6:35AM	0.48	BA
Kenwood HS	51586	51586-2-KIT-KS03-01	Kitchen Left Sink on NE Wall	6:40AM	0.38	BA
Kenwood HS	51586	51586-2-KIT-KS03-02	Kitchen Left Sink on NE Wall	6:40AM	0.24	BA
Kenwood HS	51586	51586-2-KIT-KS03-03	Kitchen Left Sink on NE Wall	6:40AM	0.2	BA
Kenwood HS	51586	51586-2-KIT-KS03-04	Kitchen Left Sink on NE Wall	6:40AM	<0.50	BA
Kenwood HS	51586	51586-2-KIT-KS03-05	Kitchen Left Sink on NE Wall	6:40AM	<0.50	BA
Kenwood HS	51586	51586-2-KIT-KS04-01	Kitchen Center Sink	6:45AM	4.5	BA
Kenwood HS	51586	51586-2-KIT-KS04-02	Kitchen Center Sink	6:45AM	2.1	BA
Kenwood HS	51586	51586-2-KIT-KS04-03	Kitchen Center Sink	6:45AM	0.79	BA
Kenwood HS	51586	51586-2-KIT-KS04-04	Kitchen Center Sink	6:45AM	0.3	BA
Kenwood HS	51586	51586-2-KIT-KS04-05	Kitchen Center Sink	6:45AM	0.66	BA
Kenwood HS	51586	51586-2-KIT-KS05-01	Kitchen Left Sink on SE Wall	6:50AM	0.32	BA
Kenwood HS	51586	51586-2-KIT-KS05-02	Kitchen Left Sink on SE Wall	6:50AM	0.34	BA
Kenwood HS	51586	51586-2-KIT-KS05-03	Kitchen Left Sink on SE Wall	6:50AM	0.33	BA
Kenwood HS	51586	51586-2-KIT-KS05-04	Kitchen Left Sink on SE Wall	6:50AM	0.33	BA
Kenwood HS	51586	51586-2-KIT-KS05-05	Kitchen Left Sink on SE Wall	6:50AM	0.39	BA
Kenwood HS	51586	51586-2-KIT-KS06-01	Kitchen Middle sink on SE Wall	6:55AM	0.31	BA

Kenwood HS	51586	51586-2-KIT-KS06-02	Kitchen Middle sink on SE Wall	6:55AM	0.37	BA
Kenwood HS	51586	51586-2-KIT-KS06-03	Kitchen Middle sink on SE Wall	6:55AM	0.36	BA
Kenwood HS	51586	51586-2-KIT-KS06-04	Kitchen Middle sink on SE Wall	6:55AM	0.39	BA
Kenwood HS	51586	51586-2-KIT-KS06-05	Kitchen Middle sink on SE Wall	6:55AM	0.38	BA
Kenwood HS	51586	51586-2-KIT-KS07-01	Kitchen Right Sink on SE Wall	7:00AM	0.68	BA
Kenwood HS	51586	51586-2-KIT-KS07-02	Kitchen Right Sink on SE Wall	7:00AM	0.56	BA
Kenwood HS	51586	51586-2-KIT-KS07-03	Kitchen Right Sink on SE Wall	7:00AM	0.51	BA
Kenwood HS	51586	51586-2-KIT-KS07-04	Kitchen Right Sink on SE Wall	7:00AM	0.54	BA
Kenwood HS	51586	51586-2-KIT-KS07-05	Kitchen Right Sink on SE Wall	7:00AM	0.62	BA
Kenwood HS	51586	51586-2-HAL-F01-01	Outside Kitchen Left Fountain	7:05AM	<0.50	BA
Kenwood HS	51586	51586-2-HAL-F01-02	Outside Kitchen Left Fountain	7:05AM	<0.50	BA
Kenwood HS	51586	51586-2-HAL-F01-03	Outside Kitchen Left Fountain	7:05AM	<0.50	BA
Kenwood HS	51586	51586-2-HAL-F01-04	Outside Kitchen Left Fountain	7:05AM	<0.50	BA
Kenwood HS	51586	51586-2-HAL-F01-05	Outside Kitchen Left Fountain	7:05AM	<0.50	BA
Kenwood HS	51586	51586-2-HAL-F02-01	Outside Kitchen Right Fountain	7:10AM	0.21	BA
Kenwood HS	51586	51586-2-HAL-F02-02	Outside Kitchen Right Fountain	7:10AM	<0.50	BA
Kenwood HS	51586	51586-2-HAL-F02-03	Outside Kitchen Right Fountain	7:10AM	<0.50	BA
Kenwood HS	51586	51586-2-HAL-F02-04	Outside Kitchen Right Fountain	7:10AM	<0.50	BA
Kenwood HS	51586	51586-2-HAL-F02-05	Outside Kitchen Right Fountain	7:10AM	<0.50	BA
Kenwood HS	51586	51586-2-HAL-F04-01	Outside RM 250 Right Fountain	7:15AM	1.2	BA
Kenwood HS	51586	51586-2-HAL-F04-02	Outside RM 250 Right Fountain	7:15AM	1.2	BA
Kenwood HS	51586	51586-2-HAL-F04-03	Outside RM 250 Right Fountain	7:15AM	1.3	BA
Kenwood HS	51586	51586-2-HAL-F04-04	Outside RM 250 Right Fountain	7:15AM	1.3	BA
Kenwood HS	51586	51586-2-HAL-F04-05	Outside RM 250 Right Fountain	7:15AM	1.4	BA
Kenwood HS	51586	51586-2-214-S01-01	RM 214 World Language Office	7:20AM	0.8	BA
Kenwood HS	51586	51586-2-214-S01-02	RM 214 World Language Office	7:20AM	0.77	BA
Kenwood HS	51586	51586-2-214-S01-03	RM 214 World Language Office	7:20AM	2.8	BA
Kenwood HS	51586	51586-2-214-S01-04	RM 214 World Language Office	7:20AM	0.7	BA
Kenwood HS	51586	51586-2-214-S01-05	RM 214 World Language Office	7:20AM	0.71	BA
Kenwood HS	51586	51586-2-HAL-F05-01	Outside RM 247 Left Fountain	7:25AM	0.34	BA
Kenwood HS	51586	51586-2-HAL-F05-02	Outside RM 247 Left Fountain	7:25AM	0.49	BA
Kenwood HS	51586	51586-2-HAL-F05-03	Outside RM 247 Left Fountain	7:25AM	0.37	BA
Kenwood HS	51586	51586-2-HAL-F05-04	Outside RM 247 Left Fountain	7:25AM	0.41	BA
Kenwood HS	51586	51586-2-HAL-F05-05	Outside RM 247 Left Fountain	7:25AM	0.33	BA

Kenwood HS	51586	51586-2-HAL-F06-01	Outside Rm 247 Right Fountain	7:30AM	0.54	BA
Kenwood HS	51586	51586-2-HAL-F06-02	Outside Rm 247 Right Fountain	7:30AM	0.4	BA
Kenwood HS	51586	51586-2-HAL-F06-03	Outside Rm 247 Right Fountain	7:30AM	0.31	BA
Kenwood HS	51586	51586-2-HAL-F06-04	Outside Rm 247 Right Fountain	7:30AM	0.3	BA
Kenwood HS	51586	51586-2-HAL-F06-05	Outside Rm 247 Right Fountain	7:30AM	0.29	BA
Kenwood HS	51586	51586-3-HAL-F01-01	Outside RM 345 Left Fountain	7:35AM	1.6	BA
Kenwood HS	51586	51586-3-HAL-F01-02	Outside RM 345 Left Fountain	7:35AM	1.1	BA
Kenwood HS	51586	51586-3-HAL-F01-03	Outside RM 345 Left Fountain	7:35AM	0.88	BA
Kenwood HS	51586	51586-3-HAL-F01-04	Outside RM 345 Left Fountain	7:35AM	0.94	BA
Kenwood HS	51586	51586-3-HAL-F01-05	Outside RM 345 Left Fountain	7:35AM	0.83	BA
Kenwood HS	51586	51586-3-HAL-F02-01	Outside RM 345 Right Fountain	7:40AM	1.1	BA
Kenwood HS	51586	51586-3-HAL-F02-02	Outside RM 345 Right Fountain	7:40AM	0.95	BA
Kenwood HS	51586	51586-3-HAL-F02-03	Outside RM 345 Right Fountain	7:40AM	0.86	BA
Kenwood HS	51586	51586-3-HAL-F02-04	Outside RM 345 Right Fountain	7:40AM	0.8	BA
Kenwood HS	51586	51586-3-HAL-F02-05	Outside RM 345 Right Fountain	7:40AM	0.79	BA
Kenwood HS	51586	51586-2-212-S01-01	RM 212 Sink	7:45AM	0.55	BA
Kenwood HS	51586	51586-2-212-S01-02	RM 212 Sink	7:45AM	1.5	BA
Kenwood HS	51586	51586-2-212-S01-03	RM 212 Sink	7:45AM	0.67	BA
Kenwood HS	51586	51586-2-212-S01-04	RM 212 Sink	7:45AM	0.68	BA
Kenwood HS	51586	51586-2-212-S01-05	RM 212 Sink	7:45AM	0.67	BA
Kenwood HS	51586	51586-1-HAL-F01-01	Outside RM 165 Janitors Closet Left	7:50AM	3.6	BA
Kenwood HS	51586	51586-1-HAL-F01-02	Outside RM 165 Janitors Closet Left	7:50AM	2	BA
Kenwood HS	51586	51586-1-HAL-F01-03	Outside RM 165 Janitors Closet Left	7:50AM	1.7	BA
Kenwood HS	51586	51586-1-HAL-F01-04	Outside RM 165 Janitors Closet Left	7:50AM	1.6	BA
Kenwood HS	51586	51586-1-HAL-F01-05	Outside RM 165 Janitors Closet Left	7:50AM	1.5	BA
Kenwood HS	51586	51586-1-HAL-F02-01	Outside RM 165 Right Fountain	7:55AM	8	BA
Kenwood HS	51586	51586-1-HAL-F02-02	Outside RM 165 Right Fountain	7:55AM	11	BA
Kenwood HS	51586	51586-1-HAL-F02-03	Outside RM 165 Right Fountain	7:55AM	6.1	BA
Kenwood HS	51586	51586-1-HAL-F02-04	Outside RM 165 Right Fountain	7:55AM	4	BA
Kenwood HS	51586	51586-1-HAL-F02-05	Outside RM 165 Right Fountain	7:55AM	3.3	BA
Kenwood HS	51586	51586-1-HAL-F03-01	Outside RM 161 Left Fountain	8:00AM	0.82	BA
Kenwood HS	51586	51586-1-HAL-F03-02	Outside RM 161 Left Fountain	8:00AM	0.6	BA
Kenwood HS	51586	51586-1-HAL-F03-03	Outside RM 161 Left Fountain	8:00AM	0.35	BA
Kenwood HS	51586	51586-1-HAL-F03-04	Outside RM 161 Left Fountain	8:00AM	0.26	BA

Kenwood HS	51586	51586-1-HAL-F03-05	Outside RM 161 Left Fountain	8:00AM	0.25	BA
Kenwood HS	51586	51586-1-HAL-F04-01	Outside RM 161 Right Fountain	8:05AM	0.72	BA
Kenwood HS	51586	51586-1-HAL-F04-02	Outside RM 161 Right Fountain	8:05AM	0.32	BA
Kenwood HS	51586	51586-1-HAL-F04-03	Outside RM 161 Right Fountain	8:05AM	0.3	BA
Kenwood HS	51586	51586-1-HAL-F04-04	Outside RM 161 Right Fountain	8:05AM	0.31	BA
Kenwood HS	51586	51586-1-HAL-F04-05	Outside RM 161 Right Fountain	8:05AM	0.52	BA
Kenwood HS	51586	51586-1-113-S01-01	RM 113 English Office	8:10AM	0.95	BA
Kenwood HS	51586	51586-1-113-S01-02	RM 113 English Office	8:10AM	1.5	BA
Kenwood HS	51586	51586-1-113-S01-03	RM 113 English Office	8:10AM	1.3	BA
Kenwood HS	51586	51586-1-113-S01-04	RM 113 English Office	8:10AM	1.3	BA
Kenwood HS	51586	51586-1-113-S01-05	RM 113 English Office	8:10AM	1.4	BA
Kenwood HS	51586	51586-1-MOF-S01-01	Main Office Kitchenette 101C	8:15AM	0.91	BA
Kenwood HS	51586	51586-1-MOF-S01-02	Main Office Kitchenette 101C	8:15AM	4.3	BA
Kenwood HS	51586	51586-1-MOF-S01-03	Main Office Kitchenette 101C	8:15AM	1.2	BA
Kenwood HS	51586	51586-1-MOF-S01-04	Main Office Kitchenette 101C	8:15AM	1.1	BA
Kenwood HS	51586	51586-1-MOF-S01-05	Main Office Kitchenette 101C	8:15AM	1	BA
Kenwood HS	51586	51586-1-106C-S01-01	Library	8:20AM	1.5	BA
Kenwood HS	51586	51586-1-106C-S01-02	Library	8:20AM	1.1	BA
Kenwood HS	51586	51586-1-106C-S01-03	Library	8:20AM	1	BA
Kenwood HS	51586	51586-1-106C-S01-04	Library	8:20AM	1.1	BA
Kenwood HS	51586	51586-1-106C-S01-05	Library	8:20AM	1	BA
Kenwood HS	51586	51586-2-224-S01-01	Rm 224	9:05AM	1.3	BA
Kenwood HS	51586	51586-2-224-S01-02	Rm 224	9:05AM	1.3	BA
Kenwood HS	51586	51586-2-224-S01-03	Rm 224	9:05AM	1.3	BA
Kenwood HS	51586	51586-2-224-S01-04	Rm 224	9:05AM	1.2	BA
Kenwood HS	51586	51586-2-224-S01-05	Rm 224	9:05AM	1.2	BA
Kenwood HS Arts	52369	52369-1-HAL-F01-01	Outside Band RM Left	8:25AM	1.9	BA
Kenwood HS Arts	52369	52369-1-HAL-F01-02	Outside Band RM Left	8:25AM	1.1	BA
Kenwood HS Arts	52369	52369-1-HAL-F01-03	Outside Band RM Left	8:25AM	0.88	BA
Kenwood HS Arts	52369	52369-1-HAL-F01-04	Outside Band RM Left	8:25AM	0.68	BA
Kenwood HS Arts	52369	52369-1-HAL-F01-05	Outside Band RM Left	8:25AM	1	BA
Kenwood HS Arts	52369	52369-1-HAL-F02-01	Outside Band RM Right	8:30AM	0.37	BA
Kenwood HS Arts	52369	52369-1-HAL-F02-02	Outside Band RM Right	8:30AM	<0.50	BA
Kenwood HS Arts	52369	52369-1-HAL-F02-03	Outside Band RM Right	8:30AM	<0.50	BA

Kenwood HS Arts	52369	52369-1-HAL-F02-04	Outside Band RM Right	8:30AM	<0.50	BA
Kenwood HS Arts	52369	52369-1-HAL-F02-05	Outside Band RM Right	8:30AM	<0.50	BA
Kenwood HS Arts	52369	52369-1-HAL-F03-01	Outside Little Theater Left	8:35AM	0.19	BA
Kenwood HS Arts	52369	52369-1-HAL-F03-02	Outside Little Theater Left	8:35AM	<0.50	BA
Kenwood HS Arts	52369	52369-1-HAL-F03-03	Outside Little Theater Left	8:35AM	0.16	BA
Kenwood HS Arts	52369	52369-1-HAL-F03-04	Outside Little Theater Left	8:35AM	<0.50	BA
Kenwood HS Arts	52369	52369-1-HAL-F03-05	Outside Little Theater Left	8:35AM	<0.50	BA
Kenwood HS Arts	52369	52369-1-HAL-F04-01	Outside Little Theater Right	8:40AM	11	BA
Kenwood HS Arts	52369	52369-1-HAL-F04-02	Outside Little Theater Right	8:40AM	2.6	BA
Kenwood HS Arts	52369	52369-1-HAL-F04-03	Outside Little Theater Right	8:40AM	2.2	BA
Kenwood HS Arts	52369	52369-1-HAL-F04-04	Outside Little Theater Right	8:40AM	1.1	BA
Kenwood HS Arts	52369	52369-1-HAL-F04-05	Outside Little Theater Right	8:40AM	0.91	BA
Kenwood HS Arts	52369	52369-2-HAL-F01-01	Outside RM 233 Art Rm Left	8:45AM	0.61	BA
Kenwood HS Arts	52369	52369-2-HAL-F01-02	Outside RM 233 Art Rm Left	8:45AM	0.35	BA
Kenwood HS Arts	52369	52369-2-HAL-F01-03	Outside RM 233 Art Rm Left	8:45AM	0.33	BA
Kenwood HS Arts	52369	52369-2-HAL-F01-04	Outside RM 233 Art Rm Left	8:45AM	0.27	BA
Kenwood HS Arts	52369	52369-2-HAL-F01-05	Outside RM 233 Art Rm Left	8:45AM	0.31	BA
Kenwood HS Arts	52369	52369-2-HAL-F02-01	Outside RM 233Art RM Right	8:50AM	1	BA
Kenwood HS Arts	52369	52369-2-HAL-F02-02	Outside RM 233Art RM Right	8:50AM	0.91	BA
Kenwood HS Arts	52369	52369-2-HAL-F02-03	Outside RM 233Art RM Right	8:50AM	1	BA
Kenwood HS Arts	52369	52369-2-HAL-F02-04	Outside RM 233Art RM Right	8:50AM	0.47	BA
Kenwood HS Arts	52369	52369-2-HAL-F02-05	Outside RM 233Art RM Right	8:50AM	0.26	BA
Kenwood HS Arts	52369	52369-2-HAL-F03-01	Outside Classroom 226 Left	8:55AM	1.1	BA
Kenwood HS Arts	52369	52369-2-HAL-F03-02	Outside Classroom 226 Left	8:55AM	1.3	BA
Kenwood HS Arts	52369	52369-2-HAL-F03-03	Outside Classroom 226 Left	8:55AM	0.97	BA
Kenwood HS Arts	52369	52369-2-HAL-F03-04	Outside Classroom 226 Left	8:55AM	0.62	BA
Kenwood HS Arts	52369	52369-2-HAL-F03-05	Outside Classroom 226 Left	8:55AM	0.39	BA
Kenwood HS Arts	52369	52369-2-HAL-F04-01	Outside RM 226 Right Fountain	9:00AM	2.4	BA
Kenwood HS Arts	52369	52369-2-HAL-F04-02	Outside RM 226 Right Fountain	9:00AM	1.7	BA
Kenwood HS Arts	52369	52369-2-HAL-F04-03	Outside RM 226 Right Fountain	9:00AM	1.2	BA
Kenwood HS Arts	52369	52369-2-HAL-F04-04	Outside RM 226 Right Fountain	9:00AM	1.2	BA
Kenwood HS Arts	52369	52369-2-HAL-F04-05	Outside RM 226 Right Fountain	9:00AM	3.6	BA
Kenwood HS Athletic	52370	52370-1-185-F01-01	Girls Locker Room Left Fountain	8:00AM	0.3	BA
Kenwood HS Athletic	52370	52370-1-185-F01-02	Girls Locker Room Left Fountain	8:00AM	0.25	BA

Kenwood HS Athletic	52370	52370-1-185-F01-03	Girls Locker Room Left Fountain	8:00AM	0.25	BA
Kenwood HS Athletic	52370	52370-1-185-F01-04	Girls Locker Room Left Fountain	8:00AM	0.19	BA
Kenwood HS Athletic	52370	52370-1-185-F01-05	Girls Locker Room Left Fountain	8:00AM	<0.50	BA
Kenwood HS Athletic	52370	52370-1-185-F02-01	Girls Locker Room Right Fountain	8:00AM	0.17	BA
Kenwood HS Athletic	52370	52370-1-185-F02-02	Girls Locker Room Right Fountain	8:00AM	<0.50	BA
Kenwood HS Athletic	52370	52370-1-185-F02-03	Girls Locker Room Right Fountain	8:00AM	0.33	BA
Kenwood HS Athletic	52370	52370-1-185-F02-04	Girls Locker Room Right Fountain	8:00AM	0.29	BA
Kenwood HS Athletic	52370	52370-1-185-F02-05	Girls Locker Room Right Fountain	8:00AM	0.25	BA
Kenwood HS Athletic	52370	52370-1-HAL-F01-01	East Hall outside Gym Left	8:05AM	0.61	BA
Kenwood HS Athletic	52370	52370-1-HAL-F01-02	East Hall outside Gym Left	8:05AM	0.61	BA
Kenwood HS Athletic	52370	52370-1-HAL-F01-03	East Hall outside Gym Left	8:05AM	0.23	BA
Kenwood HS Athletic	52370	52370-1-HAL-F01-04	East Hall outside Gym Left	8:05AM	0.23	BA
Kenwood HS Athletic	52370	52370-1-HAL-F01-05	East Hall outside Gym Left	8:05AM	0.2	BA
Kenwood HS Athletic	52370	52370-1-HAL-F02-01	East Hall outside Gym Right	8:05AM	0.6	BA
Kenwood HS Athletic	52370	52370-1-HAL-F02-02	East Hall outside Gym Right	8:05AM	0.25	BA
Kenwood HS Athletic	52370	52370-1-HAL-F02-03	East Hall outside Gym Right	8:05AM	0.23	BA
Kenwood HS Athletic	52370	52370-1-HAL-F02-04	East Hall outside Gym Right	8:05AM	0.21	BA
Kenwood HS Athletic	52370	52370-1-HAL-F02-05	East Hall outside Gym Right	8:05AM	0.27	BA
Kenwood HS Athletic	52370	52370-1-179-F01-01	Mens Locker RM	8:10AM	2.3	BA
Kenwood HS Athletic	52370	52370-1-179-F01-02	Mens Locker RM	8:10AM	1.8	BA
Kenwood HS Athletic	52370	52370-1-179-F01-03	Mens Locker RM	8:10AM	1.4	BA
Kenwood HS Athletic	52370	52370-1-179-F01-04	Mens Locker RM	8:10AM	1.3	BA
Kenwood HS Athletic	52370	52370-1-179-F01-05	Mens Locker RM	8:10AM	0.95	BA
Kenwood HS Athletic	52370	52370-1-HAL-F03-01	West Hall Left Fountain	8:15AM	0.68	BA
Kenwood HS Athletic	52370	52370-1-HAL-F03-02	West Hall Left Fountain	8:15AM	0.35	BA
Kenwood HS Athletic	52370	52370-1-HAL-F03-03	West Hall Left Fountain	8:15AM	0.3	BA
Kenwood HS Athletic	52370	52370-1-HAL-F03-04	West Hall Left Fountain	8:15AM	0.27	BA
Kenwood HS Athletic	52370	52370-1-HAL-F03-05	West Hall Left Fountain	8:15AM	0.3	BA
Kenwood HS Athletic	52370	52370-1-HAL-F04-01	West Hall Right Fountain	8:15AM	1.2	BA
Kenwood HS Athletic	52370	52370-1-HAL-F04-02	West Hall Right Fountain	8:15AM	0.64	BA
Kenwood HS Athletic	52370	52370-1-HAL-F04-03	West Hall Right Fountain	8:15AM	0.75	BA
Kenwood HS Athletic	52370	52370-1-HAL-F04-04	West Hall Right Fountain	8:15AM	0.7	BA
Kenwood HS Athletic	52370	52370-1-HAL-F04-05	West Hall Right Fountain	8:15AM	0.84	BA
Kenwood HS Athletic	52370	52370-1-101-F01-01	Pool	8:20AM	5	BA

Kenwood HS Athletic	52370	52370-1-101-F01-02	Pool	8:20AM	3.1	BA
Kenwood HS Athletic	52370	52370-1-101-F01-03	Pool	8:20AM	3.4	BA
Kenwood HS Athletic	52370	52370-1-101-F01-04	Pool	8:20AM	3.7	BA
Kenwood HS Athletic	52370	52370-1-101-F01-05	Pool	8:20AM	3.8	BA
Kenwood HS Athletic	52370	52370-2-HAL-F01-01	East Hall Left Fountain	8:30AM	0.51	BA
Kenwood HS Athletic	52370	52370-2-HAL-F01-02	East Hall Left Fountain	8:30AM	0.26	BA
Kenwood HS Athletic	52370	52370-2-HAL-F01-03	East Hall Left Fountain	8:30AM	<0.50	BA
Kenwood HS Athletic	52370	52370-2-HAL-F01-04	East Hall Left Fountain	8:30AM	<0.50	BA
Kenwood HS Athletic	52370	52370-2-HAL-F01-05	East Hall Left Fountain	8:30AM	<0.50	BA
Kenwood HS Athletic	52370	52370-2-HAL-F02-01	East Hall Right Fountain	8:35AM	1.8	BA
Kenwood HS Athletic	52370	52370-2-HAL-F02-02	East Hall Right Fountain	8:35AM	0.71	BA
Kenwood HS Athletic	52370	52370-2-HAL-F02-03	East Hall Right Fountain	8:35AM	0.61	BA
Kenwood HS Athletic	52370	52370-2-HAL-F02-04	East Hall Right Fountain	8:35AM	0.57	BA
Kenwood HS Athletic	52370	52370-2-HAL-F02-05	East Hall Right Fountain	8:35AM	0.41	BA
Kenwood HS Athletic	52370	52370-2-HAL-F03-01	West Hall Left Fountain	8:40AM	0.99	BA
Kenwood HS Athletic	52370	52370-2-HAL-F03-02	West Hall Left Fountain	8:40AM	0.75	BA
Kenwood HS Athletic	52370	52370-2-HAL-F03-03	West Hall Left Fountain	8:40AM	0.58	BA
Kenwood HS Athletic	52370	52370-2-HAL-F03-04	West Hall Left Fountain	8:40AM	0.63	BA
Kenwood HS Athletic	52370	52370-2-HAL-F03-05	West Hall Left Fountain	8:40AM	0.5	BA
Kenwood HS Branch @ Canter	51404	51404-1-KIT-KS01-01	Kitchen Left Sink	6:40AM	1.1	BA
Kenwood HS Branch @ Canter	51404	51404-1-KIT-KS01-02	Kitchen Left Sink	6:40AM	0.24	BA
Kenwood HS Branch @ Canter	51404	51404-1-KIT-KS01-03	Kitchen Left Sink	6:40AM	0.24	BA
Kenwood HS Branch @ Canter	51404	51404-1-KIT-KS01-04	Kitchen Left Sink	6:40AM	0.42	BA
Kenwood HS Branch @ Canter	51404	51404-1-KIT-KS01-05	Kitchen Left Sink	6:40AM	0.55	BA
Kenwood HS Branch @ Canter	51404	51404-1-KIT-KS02-01	Kitchen Right Sink	6:40AM	0.16	BA
Kenwood HS Branch @ Canter	51404	51404-1-KIT-KS02-02	Kitchen Right Sink	6:40AM	0.84	BA
Kenwood HS Branch @ Canter	51404	51404-1-KIT-KS02-03	Kitchen Right Sink	6:40AM	<0.50	BA
Kenwood HS Branch @ Canter	51404	51404-1-KIT-KS02-04	Kitchen Right Sink	6:40AM	<0.50	BA
Kenwood HS Branch @ Canter	51404	51404-1-KIT-KS02-05	Kitchen Right Sink	6:40AM	<0.50	BA
Kenwood HS Branch @ Canter	51404	51404-1-HAL-F01-01	West End of Hall Middle Fountain	6:45AM	0.19	BA
Kenwood HS Branch @ Canter	51404	51404-1-HAL-F01-02	West End of Hall Middle Fountain	6:45AM	<0.50	BA
Kenwood HS Branch @ Canter	51404	51404-1-HAL-F01-03	West End of Hall Middle Fountain	6:45AM	<0.50	BA
Kenwood HS Branch @ Canter	51404	51404-1-HAL-F01-04	West End of Hall Middle Fountain	6:45AM	<0.50	BA
Kenwood HS Branch @ Canter	51404	51404-1-HAL-F01-05	West End of Hall Middle Fountain	6:45AM	<0.50	BA

Kenwood HS Branch @ Canter	51404	51404-1-HAL-F02-01	West End of Hall Right Fountain	6:45AM	<0.50	BA
Kenwood HS Branch @ Canter	51404	51404-1-HAL-F02-02	West End of Hall Right Fountain	6:45AM	<0.50	BA
Kenwood HS Branch @ Canter	51404	51404-1-HAL-F02-03	West End of Hall Right Fountain	6:45AM	<0.50	BA
Kenwood HS Branch @ Canter	51404	51404-1-HAL-F02-04	West End of Hall Right Fountain	6:45AM	<0.50	BA
Kenwood HS Branch @ Canter	51404	51404-1-HAL-F02-05	West End of Hall Right Fountain	6:45AM	<0.50	BA
Kenwood HS Branch @ Canter	51404	51404-1-HAL-F03-01	West End of Hall Left Fountain	6:50AM	<0.50	BA
Kenwood HS Branch @ Canter	51404	51404-1-HAL-F03-02	West End of Hall Left Fountain	6:50AM	<0.50	BA
Kenwood HS Branch @ Canter	51404	51404-1-HAL-F03-03	West End of Hall Left Fountain	6:50AM	<0.50	BA
Kenwood HS Branch @ Canter	51404	51404-1-HAL-F03-04	West End of Hall Left Fountain	6:50AM	<0.50	BA
Kenwood HS Branch @ Canter	51404	51404-1-HAL-F03-05	West End of Hall Left Fountain	6:50AM	<0.50	BA
Kenwood HS Branch @ Canter	51404	51404-1-HAL-F04-01	East End Hall Right Fountain	6:55AM	6.2	BA
Kenwood HS Branch @ Canter	51404	51404-1-HAL-F04-02	East End Hall Right Fountain	6:55AM	2.9	BA
Kenwood HS Branch @ Canter	51404	51404-1-HAL-F04-03	East End Hall Right Fountain	6:55AM	3	BA
Kenwood HS Branch @ Canter	51404	51404-1-HAL-F04-04	East End Hall Right Fountain	6:55AM	2.4	BA
Kenwood HS Branch @ Canter	51404	51404-1-HAL-F04-05	East End Hall Right Fountain	6:55AM	1.7	BA
Kenwood HS Branch @ Canter	51404	51404-1-HAL-F05-01	East End Hall 2nd Fountain from Right	6:55AM	2.1	BA
Kenwood HS Branch @ Canter	51404	51404-1-HAL-F05-02	East End Hall 2nd Fountain from Right	6:55AM	0.57	BA
Kenwood HS Branch @ Canter	51404	51404-1-HAL-F05-03	East End Hall 2nd Fountain from Right	6:55AM	0.41	BA
Kenwood HS Branch @ Canter	51404	51404-1-HAL-F05-04	East End Hall 2nd Fountain from Right	6:55AM	0.48	BA
Kenwood HS Branch @ Canter	51404	51404-1-HAL-F05-05	East End Hall 2nd Fountain from Right	6:55AM	0.32	BA
Kenwood HS Branch @ Canter	51404	51404-1-HAL-F06-01	East End Hall 3rd Fountain from Right	7:00AM	4.2	BA
Kenwood HS Branch @ Canter	51404	51404-1-HAL-F06-02	East End Hall 3rd Fountain from Right	7:00AM	0.96	BA
Kenwood HS Branch @ Canter	51404	51404-1-HAL-F06-03	East End Hall 3rd Fountain from Right	7:00AM	0.84	BA
Kenwood HS Branch @ Canter	51404	51404-1-HAL-F06-04	East End Hall 3rd Fountain from Right	7:00AM	0.73	BA
Kenwood HS Branch @ Canter	51404	51404-1-HAL-F06-05	East End Hall 3rd Fountain from Right	7:00AM	0.71	BA
Kenwood HS Branch @ Canter	51404	51404-2-HAL-F01-01	West End of Hall Left Fountain	7:05AM	0.6	BA
Kenwood HS Branch @ Canter	51404	51404-2-HAL-F01-02	West End of Hall Left Fountain	7:05AM	0.63	BA
Kenwood HS Branch @ Canter	51404	51404-2-HAL-F01-03	West End of Hall Left Fountain	7:05AM	0.47	BA
Kenwood HS Branch @ Canter	51404	51404-2-HAL-F01-04	West End of Hall Left Fountain	7:05AM	0.38	BA
Kenwood HS Branch @ Canter	51404	51404-2-HAL-F01-05	West End of Hall Left Fountain	7:05AM	0.33	BA
Kenwood HS Branch @ Canter	51404	51404-2-HAL-F02-01	West End of Hall Middle Fountain	7:10AM	0.29	BA
Kenwood HS Branch @ Canter	51404	51404-2-HAL-F02-02	West End of Hall Middle Fountain	7:10AM	<0.50	BA
Kenwood HS Branch @ Canter	51404	51404-2-HAL-F02-03	West End of Hall Middle Fountain	7:10AM	<0.50	BA
Kenwood HS Branch @ Canter	51404	51404-2-HAL-F02-04	West End of Hall Middle Fountain	7:10AM	0.18	BA

Kenwood HS Branch @ Canter	51404	51404-2-HAL-F02-05	West End of Hall Middle Fountain	7:10AM	0.21	BA
Kenwood HS Branch @ Canter	51404	51404-2-HAL-F03-01	West End of Hall Right Fountain	7:10AM	<0.50	BA
Kenwood HS Branch @ Canter	51404	51404-2-HAL-F03-02	West End of Hall Right Fountain	7:10AM	<0.50	BA
Kenwood HS Branch @ Canter	51404	51404-2-HAL-F03-03	West End of Hall Right Fountain	7:10AM	0.16	BA
Kenwood HS Branch @ Canter	51404	51404-2-HAL-F03-04	West End of Hall Right Fountain	7:10AM	0.27	BA
Kenwood HS Branch @ Canter	51404	51404-2-HAL-F03-05	West End of Hall Right Fountain	7:10AM	<0.50	BA
Kenwood HS Branch @ Canter	51404	51404-2-HAL-F04-01	East End of Hall Right Fountain	7:15AM	48	AA
Kenwood HS Branch @ Canter	51404	51404-2-HAL-F04-02	East End of Hall Right Fountain	7:15AM	31	AA
Kenwood HS Branch @ Canter	51404	51404-2-HAL-F04-03	East End of Hall Right Fountain	7:15AM	33	AA
Kenwood HS Branch @ Canter	51404	51404-2-HAL-F04-04	East End of Hall Right Fountain	7:15AM	29	AA
Kenwood HS Branch @ Canter	51404	51404-2-HAL-F04-05	East End of Hall Right Fountain	7:15AM	28	AA
Kenwood HS Branch @ Canter	51404	51404-2-HAL-F05-01	East End Hall Middle Fountain	7:20AM	7.5	BA
Kenwood HS Branch @ Canter	51404	51404-2-HAL-F05-02	East End Hall Middle Fountain	7:20AM	17	AA
Kenwood HS Branch @ Canter	51404	51404-2-HAL-F05-03	East End Hall Middle Fountain	7:20AM	22	AA
Kenwood HS Branch @ Canter	51404	51404-2-HAL-F05-04	East End Hall Middle Fountain	7:20AM	6.1	BA
Kenwood HS Branch @ Canter	51404	51404-2-HAL-F05-05	East End Hall Middle Fountain	7:20AM	2.5	BA
Kenwood HS Branch @ Canter	51404	51404-3-HAL-F01-01	East End Hall Left Fountain	7:20AM	10	BA
Kenwood HS Branch @ Canter	51404	51404-3-HAL-F01-02	East End Hall Left Fountain	7:20AM	7.7	BA
Kenwood HS Branch @ Canter	51404	51404-3-HAL-F01-03	East End Hall Left Fountain	7:20AM	6.6	BA
Kenwood HS Branch @ Canter	51404	51404-3-HAL-F01-04	East End Hall Left Fountain	7:20AM	6.7	BA
Kenwood HS Branch @ Canter	51404	51404-3-HAL-F01-05	East End Hall Left Fountain	7:20AM	6.3	BA
Kenwood HS Branch @ Canter	51404	51404-3-HAL-F02-01	East End Hall 2nd From Left	7:25AM	7	BA
Kenwood HS Branch @ Canter	51404	51404-3-HAL-F02-02	East End Hall 2nd From Left	7:25AM	3.1	BA
Kenwood HS Branch @ Canter	51404	51404-3-HAL-F02-03	East End Hall 2nd From Left	7:25AM	2.1	BA
Kenwood HS Branch @ Canter	51404	51404-3-HAL-F02-04	East End Hall 2nd From Left	7:25AM	2.1	BA
Kenwood HS Branch @ Canter	51404	51404-3-HAL-F02-05	East End Hall 2nd From Left	7:25AM	1.8	BA
Kenwood HS Branch @ Canter	51404	51404-3-HAL-F03-01	East End Hall 3rd From left	7:25AM	14	BA
Kenwood HS Branch @ Canter	51404	51404-3-HAL-F03-02	East End Hall 3rd From left	7:25AM	4.7	BA
Kenwood HS Branch @ Canter	51404	51404-3-HAL-F03-03	East End Hall 3rd From left	7:25AM	3	BA
Kenwood HS Branch @ Canter	51404	51404-3-HAL-F03-04	East End Hall 3rd From left	7:25AM	2.3	BA
Kenwood HS Branch @ Canter	51404	51404-3-HAL-F03-05	East End Hall 3rd From left	7:25AM	2.1	BA
Kenwood HS Branch @ Canter	51404	51404-3-HAL-F04-01	East End Hall Right Fountain	7:30AM	3.6	BA
Kenwood HS Branch @ Canter	51404	51404-3-HAL-F04-02	East End Hall Right Fountain	7:30AM	1.1	BA
Kenwood HS Branch @ Canter	51404	51404-3-HAL-F04-03	East End Hall Right Fountain	7:30AM	0.74	BA

Kenwood HS Branch @ Canter	51404	51404-3-HAL-F04-04	East End Hall Right Fountain	7:30AM	0.77	BA
Kenwood HS Branch @ Canter	51404	51404-3-HAL-F04-05	East End Hall Right Fountain	7:30AM	0.64	BA
Kenwood HS Branch @ Canter	51404	51404-3-HAL-F05-01	West End of Hall Left Fountain	7:35AM	0.23	BA
Kenwood HS Branch @ Canter	51404	51404-3-HAL-F05-02	West End of Hall Left Fountain	7:35AM	0.81	BA
Kenwood HS Branch @ Canter	51404	51404-3-HAL-F05-03	West End of Hall Left Fountain	7:35AM	0.52	BA
Kenwood HS Branch @ Canter	51404	51404-3-HAL-F05-04	West End of Hall Left Fountain	7:35AM	0.36	BA
Kenwood HS Branch @ Canter	51404	51404-3-HAL-F05-05	West End of Hall Left Fountain	7:35AM	0.43	BA
Kenwood HS Branch @ Canter	51404	51404-3-HAL-F06-01	West End of Hall Middle Fountain	7:40AM	0.6	BA
Kenwood HS Branch @ Canter	51404	51404-3-HAL-F06-02	West End of Hall Middle Fountain	7:40AM	0.27	BA
Kenwood HS Branch @ Canter	51404	51404-3-HAL-F06-03	West End of Hall Middle Fountain	7:40AM	0.17	BA
Kenwood HS Branch @ Canter	51404	51404-3-HAL-F06-04	West End of Hall Middle Fountain	7:40AM	0.19	BA
Kenwood HS Branch @ Canter	51404	51404-3-HAL-F06-05	West End of Hall Middle Fountain	7:40AM	0.27	BA
Kenwood HS Branch @ Canter	51404	51404-3-HAL-F07-01	West End of Hall Right Fountain	7:45AM	0.25	BA
Kenwood HS Branch @ Canter	51404	51404-3-HAL-F07-02	West End of Hall Right Fountain	7:45AM	0.34	BA
Kenwood HS Branch @ Canter	51404	51404-3-HAL-F07-03	West End of Hall Right Fountain	7:45AM	0.57	BA
Kenwood HS Branch @ Canter	51404	51404-3-HAL-F07-04	West End of Hall Right Fountain	7:45AM	0.86	BA
Kenwood HS Branch @ Canter	51404	51404-3-HAL-F07-05	West End of Hall Right Fountain	7:45AM	0.73	BA

EPA ACTION LEVEL FOR LEAD IS 15 ppb or 15 µg/L

SPREADSHEET LEGEND

ND-Not Detected at the Reporting Limit

BA-Below EPA Action Level of 15 ppb

AA-Above EPA Action Level

Chicago Public Schools - Department of Facility Operations