



School Lead Water Testing - Data Collection Form

School Short Name **Reilly**

Length of time water remained in pipes before sampled (hours) 13.00
 Report based on lab results dated 6/9/16
 Date of test 06/08/16
 Water last used (Time and date) Approx 3:30 PM 6/7/16

Sample ID #	Sample Location	Sample Collection Time & Date	Test Result (ppb)	Test Results
53001-1-S-S03-001	Annex Kindergarten Rm 114, Sink	6/8/16 5:00 AM	22.6	AA
53001-1-S-S02-001	Annex kindergarten Rm113, Sink	6/8/16 5:00 AM	148	AA
53001-1-S-S01-001	Annex Kindergarten Rm 112, Sink	6/8/16 5:00 AM	354	AA
53001-1-W-S07-002	Annex, Teachers Lounge, Sink	6/8/16 5:00 AM	16.5	AA
51361-1-W-F03-001	Main, Fountain Next to 103, North	6/8/16 5:00 AM	34.1	AA
51361-1-W-F04-001	Main, Fountain Next to 103, South	6/8/16 5:00 AM	8.54	BA
51361-1-W-F04-002	Main, Fountain Next to 103, South	6/8/16 5:00 AM	3.92	BA
51361-1-W-F04-003	Main, Fountain Next to 103, South	6/8/16 5:00 AM	9.69	BA
51361-1-W-F03-002	Main, Fountain Next to 103, North	6/8/16 5:00 AM	30.5	AA
51361-1-W-F04-005	Main, Fountain Next to 103, South	6/8/16 5:00 AM	6.05	BA
51361-1-E-F01-001	Modular 2 Entry, North Fountain	6/8/16 5:00 AM	6.72	BA
51361-1-E-F01-002	Modular 2 Entry, North Fountain	6/8/16 5:00 AM	3.4	BA
51361-1-E-F01-003	Modular 2 Entry, North Fountain	6/8/16 5:00 AM	3.58	BA
51361-1-E-F01-004	Modular 2 Entry, North Fountain	6/8/16 5:00 AM	4.83	BA
51361-1-E-F01-005	Modular 2 Entry, North Fountain	6/8/16 5:00 AM	4.09	BA
51361-1-E-F02-001	Modular 2 Entry, South Fountain	6/8/16 5:00 AM	7.19	BA
51361-1-E-F02-002	Modular 2 Entry, South Fountain	6/8/16 5:00 AM	4	BA
51361-1-E-F02-003	Modular 2 Entry, South Fountain	6/8/16 5:00 AM	3.04	BA
51361-1-E-F02-004	Modular 2 Entry, South Fountain	6/8/16 5:00 AM	3.71	BA
51361-1-E-F02-005	Modular 2 Entry, South Fountain	6/8/16 5:00 AM	4.2	BA
53865-1-E-F01-001	Modular 1 Entry, North Fountain	6/8/16 5:00 AM	7.44	BA
53865-1-E-F01-002	Modular 1 Entry, North Fountain	6/8/16 5:00 AM	13.4	BA
53865-1-E-F01-003	Modular 1 Entry, North Fountain	6/8/16 5:00 AM	3.75	BA
53865-1-E-F01-004	Modular 1 Entry, North Fountain	6/8/16 5:00 AM	3.09	BA
53865-1-E-F01-005	Modular 1 Entry, North Fountain	6/8/16 5:00 AM	2.69	BA
53865-1-E-F02-001	Modular 1 Entry, South Fountain	6/8/16 5:00 AM	3.92	BA
53865-1-E-F02-002	Modular 1 Entry, South Fountain	6/8/16 5:00 AM	3.2	BA
53865-1-E-F02-003	Modular 1 Entry, South Fountain	6/8/16 5:00 AM	2.34	BA
53865-1-E-F02-004	Modular 1 Entry, South Fountain	6/8/16 5:00 AM	2.14	BA

53865-1-E-F02-005	Modular 1 Entry, South Fountain	6/8/16 5:00 AM	2.09	BA
51361-1-W-F03-003	Main, Fountain Next to 103, North	6/8/16 5:00 AM	22	AA
53001-1-S-S01-002	Annex Kindergraden Rm 112, Sink	6/8/16 5:00 AM	12.4	BA
53001-1-S-S01-003	Annex Kindergraden Rm 112, Sink	6/8/16 5:00 AM	5.48	BA
53001-1-S-S01-004	Annex Kindergraden Rm 112, Sink	6/8/16 5:00 AM	13.5	BA
53001-1-S-S01-005	Annex Kindergraden Rm 112, Sink	6/8/16 5:00 AM	11.5	BA
51361-1-W-F03-004	Main, Fountain Next to 103, North	6/8/16 5:00 AM	46	AA
53001-1-S-S02-002	Annex kindergarden Rm113, Sink	6/8/16 5:00 AM	6.65	BA
53001-1-S-S02-003	Annex kindergarden Rm113, Sink	6/8/16 5:00 AM	1.57	BA
53001-1-S-S02-004	Annex kindergarden Rm113, Sink	6/8/16 5:00 AM	1.53	BA
53001-1-S-S02-005	Annex kindergarden Rm113, Sink	6/8/16 5:00 AM	0.918	BA
51361-1-W-F03-005	Main, Fountain Next to 103, North	6/8/16 5:00 AM	340	AA
53001-1-S-S03-002	Annex Kindergarden Rm 114, Sink	6/8/16 5:00 AM	10.6	BA
53001-1-S-S03-003	Annex Kindergarden Rm 114, Sink	6/8/16 5:00 AM	6.16	BA
53001-1-S-S03-004	Annex Kindergarden Rm 114, Sink	6/8/16 5:00 AM	0.96	BA
53001-1-S-S03-005	Annex Kindergarden Rm 114, Sink	6/8/16 5:00 AM	9.72	BA