



June 27, 2016

Dear CPS family,

In light of national events that have brought increased attention to the issue of water quality, the City of Chicago announced several additional precautionary measures that will be added to the City's water testing protocol, continuing the City's track record of complying with current state and federal regulations as well as exceeding industry standards.

As part of this announcement, Chicago Public Schools (CPS) began testing the water for levels of lead from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe. Schools are being tested based on a priority criteria that includes the age of the school, age of the students (with priority given to schools with pre-K programs), presence of a kitchen (where meals are prepared) and presence of pipes that could need repairs or replacement.

The results of all the schools are coming in on a rolling basis, and the majority have had levels under the EPA's action level of 15 parts per billion (ppb). We wanted to let you know that no lead was found above the action level in your child's school. The full results of your school's water samples can be found online at [cps.edu/leadtesting](http://cps.edu/leadtesting).

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician for testing. Additionally, CDPH's lead hotline can address any health related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit [www.cdc.gov/lead](http://www.cdc.gov/lead).

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

Forrest Claypool  
CEO, Chicago Public Schools

Dr. Julie Morita  
Commissioner, Chicago Department of Public Health





27 de junio de 2016

Estimadas familias de CPS,

Ante los eventos nacionales que han incrementado la atención en el tema de la calidad del agua, la Alcaldía de Chicago anunció varias medidas adicionales de precaución que serán agregadas al protocolo de prueba del agua de la ciudad, continuando con el cumplimiento de las regulaciones estatales y federales, que exceden los estándares industriales.

Como parte de este anuncio, las Escuelas Públicas de Chicago (CPS) comenzaron a medir los niveles de plomo en el agua de todas las escuelas del distrito. Nuestra principal prioridad es la salud y seguridad de todos nuestros estudiantes y personal, y estas pruebas fueron iniciadas solamente para extremar las precauciones y estar seguros de que el agua es segura. Las escuelas son examinadas con base a un criterio de prioridad que incluye la antigüedad del edificio, edad de los estudiantes (con prioridad para las escuelas con programas preescolares), presencia de una cocina (donde se preparan alimentos) y la presencia de cañerías que necesiten reparación o reemplazo.

Los resultados de todas las escuelas se están conociendo, y la mayoría ha registrado niveles por debajo del nivel de acción de la EPA, que es de 15 partículas por billón (ppb). Queremos hacerles saber que no se encontraron rastros de plomo por encima del nivel de acción en la escuela de su niño. Los resultados completos de las pruebas en su escuela se pueden ver en línea en [cps.edu/leadtesting](http://cps.edu/leadtesting).

Los lineamientos federales indican que los niños menores de seis años son los que corren mayores riesgos con la exposición al plomo, algo que puede ocurrir de varias fuentes, incluyendo pintura, tierra y algunos productos de consumo. Si están preocupados por la posible exposición de su hijo al plomo, el Departamento de Salud Pública de la ciudad de Chicago (CDPH) recomienda visitar a su pediatra o a alguno de los centros de salud listados en el material adjunto, para una prueba. Además, la línea directa del CDPH puede responder cualquier pregunta que tengan, o ayudarlos a decidir si su niño debe ser examinado; por preguntas o más información, llame por favor al 312-747-5323. Por información adicional sobre el plomo y los niños, visite [www.cdc.gov/lead](http://www.cdc.gov/lead).

La seguridad de sus hijos es nuestra principal prioridad, y hacemos todo lo que está en nuestro poder para resolver esta situación de una manera rápida y rigurosa. Continuaremos informándoles sobre este proceso.

Atentamente,

Forrest Claypool  
CEO, Escuelas Públicas de Chicago

Dra. Julie Morita, Comisionada  
Departamento de Salud Pública de Chicago





## School Lead Water Testing - Data Collection Form

School Short Name **Suder**

Sample ID #	Sample Location	Sample Collection Time & Date	Test Result (ppb)	Test Results
52294-1-W-S01-001	Main- Inside Room 102, Sink	6/3/16 5:00 AM	1.09	BA
52294-1-W-S01-002	Main- Inside Room 102, Sink	6/3/16 5:00 AM	1.09	BA
52294-1-W-S01-003	Main- Inside Room 102, Sink	6/3/16 5:00 AM	1.69	BA
52294-1-W-S01-004	Main- Inside Room 102, Sink	6/3/16 5:00 AM	1.01	BA
52294-1-W-S01-005	Main- Inside Room 102, Sink	6/3/16 5:00 AM	0.935	BA
52294-1-S-S02-001	Main- Inside Room 101, Sink	6/3/16 5:00 AM	1.24	BA
52294-1-S-S02-002	Main- Inside Room 101, Sink	6/3/16 5:00 AM	0.598	BA
52294-1-S-S02-003	Main- Inside Room 101, Sink	6/3/16 5:00 AM	2.17	BA
52294-1-S-S02-004	Main- Inside Room 101, Sink	6/3/16 5:00 AM	0.559	BA
52294-1-S-S02-005	Main- Inside Room 101, Sink	6/3/16 5:00 AM	0.476	BA
52294-1-E-F03-001	Main- Across from Room 101, Fountain	6/3/16 5:00 AM	1.2	BA
52294-1-E-F03-002	Main- Across from Room 101, Fountain	6/3/16 5:00 AM	0.67	BA
52294-1-E-F03-003	Main- Across from Room 101, Fountain	6/3/16 5:00 AM	0.629	BA
52294-1-E-F03-004	Main- Across from Room 101, Fountain	6/3/16 5:00 AM	0.606	BA
52294-1-E-F03-005	Main- Across from Room 101, Fountain	6/3/16 5:00 AM	0.572	BA
52294-1-N-S04-001	Main- Inside Room 103, Sink	6/3/16 5:00 AM	1.57	BA
52294-1-N-S04-002	Main- Inside Room 103, Sink	6/3/16 5:00 AM	1.28	BA
52294-1-N-S04-003	Main- Inside Room 103, Sink	6/3/16 5:00 AM	0.636	BA
52294-1-N-S04-004	Main- Inside Room 103, Sink	6/3/16 5:00 AM	0.561	BA
52294-1-N-S04-005	Main- Inside Room 103, Sink	6/3/16 5:00 AM	0.444	BA
52294-1-W-S05-001	Main- Inside Room 104, Sink	6/3/16 5:00 AM	0.84	BA
52294-1-W-S05-002	Main- Inside Room 104, Sink	6/3/16 5:00 AM	0.86	BA
52294-1-W-S05-003	Main- Inside Room 104, Sink	6/3/16 5:00 AM	0.661	BA
52294-1-W-S05-004	Main- Inside Room 104, Sink	6/3/16 5:00 AM	0.905	BA
52294-1-W-S05-005	Main- Inside Room 104, Sink	6/3/16 5:00 AM	0.692	BA
52294-1-E-F06-001	Main- Outside Room 106, Fountain 1	6/3/16 5:00 AM	0.546	BA
52294-1-E-F06-002	Main- Outside Room 106, Fountain 1	6/3/16 5:00 AM	0.467	BA
52294-1-E-F06-003	Main- Outside Room 106, Fountain 1	6/3/16 5:00 AM	0.169	BA
52294-1-E-F06-004	Main- Outside Room 106, Fountain 1	6/3/16 5:00 AM	0.13	BA
52294-1-E-F06-005	Main- Outside Room 106, Fountain 1	6/3/16 5:00 AM	0.12	BA
52294-1-E-F07-001	Main- Outside Room 106, Fountain 2	6/3/16 5:00 AM	0.357	BA
52294-1-E-F07-002	Main- Outside Room 106, Fountain 2	6/3/16 5:00 AM	0.141	BA
52294-1-E-F07-003	Main- Outside Room 106, Fountain 2	6/3/16 5:00 AM	<0.120	ND
52294-1-E-F07-004	Main- Outside Room 106, Fountain 2	6/3/16 5:00 AM	<0.120	ND
52294-1-E-F07-005	Main- Outside Room 106, Fountain 2	6/3/16 5:00 AM	<0.120	ND
52294-1-S-F08-001	Main- Across from Room 108, Fountain 1	6/3/16 5:00 AM	0.585	BA
52294-1-S-F08-002	Main- Across from Room 108, Fountain 1	6/3/16 5:00 AM	0.52	BA
52294-1-S-F08-003	Main- Across from Room 108, Fountain 1	6/3/16 5:00 AM	0.464	BA
52294-1-S-F08-004	Main- Across from Room 108, Fountain 1	6/3/16 5:00 AM	0.431	BA
52294-1-S-F08-005	Main- Across from Room 108, Fountain 1	6/3/16 5:00 AM	0.399	BA
52294-1-S-F09-001	Main- Across from Room 108, Fountain 2	6/3/16 5:00 AM	0.482	BA
52294-1-S-F09-002	Main- Across from Room 108, Fountain 2	6/3/16 5:00 AM	0.427	BA
52294-1-S-F09-003	Main- Across from Room 108, Fountain 2	6/3/16 5:00 AM	0.41	BA
52294-1-S-F09-004	Main- Across from Room 108, Fountain 2	6/3/16 5:00 AM	0.415	BA
52294-1-S-F09-005	Main- Across from Room 108, Fountain 2	6/3/16 5:00 AM	0.391	BA
52294-1-W-F10-001	Main- Across from Room 125, Fountain 1	6/3/16 5:00 AM	1.07	BA
52294-1-W-F10-002	Main- Across from Room 125, Fountain 1	6/3/16 5:00 AM	0.46	BA
52294-1-W-F10-003	Main- Across from Room 125, Fountain 1	6/3/16 5:00 AM	0.224	BA
52294-1-W-F10-004	Main- Across from Room 125, Fountain 1	6/3/16 5:00 AM	0.172	BA
52294-1-W-F10-005	Main- Across from Room 125, Fountain 1	6/3/16 5:00 AM	0.123	BA
52294-1-W-F11-001	Main- Across from Room 125, Fountain 2	6/3/16 5:00 AM	0.318	BA
52294-1-W-F11-002	Main- Across from Room 125, Fountain 2	6/3/16 5:00 AM	<0.120	ND
52294-1-W-F11-003	Main- Across from Room 125, Fountain 2	6/3/16 5:00 AM	<0.120	ND
52294-1-W-F11-004	Main- Across from Room 125, Fountain 2	6/3/16 5:00 AM	<0.120	ND
52294-1-W-F11-005	Main- Across from Room 125, Fountain 2	6/3/16 5:00 AM	<0.120	ND
52294-1-S-F12-001	Main- By Entrance Number 4, Fountain	6/3/16 5:00 AM	2.44	BA
52294-1-S-F12-002	Main- By Entrance Number 4, Fountain	6/3/16 5:00 AM	0.959	BA
52294-1-S-F12-003	Main- By Entrance Number 4, Fountain	6/3/16 5:00 AM	0.679	BA
52294-1-S-F12-004	Main- By Entrance Number 4, Fountain	6/3/16 5:00 AM	0.815	BA
52294-1-S-F12-005	Main- By Entrance Number 4, Fountain	6/3/16 5:00 AM	0.964	BA
52294-1-N-S13-001	Main- Kitchen Sink 1	6/3/16 5:00 AM	0.64	BA
52294-1-N-S13-002	Main- Kitchen Sink 1	6/3/16 5:00 AM	0.368	BA
52294-1-N-S13-003	Main- Kitchen Sink 1	6/3/16 5:00 AM	1.07	BA
52294-1-N-S13-004	Main- Kitchen Sink 1	6/3/16 5:00 AM	1.63	BA
52294-1-N-S13-005	Main- Kitchen Sink 1	6/3/16 5:00 AM	1.88	BA
52294-1-N-S14-001	Main- Kitchen Sink 2	6/3/16 5:00 AM	1.33	BA
52294-1-N-S14-002	Main- Kitchen Sink 2	6/3/16 5:00 AM	1.46	BA
52294-1-N-S14-003	Main- Kitchen Sink 2	6/3/16 5:00 AM	1.12	BA
52294-1-N-S14-004	Main- Kitchen Sink 2	6/3/16 5:00 AM	1.04	BA
52294-1-N-S14-005	Main- Kitchen Sink 2	6/3/16 5:00 AM	0.818	BA
52294-2-E-F01-001	Main- Across from Room 221, Fountain 1	6/3/16 5:00 AM	0.618	BA
52294-2-E-F01-002	Main- Across from Room 221, Fountain 1	6/3/16 5:00 AM	0.88	BA
52294-2-E-F01-003	Main- Across from Room 221, Fountain 1	6/3/16 5:00 AM	0.501	BA
52294-2-E-F01-004	Main- Across from Room 221, Fountain 1	6/3/16 5:00 AM	0.504	BA
52294-2-E-F01-005	Main- Across from Room 221, Fountain 1	6/3/16 5:00 AM	0.707	BA
52294-2-E-F02-001	Main- Across from Room 221, Fountain 2	6/3/16 5:00 AM	0.694	BA
52294-2-E-F02-002	Main- Across from Room 221, Fountain 2	6/3/16 5:00 AM	0.551	BA
52294-2-E-F02-003	Main- Across from Room 221, Fountain 2	6/3/16 5:00 AM	0.441	BA
52294-2-E-F02-004	Main- Across from Room 221, Fountain 2	6/3/16 5:00 AM	0.318	BA
52294-2-E-F02-005	Main- Across from Room 221, Fountain 2	6/3/16 5:00 AM	0.247	BA
52294-2-S-F03-001	Main- Across from Room 210, Fountain 1	6/3/16 5:00 AM	0.49	BA
52294-2-S-F03-002	Main- Across from Room 210, Fountain 1	6/3/16 5:00 AM	0.521	BA
52294-2-S-F03-003	Main- Across from Room 210, Fountain 1	6/3/16 5:00 AM	0.418	BA
52294-2-S-F03-004	Main- Across from Room 210, Fountain 1	6/3/16 5:00 AM	0.378	BA
52294-2-S-F03-005	Main- Across from Room 210, Fountain 1	6/3/16 5:00 AM	0.364	BA
52294-2-S-F04-001	Main- Across from Room 210, Fountain 2	6/3/16 5:00 AM	0.48	BA
52294-2-S-F04-002	Main- Across from Room 210, Fountain 2	6/3/16 5:00 AM	0.394	BA
52294-2-S-F04-003	Main- Across from Room 210, Fountain 2	6/3/16 5:00 AM	0.328	BA
52294-2-S-F04-004	Main- Across from Room 210, Fountain 2	6/3/16 5:00 AM	0.286	BA
52294-2-S-F04-005	Main- Across from Room 210, Fountain 2	6/3/16 5:00 AM	0.23	BA
52294-2-W-F05-001	Main- Across from Room 207, Fountain 1	6/3/16 5:00 AM	0.267	BA
52294-2-W-F05-002	Main- Across from Room 207, Fountain 1	6/3/16 5:00 AM	0.196	BA
52294-2-W-F05-003	Main- Across from Room 207, Fountain 1	6/3/16 5:00 AM	<0.120	ND
52294-2-W-F05-004	Main- Across from Room 207, Fountain 1	6/3/16 5:00 AM	<0.120	ND
52294-2-W-F05-005	Main- Across from Room 207, Fountain 1	6/3/16 5:00 AM	<0.120	ND
52294-2-W-F06-001	Main- Across from Room 207, Fountain 2	6/3/16 5:00 AM	0.358	BA
52294-2-W-F06-002	Main- Across from Room 207, Fountain 2	6/3/16 5:00 AM	0.122	BA
52294-2-W-F06-003	Main- Across from Room 207, Fountain 2	6/3/16 5:00 AM	<0.120	ND
52294-2-W-F06-004	Main- Across from Room 207, Fountain 2	6/3/16 5:00 AM	<0.120	ND
52294-2-W-F06-005	Main- Across from Room 207, Fountain 2	6/3/16 5:00 AM	<0.120	ND

EPA ACTION LEVEL FOR LEAD IS 15 ppb or 15 µg/L

## SPREADSHEET LEGEND

ND-Not Detected at the Reporting Limit

BA-Below EPA Action Level of 15 ppb

AA-Above EPA Action Level