



School Name

Hurley

Sample ID #	Sample Location	Sample Collection Time & Date	Test Result (ppb)	Test Results
51298-B-W-501-001	Main- Basement Kitchen- Sink	6/4/16 5:00 AM	ND	ND
51298-B-W-501-002	Main- Basement Kitchen- Sink	6/4/16 5:00 AM	ND	ND
51298-B-W-501-003	Main- Basement Kitchen- Sink	6/4/16 5:00 AM	ND	ND
51298-B-W-501-004	Main- Basement Kitchen- Sink	6/4/16 5:00 AM	ND	ND
51298-B-W-501-005	Main- Basement Kitchen- Sink	6/4/16 5:00 AM	ND	ND
51298-1-E-F01-001	Main- Access From Room 104, Fountain	6/4/16 5:00 AM	ND	ND
51298-1-E-F01-002	Main- Access From Room 104, Fountain	6/4/16 5:00 AM	ND	ND
51298-1-E-F01-003	Main- Access From Room 104, Fountain	6/4/16 5:00 AM	ND	ND
51298-1-E-F01-004	Main- Access From Room 104, Fountain	6/4/16 5:00 AM	ND	ND
51298-1-E-F01-005	Main- Access From Room 104, Fountain	6/4/16 5:00 AM	ND	ND
51298-1-W-F02-001	Main- 1st Floor Outside Main Office, Fountain	6/4/16 5:00 AM	ND	ND
51298-1-W-F02-002	Main- 1st Floor Outside Main Office, Fountain	6/4/16 5:00 AM	ND	ND
51298-1-W-F02-003	Main- 1st Floor Outside Main Office, Fountain	6/4/16 5:00 AM	ND	ND
51298-1-W-F02-004	Main- 1st Floor Outside Main Office, Fountain	6/4/16 5:00 AM	ND	ND
51298-1-W-F02-005	Main- 1st Floor Outside Main Office, Fountain	6/4/16 5:00 AM	ND	ND
51298-1-W-F03-001	Main- Outside Gym, Fountain	6/4/16 5:00 AM	ND	ND
51298-1-W-F03-002	Main- Outside Gym, Fountain	6/4/16 5:00 AM	ND	ND
51298-1-W-F03-003	Main- Outside Gym, Fountain	6/4/16 5:00 AM	ND	ND
51298-1-W-F03-004	Main- Outside Gym, Fountain	6/4/16 5:00 AM	ND	ND
51298-1-W-F03-005	Main- Outside Gym, Fountain	6/4/16 5:00 AM	ND	ND
51298-2-E-F01-001	Main- 2nd Floor Access From Room 204, Fountain	6/4/16 5:00 AM	ND	ND
51298-2-E-F01-002	Main- 2nd Floor Access From Room 204, Fountain	6/4/16 5:00 AM	ND	ND
51298-2-E-F01-003	Main- 2nd Floor Access From Room 204, Fountain	6/4/16 5:00 AM	ND	ND
51298-2-E-F01-004	Main- 2nd Floor Access From Room 204, Fountain	6/4/16 5:00 AM	ND	ND
51298-2-E-F01-005	Main- 2nd Floor Access From Room 204, Fountain	6/4/16 5:00 AM	ND	ND
51298-2-W-F02-001	Main- 2nd Floor Access From Room 207, Fountain	6/4/16 5:00 AM	ND	ND
51298-2-W-F02-002	Main- 2nd Floor Access From Room 207, Fountain	6/4/16 5:00 AM	ND	ND
51298-2-W-F02-003	Main- 2nd Floor Access From Room 207, Fountain	6/4/16 5:00 AM	ND	ND
51298-2-W-F02-004	Main- 2nd Floor Access From Room 207, Fountain	6/4/16 5:00 AM	ND	ND
51298-2-W-F02-005	Main- 2nd Floor Access From Room 207, Fountain	6/4/16 5:00 AM	ND	ND
52476-1-E-F01-001	Annex- 1st Floor Access From Electrical Room, Fountain 1	6/4/16 5:00 AM	ND	ND
52476-1-E-F01-002	Annex- 1st Floor Access From Electrical Room, Fountain 1	6/4/16 5:00 AM	ND	ND
52476-1-E-F01-003	Annex- 1st Floor Access From Electrical Room, Fountain 1	6/4/16 5:00 AM	ND	ND
52476-1-E-F01-004	Annex- 1st Floor Access From Electrical Room, Fountain 1	6/4/16 5:00 AM	ND	ND
52476-1-E-F01-005	Annex- 1st Floor Access From Electrical Room, Fountain 1	6/4/16 5:00 AM	ND	ND
52476-1-E-F02-001	Annex- 1st Floor Access From Electrical Room, Fountain 2	6/4/16 5:00 AM	ND	ND
52476-1-E-F02-002	Annex- 1st Floor Access From Electrical Room, Fountain 2	6/4/16 5:00 AM	ND	ND
52476-1-E-F02-003	Annex- 1st Floor Access From Electrical Room, Fountain 2	6/4/16 5:00 AM	ND	ND
52476-1-E-F02-004	Annex- 1st Floor Access From Electrical Room, Fountain 2	6/4/16 5:00 AM	ND	ND
52476-1-E-F02-005	Annex- 1st Floor Access From Electrical Room, Fountain 2	6/4/16 5:00 AM	ND	ND
52476-1-E-S03-001	Annex- 1st Floor Inside Room 310, Sink	6/4/16 5:00 AM	ND	ND
52476-1-E-S03-002	Annex- 1st Floor Inside Room 310, Sink	6/4/16 5:00 AM	ND	ND
52476-1-E-S03-003	Annex- 1st Floor Inside Room 310, Sink	6/4/16 5:00 AM	ND	ND
52476-1-E-S03-004	Annex- 1st Floor Inside Room 310, Sink	6/4/16 5:00 AM	ND	ND
52476-1-E-S03-005	Annex- 1st Floor Inside Room 310, Sink	6/4/16 5:00 AM	ND	ND
52476-1-E-F04-001	Annex- 1st Floor Inside Room 310, Fountain	6/4/16 5:00 AM	ND	ND
52476-1-E-F04-002	Annex- 1st Floor Inside Room 310, Fountain	6/4/16 5:00 AM	ND	ND
52476-1-E-F04-003	Annex- 1st Floor Inside Room 310, Fountain	6/4/16 5:00 AM	ND	ND
52476-1-E-F04-004	Annex- 1st Floor Inside Room 310, Fountain	6/4/16 5:00 AM	ND	ND
52476-1-E-F04-005	Annex- 1st Floor Inside Room 310, Fountain	6/4/16 5:00 AM	ND	ND
52476-1-E-F05-001	Annex- 1st Floor Inside Room 309, Fountain	6/4/16 5:00 AM	ND	ND
52476-1-E-F05-002	Annex- 1st Floor Inside Room 309, Fountain	6/4/16 5:00 AM	ND	ND
52476-1-E-F05-003	Annex- 1st Floor Inside Room 309, Fountain	6/4/16 5:00 AM	ND	ND
52476-1-E-F05-004	Annex- 1st Floor Inside Room 309, Fountain	6/4/16 5:00 AM	ND	ND
52476-1-E-S06-001	Annex- 1st Floor Inside Room 309, Sink	6/4/16 5:00 AM	ND	ND
52476-1-E-S06-002	Annex- 1st Floor Inside Room 309, Sink	6/4/16 5:00 AM	ND	ND
52476-1-E-S06-003	Annex- 1st Floor Inside Room 309, Sink	6/4/16 5:00 AM	ND	ND
52476-1-E-S06-004	Annex- 1st Floor Inside Room 309, Sink	6/4/16 5:00 AM	ND	ND
52476-1-E-S06-005	Annex- 1st Floor Inside Room 309, Sink	6/4/16 5:00 AM	ND	ND
53825-1-C-F01-001	Modular 1- 1st Floor Inside Rooms 313/314, Fountain	6/4/16 5:00 AM	ND	ND
53825-1-C-F01-002	Modular 1- 1st Floor Inside Rooms 313/314, Fountain	6/4/16 5:00 AM	ND	ND
53825-1-C-F01-003	Modular 1- 1st Floor Inside Rooms 313/314, Fountain	6/4/16 5:00 AM	ND	ND
53825-1-C-F01-004	Modular 1- 1st Floor Inside Rooms 313/314, Fountain	6/4/16 5:00 AM	ND	ND
53825-1-C-F01-005	Modular 1- 1st Floor Inside Rooms 313/314, Fountain	6/4/16 5:00 AM	ND	ND
56824-1-C-F01-001	Modular 2- 1st Floor Inside Rooms 315/316, Fountain	6/4/16 5:00 AM	ND	ND
56824-1-C-F01-002	Modular 2- 1st Floor Inside Rooms 315/316, Fountain	6/4/16 5:00 AM	ND	ND
56824-1-C-F01-003	Modular 2- 1st Floor Inside Rooms 315/316, Fountain	6/4/16 5:00 AM	ND	ND
56824-1-C-F01-004	Modular 2- 1st Floor Inside Rooms 315/316, Fountain	6/4/16 5:00 AM	ND	ND
56824-1-C-F01-005	Modular 2- 1st Floor Inside Rooms 315/316, Fountain	6/4/16 5:00 AM	ND	ND
56824-1-C-F01-001	Modular 3- 1st Floor Inside Rooms 317/318, Fountain	6/4/16 5:00 AM	ND	ND
56824-1-C-F01-002	Modular 3- 1st Floor Inside Rooms 317/318, Fountain	6/4/16 5:00 AM	ND	ND
56824-1-C-F01-003	Modular 3- 1st Floor Inside Rooms 317/318, Fountain	6/4/16 5:00 AM	ND	ND
56824-1-C-F01-004	Modular 3- 1st Floor Inside Rooms 317/318, Fountain	6/4/16 5:00 AM	ND	ND
56824-1-C-F01-005	Modular 3- 1st Floor Inside Rooms 317/318, Fountain	6/4/16 5:00 AM	ND	ND

EPA ACTION LEVEL FOR LEAD IS 15 ppb or 15 µg/L

SPREADSHEET LEGEND
ND-Not Detected at the Reporting Limit
BA-Below EPA Action Level of 15 ppb
AA-Above EPA Action Level

Chicago Public Schools - Department of Facility Operations