ichool Name

Sample ID #	Sample Location	Sample Collection Time & Date	Test Result (ppb)	Test Results
31011-01-N01-F-002	Main-North Of Girls Eathroom, Fountain	5/25/16 5:00 AM 5/25/16 5:00 AM 5/25/16 5:00 AM 5/25/16 5:00 AM	0.64 0.802	- M
31011-01-N01-F-004 31011-01-N01-F-005	Main-North Of Gris Bathroom, Fountain Main-North Of Gris Bathroom, Fountain Main-North Of Gris Bathroom, Fountain	5/25/16 5:00 AM 5/25/16 5:00 AM	0.661 0.551	8A 84
31011-01-N01-S-001	Main- Inside Room 110, Sink	5/25/16 5:00 AM 5/25/16 5:00 AM	0.855	2A
31011-01-N01-S-003	Main- Inside Room 110, Sink	5/25/16 5:00 AM	0.505	2A
31011-01-N01-S-004 31011-01-N01-S-005	Main-Inside Room 110, Sink Main-Inside Room 110, Sink	5/25/16 5:00 AM 5/25/16 5:00 AM	0.458 0.464	BA BA
31011-01-N02-F-001 31011-01-N02-F-002 31011-01-N02-F-003	Main-South of Janistrial Closet, Fountain	5/75/16 5:00 AM 5/75/16 5:00 AM 5/75/16 5:00 AM 5/75/16 5:00 AM	0.309 0.251 -0.120 -0.120	2A 2A
31011-01-N02-F-003 31011-01-N02-F-004	Main-South of Janitorial Closet, Fountain Main-South of Janitorial Closet, Fountain	5/25/16 5:00 AM 5/25/16 5:00 AM	<0.120 <0.120	ND ND
31011-01-N02-F-005 31011-01-N03-F-001	Main- South of Janitorial Closet, Fountain Main- Hallaray Next To Girls Balteroom, Fountain	5/25/16 5:00 AM 5/25/16 5:00 AM	<0.120 7.63	ND SA
31011-01-N03-F-002 31011-01-N03-F-003 31011-01-N03-F-004	Main-Hallway Next To Cirls Eathroom, Fourtain Main-Hallway Next To Cirls Eathroom, Fourtain Main-Hallway Next To Cirls Eathroom, Fourtain Main-Hallway Next To Cirls Eathroom, Fountain	5/25/16 5:00 AM 5/25/16 5:00 AM 5/25/16 5:00 AM 5/25/16 5:00 AM	<0.120 <0.120	ND ND
31011-01-N03-F-005	Main-Hallway Next To Girls Bathroom, Fountain Main-Hallway Next To Girls Bathroom, Fountain	5/25/16 5:00 AM 5/25/16 5:00 AM	<0.120 <0.120	ND ND
31011-01-N03-S-001 31011-01-N03-S-002	Main-Inside Room 104, Sink Main-Inside Room 104, Sink	\$/25/16 5:00 AM \$/25/16 5:00 AM	0.662 0.768	BA BA
31011-01-N03-S-003 31011-01-N03-S-004	Main-Inside Room 104, Sink Main-Inside Room 104, Sink	5/25/16 5:00 AM 5/25/16 5:00 AM	0.918	
31011-01-N03-5-001 31011-01-N03-5-002 31011-01-N03-5-003 31011-01-N03-5-004 31011-01-N03-5-005 31011-01-N04-5-001	Main-Ireade Pitcen 104, Sink Main-Ireade Pitcen 104, Sink Main-Ireade Room 105, Sink	\$/25/16 5:00 AM \$/35/16 5:00 AM \$/35/16 5:00 AM \$/35/16 5:00 AM \$/35/16 5:00 AM \$/35/16 5:00 AM	0.662 0.768 0.918 0.809 0.918 7.91	BA BA BA
31011-01-N04-S-002 31011-01-N04-S-003	Main-Inside Room 103, Sink Main-Inside Room 103, Sink	5/25/16 5:00 AM 5/25/16 5:00 AM	1.46 0.652	- M
31011-01-N04-5-004 31011-01-N04-5-005	Main-Inside Room 103, Sink Main-Inside Room 103, Sink Main-Inside Room 103, Sink	5/25/16 5:00 AM 5/25/16 5:00 AM	0.397 0.322	BA BA
31011-01-N05-5-001	Main- Inside Room 101, Sink Main- Inside Room 101, Sink Main- Inside Room 101, Sink	5/35/16 5:00 AM 5/25/16 5:00 AM 5/25/16 5:00 AM	<0.120	ND ND
31011-01-N05-5-002 31011-01-N05-5-003	Main-Inside Room 101, Sink Main-Inside Room 101, Sink	5/25/16 5:00 AM 5/25/16 5:00 AM	1.51 0.508	SA SA
31011-01-N05-S-004 31011-01-N05-S-005	Main-Inside Room 101, Sink Main-Inside Room 101, Sink Main-Inside Room 101, Sink	5/25/16 5:00 AM 5/25/16 5:00 AM	0.433	BA BA
31011-01-N06-5-001 31011-01-N06-5-002	Main- Inside Room 101, Sink Main- Inside Room 102, Sink Main- Inside Room 102, Sink Main- Inside Room 102, Sink	\$/2\$/16 \$:00 AM \$/2\$/16 \$:00 AM \$/2\$/16 \$:00 AM	0.386 2.04 1.04	2A 04
31011-01-N06-5-003	Main-Inside Room 102, Sink	5/25/16 5:00 AM	0.591	BA .
31011-01-N06-S-005	Main-Inside Room 102, Sink Main-Inside Room 102, Sink Main-Inside Room 105, Sink	\$735/16 \$100 AM \$725/16 \$100 AM \$725/16 \$100 AM	0.292	EA.
31011-01-N07-S-002	Main- Inside Room 105, Sink	5/25/16 5:00 AM	4.28	- A
31011-01-N07-5-003 31011-01-N07-5-004	Main-Inside Room 105, Sink Main-Inside Room 105, Sink	\$/25/16 5:00 AM \$/25/16 5:00 AM	3.84 8.03	BA BA
31011-01-N07-S-005 31011-1-N-503-001	Main-Inside Room 105, Sink Main-Inside Room 108, Fountain/Sink Combo	5/25/16 5:00 AM 6/22/16 5:00 AM	4.32 1.41	2A 2A
31011-1-N-503-002 31011-1-N-503-003	Main-Inside Room 108, Fountain/Sink Combo Main-Inside Room 108, Fountain/Sink Combo	6/22/16 5:00 AM 6/22/16 5:00 AM	0.695 0.533	BA BA
31011-1-N-503-004 31011-1-N-503-005	Main-Inside Room 108, Fountain/Sink Combo Main-Inside Room 108, Fountain/Sink Combo	6/32/16 5:00 AM 6/32/16 5:00 AM 6/32/16 5:00 AM	0.168	BA BA
31011-1-N-505-001 31011-1-N-505-007	Main-Inside Room 110, Fountain/Sink Combo Main-Inside Room 110, Fountain/Sink Combo Main-Inside Room 110, Fountain/Sink Combo	6/22/16 5:00 AM 6/22/16 5:00 AM	1.19	SA SA
31011-1-N-505-002 31011-1-N-505-003 31011-1-N-505-004	Main-Inside Room 110, Fountain/Sink Combo Main-Inside Room 110, Fountain/Sink Combo Main-Inside Room 110, Fountain/Sink Combo	6/22/16 5:00 AM 6/22/16 5:00 AM 6/22/16 5:00 AM	0.791 0.67	BA BA
31011-1-N-505-004 31011-1-N-505-005	Main- Inside Room 110, Fountain/Sink Combo Main- Inside Room 110, Fountain/Sink Combo	6/22/16 5:00 AM 6/22/16 5:00 AM	0.67	SA SA
31011-1-W-F01-001	Branch-1st Floor, Next to Dievator, North Fountain 1	6/22/16 5:00 AM	0.331 1.14	BA .
31011-1-W-F01-002	Main-Inside Room 104, Fountain Branch-1st Floor, Next to Elevator, North Fountain 1	6/22/16 5:00 AM 6/22/16 5:00 AM	0.77 1.48	BA BA
31011-1-W-F01-003 31011-1-W-F01-003 31011-1-W-F01-004	Main-Institute Room 104, Fountain Main-Institute Room 104, Fountain Biranch-Ist Floor, Nand to Disvator, North Fountain 1 Main-Institute Room 104, Fountain Branch-Ist Floor, Nand to Disvator, North Fountain 1	6/22/16 5:00 AM 6/22/16 5:00 AM 6/22/16 5:00 AM 6/22/16 5:00 AM	0.844 1.16 0.914	BA BA
31011-1-W-F01-004 31011-1-W-F01-004	Main- Inside Room 104, Fountain Branch- 1st Floor, Next to Dievator, North Fountain 1	6/22/16 5:00 AM 6/22/16 5:00 AM	1.23	BA BA
31011-1-W-F01-005 31011-1-W-F01-005	Main- Inside Room 104, Fountain Branch, 1st Diocr Next to Diseaser North Fountain 1	6/22/16 5:00 AM 6/22/16 5:00 AM	0.918 1.11	2A 2A
31011-1-W-F02-001 31011-1-W-F02-002	Branch- 1st Floor, Next to Elevator, South Fountain 2 Branch- 1st Floor, Next to Elevator, South Fountain 2 Branch- 1st Floor, Next to Elevator, South Fountain 2 Branch- 1st Floor, Next to Elevator, South Fountain 2	6/72/16 5:00 AM 6/72/16 5:00 AM 6/72/16 5:00 AM 6/72/16 5:00 AM	0.309	BA BA
31011-1-W-F02-003	Branch- fat Floor, Next to Elevator, South Fountain 2 Branch, fat Elov, Next to Elevator, South Equation 2	6/22/16 5:00 AM 6/33/16 5:00 AM	0.452 0.533	2A 04
31011-1-W-F02-005 31011-1-W-F04-001	Branch- fat Floor, Next to Elevator, South Fountain 2	6/22/16 5:00 AM 6/22/16 5:00 AM	0.573 0.484	BA BA
31011-1-W-F04-002	Main-Next to Girls Restroom, North Fountain 1	6/22/16 5:00 AM	0.331	a A
31011-1-W-F04-002 31011-1-W-F04-003 31011-1-W-F04-004 31011-1-W-F04-005	Main- Next to Girls Restroom, North Fountain 1 Main- Next to Girls Restroom, North Fountain 1 Main- Next to Girls Restroom, North Fountain 1 Main- Next to Girls Restroom, North Fountain 1	6/22/16 5:00 AM 6/22/16 5:00 AM 6/22/16 5:00 AM 6/22/16 5:00 AM	0.331 0.17 0.153 0.147	- M
31011-1-W-F05-001 31011-1-W-F05-002	Main- Next to Cirts Restroom, South Fountain 1 Main- Next to Girls Restroom, South Fountain 2	6/22/16 5:00 AM 6/22/16 5:00 AM 6/22/16 5:00 AM	0.122 <0.120	BA ND
31011-1-W-F05-003	Main-Next to Girls Restroom, South Fountain 2 Main-Next to Girls Restroom, South Fountain 2 Main-Next to Girls Restroom, South Fountain 2	6/22/16 5:00 AM	0.126	9.4
31011-1-W-F05-004 31011-1-W-F05-005	Main-Nest to Girls Restroom, South Fountain 2 Main-Nest to Girls Restroom, South Fountain 2	6/22/16 5:00 AM 6/22/16 5:00 AM 6/22/16 5:00 AM	<0.120 <0.120	ND ND
31011-1-W-F07-001 31011-1-W-F07-002	Main- Outside Gym, North Fountain 1 Main- Outside Gym, North Fountain 1	6/22/16 S:00 AM	<0.120 0.343	ND SA
31011-1-W-F07-003 31011-1-W-F07-004	Main- Outside Gym, North Fountain 1 Main- Outside Gym, North Fountain 1	6/22/16 5:00 AM 6/22/16 5:00 AM	0.465	BA BA
31011-1-W-F07-005 31011-1-W-F08-001	Main- Outside Gym, North Fountain 1 Main- Outside Gym, South Fountain 2	6/22/16 5:00 AM 6/22/16 5:00 AM 6/22/16 5:00 AM	0.555	BA BA
31011-1-W-F08-002 31011-1-W-F08-003	Main- Outside Gym, South Fountain 2 Main- Outside Gym, South Fountain 2	6/22/16 S-00 AM	0.201	BA BA
31011-1-W-F08-004 31011-1-W-F08-005	Main-Outside Gym, South Fountain 2 Main-Outside Gym, South Fountain 2	6/22/16 5:00 AM 6/22/16 5:00 AM	0.124 <0.120	SA NO
31011-1-W-502-001				2A 2A
31011-1-W-502-003	Main-Inside Room 104, Sink Main-Inside Room 104, Sink Main-Inside Room 104, Sink	6/22/16 5:00 AM 6/22/16 5:00 AM 6/22/16 5:00 AM	0.927 0.863 0.931	2A
31011-1-W-502-005	Main- Inside Room 104, Sink	6/22/16 S:00 AM	0.901 1.78	BA BA
31011-1-W-502-005 31011-2-W-F01-001 31011-2-W-F01-001 31011-2-W-F01-002 31011-2-W-F01-002	Main-Outside Room 217, Fountain Branch-2nd Floor, Nato to Envalor, Neth Fountain 1 Main-Outside Room 217, Fountain Branch-2nd Floor, Ned to Envalor, North Fountain 1 Main-Outside Room 217, Fountain	6/22/16 5:00 AM 6/22/16 5:00 AM 6/22/16 5:00 AM 6/22/16 5:00 AM 6/22/16 5:00 AM 6/22/16 5:00 AM	1.78 1.48 1.9 1.07	BA BA
31011-2-W-F01-002 31011-2-W-F01-003	Branch-2nd Floor, Next to Elevator, North Fountain 1	6/22/16 5:00 AM	1.07	a A
31011-2-W-F01-003 31011-2-W-F01-003 31011-2-W-F01-004	Main- Cutside Room 217, Fountain Branch- 2nd Floor, Next to Elevator, North Fountain 1 Main- Outside Room 217, Fountain	6/22/16 5:00 AM 6/22/16 5:00 AM 6/22/16 5:00 AM	1.64 1.1 1.91	2A 2A
31011-2-W-F01-004	Main- Outside Room 217, Fountain Branch- 2nd Floor, Next to Elevator, North Fountain 1 Main- Outside Room 217, Fountain	6/22/16 5:00 AM 6/22/16 5:00 AM 6/22/16 5:00 AM	1.93 1.11 1.94	SA SA
31011-2-W-F01-005	Branch- 2nd Floor, Next to Elevator, North Fountain 1	6/22/16 S:00 AM	1.05	
31011-2-W-F02-001 31011-2-W-F02-002	Main- 2nd Floor Outside Girls Restroom, North Fountain 1 Main- 2nd Floor Outside Girls Restroom, North Fountain 1	6/22/16 5:00 AM 6/22/16 5:00 AM	4.31 3.78	BA BA
31011-2-W-F02-003 31011-2-W-F02-004	Main- 2nd Floor Outside Girls Restroom, North Fountain 1 Main- 2nd Floor Outside Girls Restroom, North Fountain 1	6/22/16 5:00 AM 6/22/16 5:00 AM	3.24 2.98	BA BA
31011-2-W-F02-005 31011-2-W-F03-001	Main- 2nd Floor Outside Girls Restroom, North Fountain 1 Main- 2nd Floor Outside Girls Restroom, South Fountain 2	6/22/16 5:00 AM 6/22/16 5:00 AM	2.56 1.99 0.76 0.262	BA BA
31011-2-W-F03-002 31011-2-W-F03-003	Main- 2nd Floor Outside Girls Restroom, South Fountain 2 Main- 2nd Floor Outside Girls Restroom, South Fountain 2	6/22/16 5:00 AM 6/22/16 5:00 AM		BA BA
31011-2-W-F03-004 31011-2-W-F03-005	Main- 2nd Floor Outside Girls Restroom, South Fountain 2 Main- 2nd Floor Outside Girls Restroom, South Fountain 2	6/22/16 5:00 AM 6/22/16 5:00 AM	0.158 0.141	BA BA
31011-2-W-502-001 31011-2-W-502-002	Branch- 2nd Floor, Next to Elevator, South Sink Branch- 2nd Floor, Next to Elevator, South Sink	6/22/16 5:00 AM 6/22/16 5:00 AM	16 1.83	SA SA
31011-2-W-502-003 31011-2-W-502-014	Branch- 2nd Floor, Next to Elevator, South Sink Branch- 2nd Floor, Next to Elevator, South Sink	6/22/16 5:00 AM 6/22/16 5:00 AM	1.72 1.28	BA BA
31011-2-W-502-005 31011-3-W-F01-001	Branch- 2nd Floor, Next to Elevator, South Sink Branch- 2nd Floor, Next to Elevator, North Fountain 1	6/22/16 5:00 AM 6/22/16 5:00 AM	1.21 2.35	BA BA
31011-3-W-F01-002	Branch- 3rd Floor, Next to Elevator, North Fountain 1	6/22/16 5:00 AM	1.94 1.86	8A 8A
31011-3-W-F01-004	Branch- 3rd Floor, Next to Elevator, North Fountier 1	6/22/16 5:00 AM 6/22/16 5:00 AM 6/22/16 5:00 AM	2.06	- A
31011-3-W-F02-001	Branch- 3rd Floor, Next to Elevator, South Fountain 2	6/22/16 S-00 AM	1.36	84
31011-3-W-F02-002 31011-3-W-F02-003	Branch- 3rd Floor, Next to Elevator, South Fountain 2 Branch- 3rd Floor, Next to Elevator, South Fountain 2	6/22/16 5:00 AM 6/22/16 5:00 AM	1.42	BA BA
31011-3-W-F02-004 31011-3-W-F02-005	Branch- 3rd Floor, Next to Elevator, South Fountain 2 Branch- 3rd Floor, Next to Elevator, South Fountain 2	6/22/16 5:00 AM 6/22/16 5:00 AM 5/25/16 5:00 AM	1.69 2.94	BA BA
31011-0-E01-KS-001 31011-0-E01-KS-002	Main-East Kitchen, Prep Sink Main-East Kitchen, Prep Sink	5/25/16 5:00 AM	1.01	2A
31011-8-E01-KS-003 31011-8-E01-KS-004	Main-East Eltchen, Prep Sink Main-East Eltchen, Prep Sink	\$/25/16 5:00 AM \$/25/16 5:00 AM	1.25	2A 2A
31011-6-201-85-005 31011-6-202-85-001 31011-6-202-85-002	Main-East Kitchen, Prep Sink Main-Kitchen, Sink Above Stove	5/25/16 5:00 AM 5/25/16 5:00 AM	1.36 9.45	9A 9A
31011-0-002-KS-002 31011-0-002-KS-003	Main-Kitchen, Sink Above Slove Main-Kitchen, Sink Above Slove	\$/25/16 \$:00 AM \$/25/16 \$:00 AM	1.36 9.45 5.29 4.8	SA SA
31011-0-E02-KS-004 31011-0-E02-KS-005	Main-Kitchen, Sink Above Stove Main-Kitchen, Sink Above Stove	5/25/16 5:00 AM 5/25/16 5:14 AM	2.52 2.61	BA BA
31011-B-N01-F-001 31011-B-N01-F-002	Main-Lunchroom, Fountain Main-Lunchroom, Fountain	5/25/16 5:00 AM 5/25/16 5:00 AM	1.37 0.883	8A 8A
31011-B-N01-F-003	Main-Lunchroom, Fountain	5/25/16 5:00 AM	0.85	<u> </u>
31011-0-N01-F-005	Main-Lunchroom, Fountain Main-Lunchroom, Fountain	5/25/16 5:00 AM 5/25/16 5:00 AM 6/22/16 5:00 AM	0.842 0.831 0.47	BA BA
31011-8-5-F01-001 31011-8-5-F01-002 31011-8-5-F01-003	Branch-Basement, Next to Elevator, Fountain Branch-Basement, Next to Elevator, Fountain Branch-Basement, Next to Elevator, Fountain	6/22/16 5:00 AM 6/22/16 5:00 AM 6/22/16 5:00 AM	0.47 1.52 1.01	BA BA
31011-0-5-F01-003 31011-0-5-F01-004	sranch-Basement, Next to Elevator, Fountain Branch-Basement, Next to Elevator, Fountain	6/22/16 5:00 AM 6/22/16 5:00 AM	1.01 0.855	8A 8A
31011-0-5-F01-005	Branch, Sessment Next to Elevator Encetain	6/22/16/5-00 AM	0.010	9.4

SPREADSHEET LEGEND
ND-Not Detected at the Reporting Lim
BA-Below EPA Action Level of 15 ppb

Chicago Public Schools - Department of Facility Operatio