



School Lead Water Testing - Data Collection Form

School Name

Dewey

Sample ID #	Sample Location	Sample Collection Time & Date	Test Result (ppb)	Test Results
22951-B-N-S01-001	Main- Kitchen, Sink 1	5/24/16 5:00 AM	3.49	BA
22951-B-N-S01-002	Main- Kitchen, Sink 1	5/24/16 5:00 AM	1.74	BA
22951-B-N-S01-003	Main- Kitchen, Sink 1	5/24/16 5:00 AM	0.991	BA
22951-B-N-S01-004	Main- Kitchen, Sink 1	5/24/16 5:00 AM	0.848	BA
22951-B-N-S01-005	Main- Kitchen, Sink 1	5/24/16 5:00 AM	0.813	BA
22951-B-N-S02-001	Main- Kitchen, Sink 2	5/24/16 5:00 AM	<0.120	ND
22951-B-N-S02-002	Main- Kitchen, Sink 2	5/24/16 5:00 AM	0.218	BA
22951-B-N-S02-003	Main- Kitchen, Sink 2	5/24/16 5:00 AM	<0.120	ND
22951-B-N-S02-004	Main- Kitchen, Sink 2	5/24/16 5:00 AM	0.12	BA
22951-B-N-S02-005	Main- Kitchen, Sink 2	5/24/16 5:00 AM	0.41	BA
22951-B-E-F03-001	Main- Outside Room 011, Fountain 1	5/24/16 5:00 AM	5.75	BA
22951-B-E-F03-002	Main- Outside Room 011, Fountain 1	5/24/16 5:00 AM	6.24	BA
22951-B-E-F03-003	Main- Outside Room 011, Fountain 1	5/24/16 5:00 AM	6.29	BA
22951-B-E-F03-004	Main- Outside Room 011, Fountain 1	5/24/16 5:00 AM	6.56	BA
22951-B-E-F03-005	Main- Outside Room 011, Fountain 1	5/24/16 5:00 AM	6.16	BA
22951-B-E-F04-001	Main- Outside Room 011, Fountain 2	5/24/16 5:00 AM	2.99	BA
22951-B-E-F04-002	Main- Outside Room 011, Fountain 2	5/24/16 5:00 AM	1.49	BA
22951-B-E-F04-003	Main- Outside Room 011, Fountain 2	5/24/16 5:00 AM	1.41	BA
22951-B-E-F04-004	Main- Outside Room 011, Fountain 2	5/24/16 5:00 AM	1.44	BA
22951-B-E-F04-005	Main- Outside Room 011, Fountain 2	5/24/16 5:00 AM	1.13	BA
22951-B-W-F05-001	Main- Outside West Store Room, Fountain	5/24/16 5:00 AM	2.17	BA
22951-B-W-F05-002	Main- Outside West Store Room, Fountain	5/24/16 5:00 AM	2.5	BA
22951-B-W-F05-003	Main- Outside West Store Room, Fountain	5/24/16 5:00 AM	3.63	BA
22951-B-W-F05-004	Main- Outside West Store Room, Fountain	5/24/16 5:00 AM	3.91	BA
22951-B-W-F05-005	Main- Outside West Store Room, Fountain	5/24/16 5:00 AM	3.99	BA
22951-1-C-F01-001	Main- Outside Room 108, Fountain 1	5/24/16 5:00 AM	0.342	BA
22951-1-C-F01-002	Main- Outside Room 108, Fountain 1	5/24/16 5:00 AM	0.179	BA
22951-1-C-F01-003	Main- Outside Room 108, Fountain 1	5/24/16 5:00 AM	0.368	BA
22951-1-C-F01-004	Main- Outside Room 108, Fountain 1	5/24/16 5:00 AM	1.11	BA
22951-1-C-F01-005	Main- Outside Room 108, Fountain 1	5/24/16 5:00 AM	0.149	ND
22951-1-C-F02-001	Main- Outside Room 108, Fountain 2	5/24/16 5:00 AM	<0.120	ND
22951-1-C-F02-002	Main- Outside Room 108, Fountain 2	5/24/16 5:00 AM	<0.120	ND
22951-1-C-F02-003	Main- Outside Room 108, Fountain 2	5/24/16 5:00 AM	<0.120	ND
22951-1-C-F02-004	Main- Outside Room 108, Fountain 2	5/24/16 5:00 AM	0.304	BA
22951-1-C-F02-005	Main- Outside Room 108, Fountain 2	5/24/16 5:00 AM	0.349	BA
22951-1-C-F03-001	Main- Outside Room 108, Fountain 3	5/24/16 5:00 AM	0.32	BA
22951-1-C-F03-002	Main- Outside Room 108, Fountain 3	5/24/16 5:00 AM	<0.120	ND
22951-1-C-F03-003	Main- Outside Room 108, Fountain 3	5/24/16 5:00 AM	<0.120	ND
22951-1-C-F03-004	Main- Outside Room 108, Fountain 3	5/24/16 5:00 AM	1.21	BA
22951-1-C-F03-005	Main- Outside Room 108, Fountain 3	5/24/16 5:00 AM	0.478	BA
22951-2-C-F01-001	Main- Outside Teachers Toilet, Fountain	5/24/16 5:00 AM	0.196	BA
22951-2-C-F01-002	Main- Outside Teachers Toilet, Fountain	5/24/16 5:00 AM	0.309	BA
22951-2-C-F01-003	Main- Outside Teachers Toilet, Fountain	5/24/16 5:00 AM	0.771	BA
22951-2-C-F01-004	Main- Outside Teachers Toilet, Fountain	5/24/16 5:00 AM	0.373	BA
22951-2-C-F01-005	Main- Outside Teachers Toilet, Fountain	5/24/16 5:00 AM	0.127	BA
22951-3-C-F01-001	Main- Inside Gym, Fountain	5/24/16 5:00 AM	0.549	BA
22951-3-C-F01-002	Main- Inside Gym, Fountain	5/24/16 5:00 AM	0.581	BA
22951-3-C-F01-003	Main- Inside Gym, Fountain	5/24/16 5:00 AM	0.149	BA
22951-3-C-F01-004	Main- Inside Gym, Fountain	5/24/16 5:00 AM	0.567	BA
22951-3-C-F01-005	Main- Inside Gym, Fountain	5/24/16 5:00 AM	0.636	BA
22951-1-A-N-S01-001	Annex CPC- Kitchen, Sink	5/24/16 5:00 AM	1.85	BA
22951-1-A-N-S01-002	Annex CPC- Kitchen, Sink	5/24/16 5:00 AM	1.43	BA
22951-1-A-N-S01-003	Annex CPC- Kitchen, Sink	5/24/16 5:00 AM	1.48	BA
22951-1-A-N-S01-004	Annex CPC- Kitchen, Sink	5/24/16 5:00 AM	1.44	BA
22951-1-A-N-S01-005	Annex CPC- Kitchen, Sink	5/24/16 5:00 AM	1.39	BA
22951-1-A-N-S02-001	Annex CPC- Classroom Kitchen, Sink	5/24/16 5:00 AM	2.34	BA
22951-1-A-N-S02-002	Annex CPC- Classroom Kitchen, Sink	5/24/16 5:00 AM	0.844	BA
22951-1-A-N-S02-003	Annex CPC- Classroom Kitchen, Sink	5/24/16 5:00 AM	0.627	BA
22951-1-A-N-S02-004	Annex CPC- Classroom Kitchen, Sink	5/24/16 5:00 AM	0.951	BA
22951-1-A-N-S02-005	Annex CPC- Classroom Kitchen, Sink	5/24/16 5:00 AM	1.83	BA
22951-1-N-F03-001	Annex CPC- Inside Room 405, Fountain	5/24/16 5:00 AM	1.04	BA
22951-1-N-F03-002	Annex CPC- Inside Room 405, Fountain	5/24/16 5:00 AM	1.44	BA
22951-1-N-F03-003	Annex CPC- Inside Room 405, Fountain	5/24/16 5:00 AM	1.7	BA
22951-1-N-F03-004	Annex CPC- Inside Room 405, Fountain	5/24/16 5:00 AM	1.67	BA
22951-1-N-F03-005	Annex CPC- Inside Room 405, Fountain	5/24/16 5:00 AM	1.62	BA
22951-1-N-F04-001	Annex CPC- Inside Room 408, Fountain	5/24/16 5:00 AM	1.11	BA
22951-1-N-F04-002	Annex CPC- Inside Room 408, Fountain	5/24/16 5:00 AM	0.454	BA
22951-1-N-F04-003	Annex CPC- Inside Room 408, Fountain	5/24/16 5:00 AM	1.06	BA
22951-1-N-F04-004	Annex CPC- Inside Room 408, Fountain	5/24/16 5:00 AM	1.15	BA
22951-1-N-F04-005	Annex CPC- Inside Room 408, Fountain	5/24/16 5:00 AM	1.18	BA
22951-1-S-S05-001	Annex CPC- Inside Room 411, Sink	5/24/16 5:00 AM	1.14	BA
22951-1-S-S05-002	Annex CPC- Inside Room 411, Sink	5/24/16 5:00 AM	0.976	BA
22951-1-S-S05-003	Annex CPC- Inside Room 411, Sink	5/24/16 5:00 AM	1.18	BA
22951-1-S-S05-004	Annex CPC- Inside Room 411, Sink	5/24/16 5:00 AM	1.16	BA
22951-1-S-S05-005	Annex CPC- Inside Room 411, Sink	5/24/16 5:00 AM	1.1	BA
22951-1-S-S06-001	Annex CPC- Inside Room 412, Sink	5/24/16 5:00 AM	1.28	BA
22951-1-S-S06-002	Annex CPC- Inside Room 412, Sink	5/24/16 5:00 AM	1.05	BA
22951-1-S-S06-003	Annex CPC- Inside Room 412, Sink	5/24/16 5:00 AM	1.23	BA
22951-1-S-S06-004	Annex CPC- Inside Room 412, Sink	5/24/16 5:00 AM	1.3	BA
22951-1-S-S06-005	Annex CPC- Inside Room 412, Sink	5/24/16 5:00 AM	1.23	BA
22951-1-S-F07-001	Annex CPC- Inside Room 413, Fountain	5/24/16 5:00 AM	0.954	BA
22951-1-S-F07-002	Annex CPC- Inside Room 413, Fountain	5/24/16 5:00 AM	1.22	BA
22951-1-S-F07-003	Annex CPC- Inside Room 413, Fountain	5/24/16 5:00 AM	1.18	BA
22951-1-S-F07-004	Annex CPC- Inside Room 413, Fountain	5/24/16 5:00 AM	1.19	BA
22951-1-S-F07-005	Annex CPC- Inside Room 413, Fountain	5/24/16 5:00 AM	1.2	BA

EPA ACTION LEVEL FOR LEAD IS 15 ppb or 15 µg/L

SPREADSHEET LEGEND

ND-Not Detected at the Reporting Limit

BA-Below EPA Action Level of 15 ppb

AA-Above EPA Action Level

Chicago Public Schools - Department of Facility Operations