



School Lead Water Testing - Data Collection Form

School Short Name **Kilmer**

Length of time water remained in pipes before sampled (hours) 13.00
Report based on lab results dated 6/13/16
Date of test 05/28/16
Water last used (Time and date) Approx 4 PM 5/27/16

Sample ID #	Sample Location	Sample Collection Time & Date	Test Result (ppb)	Test Results
51064-1-E-FD1-001	Next To Room 107, Fountain	5/28/2016 5:00AM	0.647	BA
51064-1-E-FD1-002	Next To Room 107, Fountain	5/28/2016 5:00AM	0.322	BA
51064-1-E-FD1-003	Next To Room 107, Fountain	5/28/2016 5:00AM	0.452	BA
51064-1-E-FD1-004	Next To Room 107, Fountain	5/28/2016 5:00AM	0.24	BA
51064-1-E-FD1-005	Next To Room 107, Fountain	5/28/2016 5:00AM	0.417	BA
51064-1-W-FD2-001	Next To Auditorium, Fountain	5/28/2016 5:00AM	1.24	BA
51064-1-W-FD2-002	Next To Auditorium, Fountain	5/28/2016 5:00AM	1.06	BA
51064-1-W-FD2-003	Next To Auditorium, Fountain	5/28/2016 5:00AM	2.17	BA
51064-1-W-FD2-004	Next To Auditorium, Fountain	5/28/2016 5:00AM	1.34	BA
51064-1-W-FD2-005	Next To Auditorium, Fountain	5/28/2016 5:00AM	0.997	BA
51064-1-E-FD3-001	Next To Room 101, Fountain	5/28/2016 5:00AM	0.286	BA
51064-1-E-FD3-002	Next To Room 101, Fountain	5/28/2016 5:00AM	0.363	BA
51064-1-E-FD3-003	Next To Room 101, Fountain	5/28/2016 5:00AM	0.228	BA
51064-1-E-FD3-004	Next To Room 101, Fountain	5/28/2016 5:00AM	0.354	BA
51064-1-E-FD3-005	Next To Room 101, Fountain	5/28/2016 5:00AM	0.583	BA
51064-1-S-FD4-001	Inside Room 100, Fountain	5/28/2016 5:00AM	3.96	BA
51064-1-S-FD4-002	Inside Room 100, Fountain	5/28/2016 5:00AM	1.19	BA
51064-1-S-FD4-003	Inside Room 100, Fountain	5/28/2016 5:00AM	1.01	BA
51064-1-S-FD4-004	Inside Room 100, Fountain	5/28/2016 5:00AM	1	BA
51064-1-S-FD4-005	Inside Room 100, Fountain	5/28/2016 5:00AM	0.881	BA
51064-2-E-FD1-001	Next To Room 209, Fountain	5/28/2016 5:00AM	3.14	BA
51064-2-E-FD1-002	Next To Room 209, Fountain	5/28/2016 5:00AM	2.24	BA
51064-2-E-FD1-003	Next To Room 209, Fountain	5/28/2016 5:00AM	2.1	BA
51064-2-E-FD1-004	Next To Room 209, Fountain	5/28/2016 5:00AM	1.62	BA
51064-2-E-FD1-005	Next To Room 209, Fountain	5/28/2016 5:00AM	0.976	BA
51064-2-W-FD2-001	Next To Balcony, Fountain	5/28/2016 5:00AM	1.77	BA
51064-2-W-FD2-002	Next To Balcony, Fountain	5/28/2016 5:00AM	2.25	BA
51064-2-W-FD2-003	Next To Balcony, Fountain	5/28/2016 5:00AM	2.06	BA
51064-2-W-FD2-004	Next To Balcony, Fountain	5/28/2016 5:00AM	1.75	BA
51064-2-W-FD2-005	Next To Balcony, Fountain	5/28/2016 5:00AM	2.2	BA
51064-2-E-FD3-001	Next To Room 201, Fountain	5/28/2016 5:00AM	0.661	BA
51064-2-E-FD3-002	Next To Room 201, Fountain	5/28/2016 5:00AM	5.15	BA
51064-2-E-FD3-003	Next To Room 201, Fountain	5/28/2016 5:00AM	0.31	BA
51064-2-E-FD3-004	Next To Room 201, Fountain	5/28/2016 5:00AM	0.336	BA
51064-2-E-FD3-005	Next To Room 201, Fountain	5/28/2016 5:00AM	0.254	BA
51064-3-E-FD1-001	Next To Room 304, Fountain	5/28/2016 5:00AM	2.17	BA
51064-3-E-FD1-002	Next To Room 304, Fountain	5/28/2016 5:00AM	1.44	BA
51064-3-E-FD1-003	Next To Room 304, Fountain	5/28/2016 5:00AM	1.31	BA
51064-3-E-FD1-004	Next To Room 304, Fountain	5/28/2016 5:00AM	1.45	BA
51064-3-E-FD1-005	Next To Room 304, Fountain	5/28/2016 5:00AM	1.51	BA
51064-3-W-FD2-001	Next To Gym, Fountain	5/28/2016 5:00AM	6.69	BA
51064-3-W-FD2-002	Next To Gym, Fountain	5/28/2016 5:00AM	2.99	BA
51064-3-W-FD2-003	Next To Gym, Fountain	5/28/2016 5:00AM	4.07	BA
51064-3-W-FD2-004	Next To Gym, Fountain	5/28/2016 5:00AM	2.13	BA
51064-3-W-FD2-005	Next To Gym, Fountain	5/28/2016 5:00AM	2.95	BA
51064-3-E-FD3-001	Next To Room 301, Fountain	5/28/2016 5:00AM	0.908	BA
51064-3-E-FD3-002	Next To Room 301, Fountain	5/28/2016 5:00AM	0.715	BA
51064-3-E-FD3-003	Next To Room 301, Fountain	5/28/2016 5:00AM	1.45	BA
51064-3-E-FD3-004	Next To Room 301, Fountain	5/28/2016 5:00AM	0.855	BA
51064-3-E-FD3-005	Next To Room 301, Fountain	5/28/2016 5:00AM	0.84	BA
51064-1-S-FD1-001	Addition-Next To Elevator Lobby, Fountain (1)	5/28/2016 5:00AM	<0.120	ND
51064-1-S-FD1-002	Addition-Next To Elevator Lobby, Fountain (1)	5/28/2016 5:00AM	<0.120	ND
51064-1-S-FD1-003	Addition-Next To Elevator Lobby, Fountain (1)	5/28/2016 5:00AM	<0.120	ND
51064-1-S-FD1-004	Addition-Next To Elevator Lobby, Fountain (1)	5/28/2016 5:00AM	<0.120	ND
51064-1-S-FD1-005	Addition-Next To Elevator Lobby, Fountain (1)	5/28/2016 5:00AM	<0.120	ND
51064-1-S-FD2-001	Addition- Next To Elevator Lobby, Fountain (2)	5/28/2016 5:00AM	<0.120	ND
51064-1-S-FD2-002	Addition- Next To Elevator Lobby, Fountain (2)	5/28/2016 5:00AM	<0.120	ND
51064-1-S-FD2-003	Addition- Next To Elevator Lobby, Fountain (2)	5/28/2016 5:00AM	<0.120	ND
51064-1-S-FD2-004	Addition- Next To Elevator Lobby, Fountain (2)	5/28/2016 5:00AM	<0.120	ND
51064-1-S-FD2-005	Addition- Next To Elevator Lobby, Fountain (2)	5/28/2016 5:00AM	<0.120	ND
51064-1-S-SD3-001	Addition- Kitchen, Sink	5/28/2016 5:00AM	0.261	BA
51064-1-S-SD3-002	Addition- Kitchen, Sink	5/28/2016 5:00AM	<0.120	ND
51064-1-S-SD3-003	Addition- Kitchen, Sink	5/28/2016 5:00AM	<0.120	ND
51064-1-S-SD3-004	Addition- Kitchen, Sink	5/28/2016 5:00AM	0.217	BA
51064-1-S-SD3-005	Addition- Kitchen, Sink	5/28/2016 5:00AM	0.142	BA
51064-2-S-FD2-001	Addition-Next To Elevator Lobby 2nd FL, Fountain	5/28/2016 5:00AM	<0.120	ND
51064-2-S-FD2-002	Addition-Next To Elevator Lobby 2nd FL, Fountain	5/28/2016 5:00AM	<0.120	ND
51064-2-S-FD2-003	Addition-Next To Elevator Lobby 2nd FL, Fountain	5/28/2016 5:00AM	<0.120	ND
51064-2-S-FD2-004	Addition-Next To Elevator Lobby 2nd FL, Fountain	5/28/2016 5:00AM	<0.120	ND
51064-2-S-FD2-005	Addition-Next To Elevator Lobby 2nd FL, Fountain	5/28/2016 5:00AM	<0.120	ND
51064-3-S-FD1-001	Addition-Next To Elevator Lobby 3rd FL, Fountain (1)	5/28/2016 5:00AM	<0.120	ND
51064-3-S-FD1-002	Addition-Next To Elevator Lobby 3rd FL, Fountain (1)	5/28/2016 5:00AM	<0.120	ND
51064-3-S-FD1-003	Addition-Next To Elevator Lobby 3rd FL, Fountain (1)	5/28/2016 5:00AM	<0.120	ND
51064-3-S-FD1-004	Addition-Next To Elevator Lobby 3rd FL, Fountain (1)	5/28/2016 5:00AM	<0.120	ND
51064-3-S-FD1-005	Addition-Next To Elevator Lobby 3rd FL, Fountain (1)	5/28/2016 5:00AM	<0.120	ND
51064-3-S-FD2-001	Addition-Next To Elevator Lobby 3rd FL, Fountain (2)	5/28/2016 5:00AM	<0.120	ND
51064-3-S-FD2-002	Addition-Next To Elevator Lobby 3rd FL, Fountain (2)	5/28/2016 5:00AM	<0.120	ND
51064-3-S-FD2-003	Addition-Next To Elevator Lobby 3rd FL, Fountain (2)	5/28/2016 5:00AM	<0.120	ND
51064-3-S-FD2-004	Addition-Next To Elevator Lobby 3rd FL, Fountain (2)	5/28/2016 5:00AM	<0.120	ND
51064-3-S-FD2-005	Addition- Next To Elevator Lobby 3rd FL, Fountain (2)	5/28/2016 5:00AM	<0.120	ND

EPA ACTION LEVEL FOR LEAD IS 15 ppb or 15 µg/L

SPREADSHEET LEGEND
ND Not Detected at the Reporting Limit
BA Below EPA Action Level of 15 ppb
AA Above EPA Action Level