



School Lead Water Testing Summary

School Short Name **South Shore**
Address 1415 E. 70th St.
Facility ID 51399
CPS Team Member Craig Edgerley
MEC Team Member Evan Christian

Length of time water remained in pipes before sampled [Approx 8-9 hours](#)
Water last used (Time and date) [Approx 10 PM 5/5/16](#)
Date of test [5/6/2016](#)
Report based on lab results dated [5/13/2016](#)

Sample ID #	Sample Location	Sample Collection Time & Date	Test Results (ppb)	ppb Level
51399-1-K-CS-01	Kitchen	6:45 AM 5/6/16	ND	-
51399-1-NW-F-02	Hallway by Room 102	6:48 AM 5/6/16	ND	-
51399-1-SE-F-03	Hallway by Room 115	6:51 AM 5/6/16	ND	-
51399-2-SW-F-04	Hallway by Room 222	6:53 AM 5/6/16	ND	-
51399-2-NE-F-05	Hallway by Room 208	6:56 AM 5/6/16	ND	-

EPA ACTION LEVEL FOR LEAD IS 15 ppb or 15 µg/L

SPREADSHEET LEGEND

ND-Not Detected at the Reporting Limit
BA-Below EPA Action Level of 15 ppb
AA-Above EPA Action Level

Chicago Public Schools - Department of Facility Operations